


Less is more



Multi Split

Simply extend your comfort!

A Daikin multi split system offers you unexpected possibilities in creating a comfortable and cosy home. This is your solution to reduce limitations like environmental impact and financial aspects.

Less mounting space, less visibility, less sound

- › **Save space:** Drastically reduce the space required for placing a number of units on your facade
- › **Less visibility:** Enjoy your nice ambience. Finding just one hiding place is much easier
- › **Less noise:** Only one unit in operation is much quieter than two or more units

Easier installation, wiring, piping and maintenance

- › **Save mounting equipment:** Wherever you want to place an outdoor unit, for every unit you will need a mounting for a secure fixing and problem-free operation
- › **Save time:** The physical installation, wiring, drain piping as well as the initial setup of only one system is much easier and faster
- › When using only one outdoor unit instead of two or more, the statistical probability of a **possible technical defect is reduced** with every unit that you do not need.

Lower power consumption, high efficiency


- › **Less power consumption:** Our big compressors can work more efficiently than various smaller ones with the same capacity in sum. Also save a significant proportion of energy thanks to standby mode

More flexibility: Connect up to 5 indoor units of any style

There are many possibilities in comfort you can profit from a multi split solution:

- › **Up to 5 indoor units** connectable to only one outdoor unit
- › Every single indoor unit can be **regulated separately**
- › Choose from **a greater variety** of connectable indoor unit types out of our split and Sky Air series
- › Use low capacity indoor units specially **designed for small rooms** which can only be connected to a multi split system
- › Are you planning an **additional indoor unit later on?** Just decide now for an outdoor unit with higher capacity and simply connect it later

Pair split or multi split combination – the direct system comparison



Conventional pair split installation for air-conditioning three rooms

Solution for the same situation with only one multi split outdoor unit

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
2MXM40N2V1B	1.5	1.50	---	1.30	1.50	2.00	0.33	0.31	0.40	1.78	1.70	2.17	79	---	---	---	---	---	---	---
	2.0	2.00	---	1.30	2.00	2.40	0.33	0.44	0.57	1.78	2.38	3.09	79	---	---	---	---	---	---	---
	2.5	2.50	---	1.30	2.50	3.00	0.33	0.61	0.80	1.78	3.33	4.40	79	---	---	---	---	---	---	---
	3.5	3.50	---	1.30	3.50	4.00	0.33	1.04	1.35	1.78	5.71	7.38	79	---	---	---	---	---	---	---
	1.5+1.5	1.50	1.50	1.50	3.00	3.60	0.31	0.60	0.73	1.67	3.33	4.00	79	4.97	A	302	A+++	8.66	3.00	122
	1.5+2.0	1.50	2.00	1.50	3.50	4.00	0.31	0.79	0.91	1.67	4.35	4.98	79	4.43	A	396	A+++	8.60	3.50	143
	1.5+2.5	1.50	2.50	1.50	4.00	4.20	0.31	0.98	1.03	1.67	5.37	5.64	79	4.10	A	488	A+++	8.55	4.00	164
	1.5+3.5	1.20	2.80	1.50	4.00	4.40	0.31	0.96	1.06	1.67	5.30	5.83	79	4.16	A	481	A++	8.26	4.00	170
	2.0+2.0	2.00	2.00	1.50	4.00	4.20	0.31	0.97	1.02	1.67	5.34	5.61	79	4.13	A	486	A+++	8.53	4.00	165
	2.0+2.5	1.78	2.22	1.50	4.00	4.30	0.31	0.96	1.04	1.67	5.30	5.70	79	4.16	A	481	A+++	8.50	4.00	165
	2.0+3.5	1.45	2.55	1.50	4.00	4.50	0.31	0.95	1.08	1.67	5.25	5.91	79	4.20	A	477	A++	8.19	4.00	171
	2.5+2.5	2.00	2.00	1.50	4.00	4.40	0.31	0.96	1.06	1.67	5.27	5.80	79	4.18	A	479	A++	8.36	4.00	168
	2.5+3.5	1.67	2.33	1.50	4.00	4.60	0.31	0.94	1.09	1.67	5.20	5.98	79	4.24	A	472	A++	8.11	4.00	173

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	Energy label	Seasonal data				
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				Label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
2MXM40N2V1B	1.5	2.00	---	1.00	2.00	3.30	0.26	0.68	1.04	1.43	3.66	5.69	79	---	---	---	---	---	---	---
	2.0	3.00	---	1.00	3.00	3.70	0.26	0.83	1.24	1.43	4.52	6.78	79	---	---	---	---	---	---	---
	2.5	3.40	---	1.00	3.40	4.10	0.26	1.02	1.48	1.43	5.59	8.09	79	---	---	---	---	---	---	---
	3.5	3.80	---	1.00	3.80	4.40	0.26	1.28	1.71	1.43	7.02	9.40	79	---	---	---	---	---	---	---
	1.5+1.5	1.75	1.75	1.20	3.50	4.30	0.24	0.80	0.99	1.31	4.43	5.45	79	4.35	A	A++	4.62	3.00	908	0.50
	1.5+2.0	1.63	2.17	1.20	3.80	4.50	0.24	0.88	1.04	1.31	4.85	5.75	79	4.32	A	A++	4.61	3.20	972	0.70
	1.5+2.5	1.58	2.63	1.20	4.20	4.60	0.24	1.00	1.10	1.31	5.53	6.06	79	4.18	A	A++	4.60	3.20	972	0.60
	1.5+3.5	1.26	2.94	1.20	4.20	4.70	0.24	0.96	1.12	1.31	5.29	5.92	79	4.37	A	A++	4.63	3.20	968	0.50
	2.0+2.0	2.10	2.10	1.30	4.20	4.60	0.24	0.98	1.08	1.31	5.41	5.93	79	4.28	A	A++	4.64	3.20	966	0.60
	2.0+2.5	1.87	2.33	1.30	4.20	4.70	0.24	0.97	1.09	1.31	5.36	6.00	79	4.32	A	A++	4.60	3.20	973	0.50
	2.0+3.5	1.53	2.67	1.30	4.20	4.80	0.24	0.95	1.09	1.31	5.25	6.00	79	4.41	A	A++	4.60	3.20	974	0.40
	2.5+2.5	2.10	2.10	1.30	4.20	4.70	0.24	0.96	1.08	1.31	5.29	5.92	79	4.37	A	A++	4.60	3.20	974	0.50
	2.5+3.5	1.75	2.45	1.30	4.20	4.80	0.24	0.94	1.08	1.31	5.19	5.94	79	4.46	A	A++	4.61	3.20	971	0.40

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
2MXM50N2V1B	1.5	1.50	---	1.40	1.50	2.20	0.31	0.32	0.52	1.53	1.55	2.53	89	---	---	---	---	---	---	---
	2.0	2.00	---	1.40	2.00	2.60	0.31	0.47	0.69	1.53	2.25	3.37	89	---	---	---	---	---	---	---
	2.5	2.50	---	1.40	2.50	3.10	0.31	0.67	0.92	1.53	3.27	4.50	89	---	---	---	---	---	---	---
	3.5	3.50	---	1.40	3.50	4.00	0.31	1.09	1.42	1.53	5.32	6.95	89	---	---	---	---	---	---	---
	4.2	4.20	---	1.40	4.20	4.70	0.31	1.59	1.75	1.53	7.73	8.57	89	---	---	---	---	---	---	---
	5.0	5.00	---	1.60	5.00	5.30	0.33	1.30	1.44	1.64	6.33	7.01	89	---	---	---	---	---	---	---
	1.5+1.5	1.50	1.50	1.60	3.00	3.20	0.33	0.62	0.66	1.64	3.03	3.24	89	4.84	A	310	A+++	8.80	3.00	120
	1.5+2.0	1.50	2.00	1.60	3.50	3.70	0.33	0.76	0.80	1.64	3.71	3.93	89	4.61	A	380	A+++	8.74	3.50	141
	1.5+2.5	1.50	2.50	1.60	4.00	4.20	0.33	0.94	0.99	1.64	4.60	4.83	89	4.25	A	471	A+++	8.64	4.00	162
	1.5+3.5	1.50	3.50	1.60	5.00	5.00	0.33	1.25	1.25	1.64	6.10	6.10	89	4.01	A	624	A+++	8.52	5.00	206
	1.5+4.2	1.32	3.68	1.60	5.00	5.40	0.33	1.23	1.54	1.64	6.04	6.53	89	4.05	A	618	A+++	8.55	5.00	205
	1.5+5.0	1.15	3.85	1.80	5.00	5.50	0.33	1.23	1.68	1.64	5.99	6.59	89	4.08	A	613	A+++	8.50	5.00	206
	2.0+2.0	2.00	2.00	1.80	4.00	5.00	0.33	0.94	1.28	1.64	4.60	5.75	89	4.25	A	471	A+++	8.71	4.00	161
	2.0+2.5	2.00	2.50	1.80	4.50	5.10	0.33	1.07	1.31	1.64	5.23	5.93	89	4.21	A	535	A+++	8.67	4.50	182
	2.0+3.5	1.82	3.18	1.80	5.00	5.40	0.33	1.24	1.49	1.64	6.05	6.54	89	4.04	A	619	A+++	8.54	5.00	205
	2.0+4.2	1.61	3.39	1.80	5.00	5.50	0.33	1.23	1.51	1.64	6.01	6.62	89	4.07	A	615	A+++	8.54	5.00	205
	2.0+5.0	1.43	3.57	1.80	5.00	5.50	0.33	1.22	1.44	1.64	5.95	6.55	89	4.11	A	609	A+++	8.51	5.00	208
	2.5+2.5	2.50	2.50	1.80	5.00	5.30	0.33	1.25	1.42	1.64	6.10	6.47	89	4.01	A	624	A+++	8.53	5.00	205
	2.5+3.5	2.08	2.92	1.80	5.00	5.40	0.33	1.23	1.43	1.64	6.02	6.51	89	4.06	A	616	A+++	8.56	5.00	205
	2.5+4.2	1.87	3.13	1.80	5.00	5.50	0.33	1.22	1.45	1.64	5.98	6.58	89	4.09	A	612	A+++	8.57	5.00	204
	2.5+5.0	1.67	3.33	1.80	5.00	5.50	0.33	1.21	1.38	1.64	5.92	6.52	89	4.13	A	606	A+++	8.52	5.00	206
	3.5+3.5	2.50	2.50	1.80	5.00	5.40	0.33	1.22	1.42	1.64	5.95	6.43	89	4.11	A	609	A+++	8.57	5.00	205
	3.5+4.2	2.27	2.73	1.80	5.00	5.50	0.33	1.21	1.40	1.64	5.90	6.49	89	4.14	A	604	A+++	8.60	5.00	204
	3.5+5.0	2.06	2.94	1.80	5.00	5.50	0.33	1.20	1.34	1.64	5.85	6.44	89	4.18	A	599	A+++	8.52	5.00	206
4.2+4.2	2.50	2.50	1.80	5.00	5.50	0.33	1.20	1.38	1.64	5.88	6.47	89	4.16	A	601	A+++	8.56	5.00	205	

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	Energy label	Seasonal data				
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				Label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
2MXM50N2V1B	1.5	2.00	---	1.10	2.00	3.30	0.29	0.68	0.95	1.44	3.31	4.66	89	---	---	---	---	---	---	---
	2.0	3.00	---	1.10	3.00	3.70	0.27	0.82	1.13	1.33	3.99	5.52	89	---	---	---	---	---	---	---
	2.5	3.40	---	1.10	3.40	4.10	0.25	0.99	1.34	1.23	4.81	6.54	89	---	---	---	---	---	---	---
	3.5	4.00	---	1.10	4.00	4.60	0.25	1.24	1.53	1.23	6.03	7.46	89	---	---	---	---	---	---	---
	4.2	4.60	---	1.10	4.60	5.00	0.23	1.49	1.81	1.12	7.27	8.85	89	---	---	---	---	---	---	---
	5.0	5.50	---	1.20	5.50	5.60	0.23	1.35	1.51	1.12	6.56	9.01	89	---	---	---	---	---	---	---
	1.5+1.5	2.00	2.00	1.20	4.00	4.54	0.23	0.87	0.99	1.12	4.27	4.85	89	4.58	A	A++	4.79	3.30	965	0.50
	1.5+2.0	1.89	2.51	1.20	4.40	4.89	0.23	1.02	1.13	1.12	4.97	5.53	89	4.33	A	A++	4.66	3.80	1140	0.80
	1.5+2.5	1.80	3.00	1.20	4.80	5.19	0.23	1.18	1.27	1.12	5.75	6.22	89	4.08	A	A++	4.64	3.80	1146	0.60
	1.5+3.5	1.56	3.64	1.20	5.20	5.70	0.25	1.28	1.40	1.23	6.25	6.86	89	4.07	A	A++	4.61	4.00	1214	0.60
	1.5+4.2	1.47	4.13	1.20	5.60	5.96	0.25	1.37	1.46	1.23	6.71	7.15	89	4.08	A	A++	4.62	4.10	1241	0.70
	1.5+5.0	1.29	4.31	1.20	5.60	6.16	0.25	1.37	1.50	1.23	6.68	7.35	89	4.10	A	A++	4.63	4.20	1269	0.80
	2.0+2.0	2.60	2.60	1.20	5.20	5.70	0.23	1.27	1.40	1.12	6.22	6.82	89	4.09	A	A++	4.61	4.00	1214	0.60
	2.0+2.5	2.49	3.11	1.20	5.60	5.80	0.23	1.37	1.42	1.12	6.68	6.92	89	4.10	A	A++	4.61	4.10	1244	0.70
	2.0+3.5	2.04	3.56	1.20	5.60	5.90	0.25	1.36	1.43	1.23	6.65	7.01	89	4.12	A	A++	4.61	4.20	1275	0.80
	2.0+4.2	1.81	3.79	1.20	5.60	6.00	0.25	1.36	1.46	1.23	6.63	7.11	89	4.13	A	A++	4.63	4.20	1268	0.80
	2.0+5.0	1.60	4.00	1.20	5.60	6.20	0.25	1.35	1.50	1.23	6.60	7.31	89	4.15	A	A++	4.68	4.20	1255	0.80
	2.5+2.5	2.80	2.80	1.20	5.60	5.80	0.23	1.37	1.42	1.12	6.71	6.95	89	4.08	A	A++	4.61	4.20	1275	0.80
	2.5+3.5	2.33	3.27	1.20	5.60	6.00	0.25	1.38	1.48	1.23	6.76	7.25	89	4.05	A	A++	4.62	4.20	1272	0.80
	2.5+4.2	2.09	3.51	1.20	5.60	6.10	0.25	1.39	1.51	1.23	6.79	7.40	89	4.03	A	A++	4.65	4.20	1265	0.80
	2.5+5.0	1.87	3.73	1.30	5.60	6.30	0.25	1.41	1.58	1.23	6.88	7.74	89	3.98	A	A++	4.71	4.20	1249	0.80
	3.5+3.5	2.80	2.80	1.30	5.60	6.10	0.25	1.40	1.52	1.23	6.83	7.44	89	4.01	A	A++	4.66	4.20	1262	0.80
	3.5+4.2	2.55	3.05	1.30	5.60	6.20	0.25	1.40	1.55	1.23	6.84	7.58	89	4.00	A	A++	4.67	4.20	1258	0.80
	3.5+5.0	2.31	3.29	1.30	5.60	6.40	0.25	1.42	1.63	1.23	6.95	7.95	89	3.94	A	A++	4.75	4.20	1238	0.80
4.2+4.2	2.80	2.80	1.30	5.60	6.30	0.25	1.41	1.58	1.23	6.88	7.74	89	3.98	A	A++	4.70	4.20	1251	0.80	

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity [kW]		Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room A	Room B	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.	
2MXM68N2V1B	1,5	1,60	---	1,52	1,60	2,49	0,40	0,42	0,59	1,82	1,98	2,71	95
	2,0	2,00	---	1,66	2,00	2,68	0,42	0,43	0,60	1,91	2,08	2,75	95
	2,5	2,50	---	1,74	2,50	3,44	0,44	0,55	0,82	2,00	2,62	3,77	95
	3,5	3,50	---	1,93	3,50	4,86	0,46	0,80	1,43	2,09	3,84	6,53	95
	4,2	---	4,20	1,93	4,20	5,33	0,46	0,82	1,44	2,09	3,93	6,57	95
	5,0	---	5,00	1,94	5,00	6,03	0,44	1,50	2,13	2,00	7,20	9,77	95
	6,0	---	6,00	1,94	6,00	6,51	0,44	1,52	2,13	2,00	7,29	9,77	95
	1.5+1.5	1,50	1,50	1,95	3,00	4,79	0,40	0,60	1,15	1,81	2,75	5,25	95
	1.5+2.0	1,50	2,00	1,95	3,50	4,96	0,40	0,74	1,22	1,81	3,38	5,58	95
	1.5+2.5	1,50	2,50	1,95	4,00	5,28	0,40	0,89	1,36	1,81	4,08	6,23	95
	1.5+3.5	1,50	3,50	1,95	5,00	6,17	0,39	1,24	1,83	1,77	5,68	8,39	95
	1.5+4.2	1,50	4,20	1,95	5,70	6,39	0,39	1,51	1,96	1,77	6,90	8,96	95
	1.5+5.0	1,50	5,00	1,95	6,50	7,08	0,38	1,78	2,23	1,73	8,14	10,22	95
	1.5+6.0	1,36	5,44	1,96	6,80	7,59	0,37	1,93	2,36	1,68	8,82	10,79	95
	2.0+2.0	2,00	2,00	1,95	4,00	5,12	0,40	0,89	1,29	1,81	4,08	5,91	95
	2.0+2.5	2,00	2,50	1,95	4,50	5,44	0,40	1,06	1,43	1,81	4,86	6,56	95
	2.0+3.5	2,00	3,50	1,95	5,50	6,30	0,39	1,39	1,91	1,77	6,38	8,76	95
	2.0+4.2	2,00	4,20	1,95	6,20	6,51	0,39	1,70	2,05	1,77	7,77	9,37	95
	2.0+5.0	1,94	4,86	1,95	6,80	7,26	0,38	1,90	2,36	1,73	8,68	10,79	95
	2.0+6.0	1,70	5,10	1,96	6,80	7,71	0,37	1,92	2,45	1,68	8,78	11,20	95
	2.5+2.5	2,50	2,50	1,95	5,00	6,10	0,41	1,20	1,78	1,89	5,51	8,15	95
	2.5+3.5	2,50	3,50	1,95	6,00	6,57	0,40	1,54	2,11	1,81	7,03	9,65	95
	2.5+4.2	2,50	4,20	1,95	6,70	6,95	0,40	1,79	2,38	1,81	8,21	10,88	95
	2.5+5.0	2,27	4,53	1,95	6,80	7,37	0,37	1,78	2,45	1,68	8,15	11,20	95
	2.5+6.0	2,00	4,80	1,96	6,80	7,71	0,35	1,76	2,45	1,60	8,06	11,20	95
	3.5+3.5	3,40	3,40	1,95	6,80	7,13	0,38	1,73	2,37	1,73	7,90	10,83	95
	3.5+4.2	3,09	3,71	1,95	6,80	7,24	0,38	1,72	2,46	1,73	7,87	11,24	95
	3.5+5.0	2,80	4,00	1,95	6,80	7,76	0,35	1,68	2,78	1,60	7,71	12,71	95
3.5+6.0	2,51	4,29	2,26	6,80	8,07	0,40	1,67	2,72	1,81	7,63	12,46	95	
4.2+4.2*	3,40	3,40	1,95	6,80	7,14	0,38	1,71	2,37	1,73	7,84	10,83	95	
4.2+5.0*	3,10	3,70	1,95	6,80	7,77	0,35	1,68	2,78	1,60	7,68	12,71	95	
4.2+6.0*	2,80	4,00	2,26	6,80	8,08	0,40	1,66	2,72	1,81	7,60	12,46	95	

Heating

Outdoor unit	Indoor unit	Heating capacity [kW]		Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room A	Room B	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.	
2MXM68N2V1B	1,5	2,70	---	1,47	2,70	4,08	0,42	0,72	1,22	1,91	3,35	5,59	95
	2,0	2,72	---	1,48	2,72	4,09	0,43	0,73	1,28	1,95	3,39	5,64	95
	2,5	3,40	---	1,44	3,40	4,30	0,42	1,02	1,37	1,91	4,72	6,08	95
	3,5	4,30	---	1,45	4,30	4,90	0,40	1,41	1,75	1,82	6,50	7,15	95
	4,2	---	4,32	1,44	4,32	5,70	0,40	1,40	2,04	1,82	6,46	7,15	95
	5,0	---	5,60	1,66	5,60	6,90	0,39	1,82	2,59	1,78	8,43	8,70	95
	6,0	---	7,90	1,88	7,90	8,91	0,37	2,62	2,64	1,69	12,13	12,08	95
	1.5+1.5	2,65	2,65	1,65	5,30	7,38	0,36	1,19	1,83	1,63	5,45	8,38	95
	1.5+2.0	2,44	3,26	1,65	5,70	7,76	0,36	1,31	1,99	1,63	6,00	9,09	95
	1.5+2.5	2,29	3,81	1,65	6,10	7,95	0,36	1,43	2,06	1,63	6,55	9,43	95
	1.5+3.5	2,07	4,83	1,80	6,90	8,50	0,37	1,69	2,35	1,68	7,74	10,74	95
	1.5+4.2	1,97	5,53	1,80	7,50	8,85	0,37	1,90	2,57	1,68	8,70	11,75	95
	1.5+5.0	1,89	6,31	2,18	8,20	10,38	0,45	2,13	2,91	2,06	9,75	13,31	95
	1.5+6.0	1,72	6,88	2,46	8,60	10,58	0,48	2,28	2,67	2,19	10,44	12,21	95
	2.0+2.0	3,25	3,25	1,65	6,50	7,95	0,36	1,37	2,31	1,63	6,28	9,47	95
	2.0+2.5	3,07	3,83	1,65	6,90	8,12	0,36	1,52	2,32	1,63	6,96	9,81	95
	2.0+3.5	2,73	4,77	1,80	7,50	8,67	0,37	1,75	2,43	1,68	8,01	11,12	95
	2.0+4.2	2,58	5,42	1,80	8,00	9,03	0,37	1,98	2,66	1,68	9,07	12,17	95
	2.0+5.0	2,46	6,14	2,18	8,60	10,56	0,45	2,26	3,00	2,06	10,35	13,73	95
	2.0+6.0	2,15	6,45	2,46	8,60	10,75	0,48	2,24	2,74	2,19	10,26	12,55	95
	2.5+2.5	3,60	3,60	1,65	7,20	8,49	0,36	1,62	2,36	1,63	7,42	10,78	95
	2.5+3.5	3,29	4,61	1,89	7,90	9,03	0,38	1,91	2,66	1,72	8,75	12,17	95
	2.5+4.2	3,10	5,20	1,89	8,30	9,29	0,38	2,11	2,82	1,72	9,66	12,93	95
	2.5+5.0	2,87	5,73	2,27	8,60	10,68	0,46	2,24	3,09	2,11	10,26	14,15	95
	2.5+6.0	2,53	6,07	2,55	8,60	10,88	0,50	2,22	2,77	2,28	10,17	12,67	95
	3.5+3.5	4,30	4,30	2,17	8,60	9,38	0,42	2,26	2,86	1,94	10,35	13,09	95
	3.5+4.2	3,91	4,69	2,17	8,60	9,47	0,42	2,26	2,91	1,94	10,35	13,31	95
	3.5+5.0	3,54	5,06	2,56	8,60	10,90	0,51	2,22	3,13	2,32	10,17	14,32	95
3.5+6.0	3,17	5,43	2,74	8,60	11,01	0,52	2,21	2,76	2,37	10,12	12,63	95	
4.2+4.2*	4,30	4,30	2,17	8,60	9,56	0,42	2,22	2,94	1,94	10,17	13,47	95	
4.2+5.0*	3,93	4,67	2,56	8,60	10,91	0,51	2,21	3,19	2,32	10,12	14,61	95	
4.2+6.0*	3,54	5,06	2,74	8,60	11,02	0,51	2,20	2,79	2,32	10,07	12,76	95	

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
3MXM40N2V1B8	1.50	1.50	---	---	1.40	1.50	2.20	0.32	0.35	0.46	1.52	1.63	2.2	91	---	---	---	---	---	---	
	2.00	2.00	---	---	1.40	2.00	2.90	0.32	0.48	0.71	1.52	2.28	3.4	91	---	---	---	---	---	---	
	2.50	2.50	---	---	1.40	2.50	3.10	0.32	0.64	0.82	1.52	3.05	3.9	91	---	---	---	---	---	---	
	3.50	3.50	---	---	1.40	3.50	4.10	0.32	0.98	1.19	1.52	4.68	5.7	91	---	---	---	---	---	---	
	1.5+1.5	1.50	1.50	---	1.60	3.00	4.20	0.34	0.59	1.14	1.63	2.82	5.44	91	5.12	A	293	A+++	8.64	3.00	122
	1.5+2.0	1.50	2.00	---	1.60	3.50	4.20	0.34	0.71	1.12	1.63	3.40	5.33	91	4.96	A	353	A+++	8.59	3.50	143
	1.5+2.5	1.50	2.50	---	1.60	4.00	4.20	0.34	0.86	1.10	1.63	4.11	5.33	91	4.68	A	427	A+++	8.51	4.00	164
	1.5+3.5	1.20	2.80	---	1.60	4.00	4.20	0.34	0.85	1.08	1.63	4.07	5.33	91	4.72	A	424	A+++	8.50	4.00	165
	2.0+2.0	2.00	2.00	---	1.60	4.00	4.50	0.34	0.84	1.09	1.63	4.02	5.22	91	4.76	A	420	A+++	8.52	4.00	165
	2.0+2.5	1.78	2.22	---	1.60	4.00	4.50	0.34	0.83	1.07	1.63	3.97	5.22	91	4.82	A	415	A+++	8.52	4.00	165
	2.0+3.5	1.45	2.55	---	1.60	4.00	4.50	0.34	0.83	1.03	1.63	3.97	5.22	91	4.86	A	412	A+++	8.50	4.00	165
	2.5+2.5	2.00	2.00	---	1.60	4.00	4.50	0.34	0.83	1.05	1.63	3.97	5.22	91	4.84	A	413	A+++	8.51	4.00	165
	2.5+3.5	1.67	2.33	---	1.60	4.00	4.50	0.34	0.82	1.01	1.63	3.92	5.22	91	4.88	A	410	A+++	8.50	4.00	165
	3.5+3.5	2.00	2.00	---	1.60	4.00	4.50	0.34	0.82	0.99	1.63	3.92	5.11	91	4.92	A	407	A+++	8.50	4.00	165
	1.5+1.5+1.5	1.33	1.33	1.33	1.70	4.00	4.60	0.36	0.78	0.98	1.74	3.73	4.68	91	5.18	A	386	A+++	8.55	4.00	164
	1.5+1.5+2.0	1.20	1.20	1.60	1.70	4.00	4.60	0.36	0.77	0.96	1.74	3.68	4.68	91	5.20	A	385	A+++	8.55	4.00	164
	1.5+1.5+2.5	1.09	1.09	1.82	1.70	4.00	4.60	0.36	0.77	0.94	1.74	3.68	4.68	91	5.22	A	383	A+++	8.54	4.00	164
	1.5+1.5+3.5	0.92	0.92	2.15	1.70	4.00	4.60	0.36	0.76	0.90	1.74	3.64	4.68	91	5.26	A	380	A+++	8.53	4.00	165
	1.5+2.0+2.0	1.09	1.45	1.45	1.70	4.00	4.60	0.36	0.77	0.92	1.74	3.68	4.68	91	5.25	A	381	A+++	8.53	4.00	164
	1.5+2.0+2.5	1.00	1.33	1.67	1.70	4.00	4.60	0.36	0.76	0.91	1.74	3.64	4.68	91	5.29	A	378	A+++	8.54	4.00	164
	1.5+2.0+3.5	0.86	1.14	2.00	1.70	4.00	4.60	0.36	0.76	0.89	1.74	3.64	4.68	91	5.31	A	377	A+++	8.53	4.00	165
	1.5+2.5+2.5	0.92	1.54	1.54	1.70	4.00	4.60	0.36	0.76	0.87	1.74	3.64	4.68	91	5.27	A	380	A+++	8.53	4.00	165
	2.0+2.0+2.0	1.33	1.33	1.33	1.70	4.00	4.60	0.36	0.76	0.85	1.74	3.64	4.68	91	5.30	A	377	A+++	8.52	4.00	214
	2.0+2.0+2.5	1.23	1.23	1.54	1.70	4.00	4.60	0.36	0.76	0.83	1.74	3.64	4.68	91	5.32	A	376	A+++	8.51	4.00	165
	2.0+2.5+2.5	1.14	1.43	1.43	1.70	4.00	4.60	0.36	0.75	0.81	1.74	3.59	4.68	91	5.35	A	374	A+++	8.50	4.00	165

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				Back-up heater capacity at -10°C
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	
3MXM40N2V1B8	1.50	2.30	---	---	1.10	2.30	3.30	0.30	0.60	0.82	1.38	2.77	3.83	93	---	---	---	---	---	---	
	2.00	2.70	---	---	1.10	2.70	3.70	0.30	0.76	1.23	1.38	3.51	5.75	93	---	---	---	---	---	---	
	2.50	3.40	---	---	1.10	3.40	4.10	0.30	1.01	1.28	1.38	4.68	5.96	93	---	---	---	---	---	---	
	3.50	4.20	---	---	1.10	4.20	4.80	0.30	1.42	1.71	1.38	6.60	7.98	93	---	---	---	---	---	---	
	1.5+1.5	1.80	1.80	---	1.20	3.60	5.00	0.32	0.69	1.30	1.49	3.23	6.07	93	5.25	A	A++	4.60	3.60	1096	0.50
	1.5+2.0	1.54	2.06	---	1.20	3.60	5.00	0.32	0.69	1.28	1.49	3.23	5.96	93	5.29	A	A++	4.62	3.60	1091	0.50
	1.5+2.5	1.50	2.50	---	1.20	4.00	5.00	0.32	0.86	1.26	1.49	4.03	5.96	93	4.68	A	A+	4.39	4.20	1338	0.70
	1.5+3.5	1.38	3.22	---	1.20	4.60	5.00	0.32	0.98	1.22	1.49	4.59	5.96	93	4.72	A	A+	4.28	4.80	1570	0.80
	2.0+2.0	2.30	2.30	---	1.20	4.60	5.00	0.32	0.97	1.25	1.49	4.54	5.85	93	4.76	A	A+	4.24	4.80	1582	0.90
	2.0+2.5	2.04	2.56	---	1.20	4.60	5.00	0.32	0.98	1.23	1.49	4.59	5.85	93	4.72	A	A+	4.27	4.80	1572	0.90
	2.0+3.5	1.67	2.93	---	1.20	4.60	5.00	0.32	0.97	1.19	1.49	4.54	5.85	93	4.76	A	A+	4.30	4.80	1560	0.80
	2.5+2.5	2.30	2.30	---	1.20	4.60	5.00	0.32	0.96	1.21	1.49	4.49	5.85	93	4.84	A	A+	4.34	4.80	1548	0.90
	2.5+3.5	1.92	2.68	---	1.20	4.60	5.00	0.32	0.95	1.17	1.49	4.45	5.85	93	4.88	A	A+	4.37	4.80	1537	0.80
	3.5+3.5	2.30	2.30	---	1.20	4.60	5.00	0.32	0.94	1.15	1.49	4.40	5.75	93	4.92	A	A+	4.38	5.00	1598	0.90
	1.5+1.5+1.5	1.53	1.53	1.53	1.30	4.60	5.10	0.32	0.89	1.02	1.49	4.17	4.79	93	5.18	A	A++	4.65	5.00	1505	0.90
	1.5+1.5+2.0	1.38	1.38	1.84	1.30	4.60	5.10	0.32	0.89	1.01	1.49	4.17	4.72	93	5.2	A	A++	4.63	5.00	1511	0.90
	1.5+1.5+2.5	1.25	1.25	2.09	1.30	4.60	5.10	0.32	0.89	0.99	1.49	4.17	4.63	93	5.22	A	A++	4.61	5.00	1517	0.90
	1.5+1.5+3.5	1.06	1.06	2.48	1.30	4.60	5.10	0.32	0.88	0.97	1.49	4.12	4.53	93	5.26	A	A++	4.61	5.00	1518	0.90
	1.5+2.0+2.0	1.25	1.67	1.67	1.30	4.60	5.10	0.32	0.88	0.95	1.49	4.12	4.44	93	5.25	A	A++	4.60	5.00	1520	0.90
	1.5+2.0+2.5	1.15	1.53	1.92	1.30	4.60	5.10	0.32	0.87	0.93	1.49	4.07	4.35	93	5.29	A	A++	4.60	5.00	1521	0.90
	1.5+2.0+3.5	0.99	1.31	2.30	1.30	4.60	5.10	0.32	0.87	0.91	1.49	4.07	4.25	93	5.31	A	A++	4.62	5.00	1515	0.90
	1.5+2.5+2.5	1.06	1.77	1.77	1.30	4.60	5.10	0.32	0.88	0.87	1.49	4.12	4.07	93	5.27	A	A++	4.62	5.00	1513	0.90
	2.0+2.0+2.0	1.53	1.53	1.53	1.30	4.60	5.10	0.32	0.87	0.89	1.49	4.07	4.16	93	5.3	A	A++	4.60	5.00	1521	0.90
	2.0+2.0+2.5	1.42	1.42	1.77	1.30	4.60	5.10	0.32	0.87	0.86	1.49	4.07	4.02	93	5.32	A	A++	4.62	5.00	1515	0.90
	2.0+2.5+2.5	1.31	1.64	1.64	1.30	4.60	5.10	0.32	0.86	0.84	1.49	4.03	3.93	93	5.35	A	A++	4.63	5.00	1512	0.90

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
3MXM52N2V1B8	1.5	1.50	---	---	1.40	1.50	2.40	0.34	0.36	0.63	1.50	1.62	2.86	96	---	---	---	---	---	---	
	2.0	2.00	---	---	1.60	2.00	3.00	0.36	0.48	0.78	1.60	2.17	3.51	96	---	---	---	---	---	---	
	2.5	2.50	---	---	1.60	2.50	3.20	0.36	0.64	0.87	1.62	2.89	3.92	96	---	---	---	---	---	---	
	3.5	3.50	---	---	1.60	3.50	4.20	0.37	0.98	1.30	1.63	4.43	5.88	96	---	---	---	---	---	---	
	4.2	4.20	---	---	1.60	4.20	4.60	0.37	1.21	1.49	1.63	5.47	6.70	96	---	---	---	---	---	---	
	5.0	---	5.00	---	1.60	5.00	5.40	0.35	1.76	2.03	1.55	7.94	9.18	96	---	---	---	---	---	---	
	1.5+1.5	1.50	1.50	---	1.70	3.00	4.70	0.35	0.55	1.32	1.55	2.50	5.98	96	5.48	A	274	A+++	8.64	3.00	122
	1.5+2.0	1.50	2.00	---	1.70	3.50	4.70	0.35	0.66	1.30	1.55	2.99	5.88	96	5.31	A	330	A+++	8.60	3.50	143
	1.5+2.5	1.50	2.50	---	1.70	4.00	5.00	0.35	0.78	1.92	1.55	3.54	8.66	96	5.16	A	388	A+++	8.54	4.00	164
	1.5+3.5	1.50	3.50	---	1.70	5.00	6.00	0.35	1.06	2.17	1.55	4.81	9.80	96	4.75	A	527	A+++	8.51	5.00	206
	1.5+4.2	1.37	3.83	---	1.70	5.20	6.10	0.35	1.10	2.26	1.55	4.99	10.21	96	4.74	A	549	A+++	8.51	5.20	214
	1.5+5.0	1.20	4.00	---	1.70	5.20	6.30	0.35	1.10	2.28	1.55	4.99	10.31	96	4.77	A	546	A+++	8.50	5.20	215
	2.0+2.0	2.00	2.00	---	1.70	4.00	6.00	0.35	0.85	2.25	1.55	3.85	10.16	96	4.72	A	424	A+++	8.52	4.00	165
	2.0+2.5	2.00	2.50	---	1.70	4.50	6.20	0.35	0.95	2.21	1.55	4.31	9.99	96	4.74	A	475	A+++	8.50	4.50	186
	2.0+3.5	1.89	3.31	---	1.70	5.20	6.30	0.35	1.10	2.30	1.55	4.99	10.38	96	4.76	A	547	A+++	8.53	5.20	214
	2.0+4.2	1.68	3.52	---	1.70	5.20	6.30	0.35	1.09	2.25	1.55	4.94	10.18	96	4.78	A	544	A+++	8.52	5.20	214
	2.0+5.0	1.49	3.71	---	1.70	5.20	6.50	0.35	1.09	2.19	1.55	4.94	9.89	96	4.80	A	542	A+++	8.51	5.20	214
	2.5+2.5	2.50	2.50	---	1.70	5.00	6.30	0.35	1.04	2.34	1.55	4.72	10.59	96	4.85	A	516	A+++	8.59	5.00	204
	2.5+3.5	2.17	3.03	---	1.70	5.20	6.30	0.35	1.09	2.28	1.55	4.94	10.31	96	4.78	A	544	A+++	8.58	5.20	213
	2.5+4.2	1.94	3.26	---	1.70	5.20	6.40	0.35	1.09	2.30	1.55	4.94	10.41	96	4.80	A	542	A+++	8.56	5.20	213
	2.5+5.0	1.73	3.47	---	1.70	5.20	6.50	0.35	1.06	2.14	1.55	4.81	9.68	96	4.92	A	529	A+++	8.53	5.20	214
	3.5+3.5	2.60	2.60	---	1.70	5.20	6.40	0.35	1.08	2.28	1.55	4.90	10.31	96	4.82	A	540	A+++	8.57	5.20	213
	3.5+4.2	2.36	2.84	---	1.70	5.20	6.40	0.35	1.08	2.26	1.55	4.90	10.21	96	4.83	A	539	A+++	8.55	5.20	213
	3.5+5.0	2.14	3.06	---	1.70	5.20	6.60	0.35	1.06	2.19	1.55	4.81	9.89	96	4.94	A	527	A+++	8.50	5.20	215
	4.2+4.2	2.60	2.60	---	1.70	5.20	6.50	0.35	1.07	2.24	1.55	4.85	10.11	96	4.88	A	533	A+++	8.54	5.20	213
	1.5+1.5+1.5	1.50	1.50	1.50	1.80	4.50	6.70	0.37	0.90	2.28	1.65	4.08	10.30	96	5.00	A	450	A+++	8.58	4.50	184
	1.5+1.5+2.0	1.50	1.50	2.00	1.80	5.00	6.70	0.37	1.06	2.26	1.65	4.81	10.20	96	4.76	A	526	A+++	8.51	5.20	214
	1.5+1.5+2.5	1.42	1.42	2.36	1.80	5.20	6.70	0.37	1.09	2.23	1.65	4.94	10.10	96	4.78	A	544	A+++	8.50	5.20	215
	1.5+1.5+3.5	1.20	1.20	2.80	1.90	5.20	6.80	0.37	1.09	2.28	1.65	4.94	10.30	96	4.81	A	541	A+++	8.50	5.20	215
	1.5+1.5+4.2	1.08	1.08	3.03	1.90	5.20	6.80	0.37	1.08	2.26	1.65	4.90	10.20	96	4.83	A	539	A+++	8.50	5.20	215
	1.5+1.5+5.0	0.98	0.98	3.25	2.00	5.20	7.10	0.35	1.05	2.17	1.55	4.76	9.80	96	4.98	A	523	A++	8.24	5.20	221
	1.5+2.0+2.0	1.42	1.89	1.89	1.80	5.20	6.70	0.37	1.10	2.21	1.65	4.99	10.00	96	4.77	A	546	A+++	8.50	5.20	215
	1.5+2.0+2.5	1.30	1.73	2.17	1.80	5.20	6.70	0.37	1.09	2.19	1.65	4.94	9.90	96	4.79	A	543	A+++	8.50	5.20	215
	1.5+2.0+3.5	1.11	1.49	2.60	1.90	5.20	6.80	0.37	1.08	2.23	1.65	4.90	10.10	96	4.82	A	540	A+++	8.50	5.20	215
	1.5+2.0+4.2	1.01	1.35	2.84	1.90	5.20	6.80	0.37	1.08	2.19	1.65	4.90	9.90	96	4.84	A	538	A+++	8.50	5.20	215
	1.5+2.0+5.0	0.92	1.22	3.06	2.00	5.20	7.20	0.35	1.04	2.15	1.55	4.72	9.70	96	5.01	A	519	A++	8.24	5.20	221
	1.5+2.5+2.5	1.20	2.00	2.00	1.80	5.20	6.70	0.37	1.09	2.17	1.65	4.94	9.80	96	4.81	A	541	A+++	8.52	5.20	214
	1.5+2.5+3.5	1.04	1.73	2.43	1.90	5.20	6.80	0.37	1.08	2.21	1.65	4.90	10.00	96	4.85	A	537	A+++	8.51	5.20	214
	1.5+2.5+4.2	0.95	1.59	2.66	1.90	5.20	6.80	0.37	1.07	2.19	1.65	4.85	9.90	96	4.87	A	534	A+++	8.50	5.20	214
	1.5+2.5+5.0	0.87	1.44	2.89	2.00	5.20	7.30	0.35	1.04	2.17	1.55	4.72	9.80	96	5.03	A	517	A++	8.17	5.20	223
	1.5+3.5+3.5	0.92	2.14	2.14	1.80	5.20	7.30	0.37	1.07	2.15	1.65	4.85	9.70	96	4.89	A	532	A+++	8.50	5.20	215
	2.0+2.0+2.0	1.73	1.73	1.73	1.80	5.20	7.00	0.37	1.07	2.22	1.65	4.85	10.05	96	4.87	A	534	A+++	8.51	5.20	214
	2.0+2.0+2.5	1.60	1.60	2.00	1.80	5.20	7.00	0.37	1.06	2.21	1.65	4.81	10.00	96	4.94	A	527	A+++	8.51	5.20	214
	2.0+2.0+3.5	1.39	1.39	2.43	1.90	5.20	7.20	0.39	1.05	2.17	1.75	4.76	9.80	96	4.96	A	525	A+++	8.50	5.20	214
	2.0+2.0+4.2	1.27	1.27	2.66	1.90	5.20	7.20	0.39	1.04	2.15	1.75	4.72	9.70	96	5.00	A	520	A+++	8.50	5.20	214
	2.0+2.0+5.0	1.16	1.16	2.89	2.00	5.20	7.30	0.37	1.03	2.19	1.65	4.67	9.91	96	5.05	A	515	A++	8.14	5.20	224
	2.0+2.5+2.5	1.49	1.86	1.86	1.80	5.20	7.10	0.39	1.05	2.12	1.75	4.76	9.60	96	4.98	A	523	A+++	8.51	5.20	214
	2.0+2.5+3.5	1.30	1.63	2.28	1.90	5.20	7.20	0.39	1.04	2.15	1.75	4.72	9.70	96	5.01	A	519	A+++	8.50	5.20	215
	2.0+2.5+4.2	1.20	1.49	2.51	1.90	5.20	7.20	0.39	1.04	2.14	1.75	4.72	9.65	96	5.03	A	517	A+++	8.50	5.20	214
	2.0+3.5+3.5	1.16	2.02	2.02	1.90	5.20	7.30	0.39	1.04	2.15	1.75	4.72	9.70	96	5.02	A	518	A+++	8.50	5.20	215
2.5+2.5+2.5	1.73	1.73	1.73	1.90	5.20	7.10	0.39	1.04	2.19	1.75	4.72	9.90	96	5.00	A	520	A+++	8.50	5.20	215	
2.5+2.5+3.5	1.53	1.53	2.14	1.90	5.20	7.20	0.39	1.04	2.16	1.75	4.72	9.75	96	5.02	A	518	A+++	8.50	5.20	215	

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
3MXM52N2V1B8	1.5	2.3	---	---	1.10	2.30	3.40	0.30	0.57	1.09	1.34	2.55	4.94	96	---	---	---	---	---	---	---
	2.0	2.7	---	---	1.10	2.70	3.80	0.30	0.76	1.27	1.34	3.40	5.75	96	---	---	---	---	---	---	---
	2.5	3.4	---	---	1.10	3.40	4.20	0.30	1.01	1.36	1.34	4.54	6.16	96	---	---	---	---	---	---	---
	3.5	4.2	---	---	1.10	4.20	4.80	0.30	1.42	1.74	1.34	6.39	7.88	96	---	---	---	---	---	---	---
	4.2	4.8	---	---	1.10	4.80	5.60	0.30	1.62	2.03	1.34	7.32	9.18	96	---	---	---	---	---	---	---
	5.0	---	5.8	---	1.10	5.80	6.80	0.30	2.17	2.58	1.34	9.80	11.68	96	---	---	---	---	---	---	---
	1.5+1.5	1.8	1.8	---	1.20	3.60	5.80	0.32	0.67	1.62	1.44	3.04	7.34	96	5.42	A	A++	4.60	3.60	1095	0.5
	1.5+2.0	1.7	2.3	---	1.20	4.00	5.80	0.32	0.77	1.60	1.44	3.49	7.25	96	5.21	A	A++	4.65	3.60	1084	0.5
	1.5+2.5	1.7	2.8	---	1.20	4.50	6.90	0.32	0.91	2.06	1.44	4.13	9.33	96	4.96	A	A+	4.44	4.20	1325	0.7
	1.5+3.5	1.7	3.9	---	1.20	5.50	7.00	0.32	1.22	2.25	1.44	5.53	10.19	96	4.53	A	A+	4.30	4.80	1562	0.8
	1.5+4.2	1.6	4.4	---	1.20	6.00	7.00	0.32	1.42	2.23	1.44	6.44	10.10	96	4.24	A	A+	4.34	4.80	1546	0.8
	1.5+5.0	1.6	5.2	---	1.30	6.80	7.20	0.32	1.58	2.30	1.44	7.16	10.42	96	4.33	A	A+	4.47	4.80	1501	0.7
	2.0+2.0	3.4	3.4	---	1.20	6.80	7.00	0.32	1.59	2.06	1.44	7.21	10.24	96	4.28	A	A+	4.27	4.80	1573	0.9
	2.0+2.5	3.0	3.8	---	1.20	6.80	7.00	0.32	1.58	2.25	1.44	7.16	10.19	96	4.32	A	A+	4.30	4.80	1563	0.9
	2.0+3.5	2.5	4.3	---	1.20	6.80	7.10	0.32	1.57	2.26	1.44	7.12	10.24	96	4.34	A	A+	4.33	4.80	1552	0.8
	2.0+4.2	2.2	4.6	---	1.20	6.80	7.10	0.32	1.56	2.24	1.44	7.07	10.14	96	4.36	A	A+	4.36	4.80	1541	0.8
	2.0+5.0	1.9	4.9	---	1.40	6.80	7.20	0.32	1.53	2.28	1.44	6.93	10.32	96	4.46	A	A+	4.50	4.80	1492	0.7
	2.5+2.5	3.4	3.4	---	1.20	6.80	7.00	0.32	1.53	2.23	1.44	6.93	10.10	96	4.45	A	A+	4.38	4.80	1533	0.9
	2.5+3.5	2.8	4.0	---	1.30	6.80	7.20	0.32	1.53	2.35	1.44	6.93	10.64	96	4.46	A	A+	4.41	4.80	1523	0.8
	2.5+4.2	2.5	4.3	---	1.30	6.80	7.20	0.32	1.52	2.33	1.44	6.89	10.55	96	4.48	A	A+	4.45	4.80	1508	0.8
	2.5+5.0	2.3	4.5	---	1.40	6.80	7.40	0.32	1.50	2.33	1.44	6.80	10.52	96	4.54	A	A+	4.53	4.80	1482	0.7
	3.5+3.5	3.4	3.4	---	1.40	6.80	7.30	0.32	1.52	2.38	1.44	6.89	10.78	96	4.50	A	A+	4.40	5.00	1590	0.9
	3.5+4.2	3.1	3.7	---	1.40	6.80	7.30	0.32	1.51	2.36	1.44	6.84	10.69	96	4.52	A	A+	4.43	5.00	1579	0.9
	3.5+5.0	2.8	4.0	---	1.45	6.80	7.50	0.32	1.50	2.30	1.44	6.80	10.42	96	4.56	A	A+	4.52	5.00	1548	0.8
	4.2+4.2	3.4	3.4	---	1.40	6.80	7.30	0.32	1.50	2.35	1.44	6.80	10.62	96	4.55	A	A+	4.46	5.00	1569	0.9
	1.5+1.5+1.5	2.3	2.3	2.3	1.30	6.80	8.00	0.32	1.40	2.12	1.44	6.35	9.60	96	4.87	A	A++	4.60	5.00	1522	0.9
	1.5+1.5+2.0	2.0	2.0	2.7	1.30	6.80	8.00	0.32	1.40	2.10	1.44	6.35	9.51	96	4.88	A	A++	4.61	5.00	1517	0.9
	1.5+1.5+2.5	1.9	1.9	3.1	1.30	6.80	8.00	0.32	1.39	2.08	1.44	6.30	9.42	96	4.91	A	A++	4.63	5.00	1512	0.9
	1.5+1.5+3.5	1.6	1.6	3.7	1.40	6.80	8.10	0.32	1.38	2.13	1.44	6.25	9.65	96	4.94	A	A++	4.65	5.00	1506	0.9
	1.5+1.5+4.2	1.4	1.4	4.0	1.40	6.80	8.10	0.32	1.38	2.11	1.44	6.25	9.56	96	4.96	A	A++	4.66	5.00	1500	0.9
	1.5+1.5+5.0	1.3	1.3	4.3	1.60	6.80	8.30	0.32	1.32	2.09	1.44	5.98	9.47	96	5.18	A	A++	4.83	5.00	1448	0.8
	1.5+2.0+2.0	1.9	2.5	2.5	1.30	6.80	8.00	0.32	1.39	2.14	1.44	6.30	9.69	96	4.90	A	A++	4.62	5.00	1515	0.9
	1.5+2.0+2.5	1.7	2.3	2.8	1.30	6.80	8.00	0.32	1.38	2.12	1.44	6.25	9.60	96	4.93	A	A++	4.64	5.00	1509	0.9
	1.5+2.0+3.5	1.5	1.9	3.4	1.40	6.80	8.10	0.32	1.37	2.16	1.44	6.21	9.78	96	4.97	A	A++	4.65	5.00	1503	0.9
	1.5+2.0+4.2	1.3	1.8	3.7	1.40	6.80	8.10	0.32	1.36	2.14	1.44	6.16	9.69	96	5.00	A	A++	4.67	5.00	1498	0.9
	1.5+2.0+5.0	1.2	1.6	4.0	1.60	6.80	8.30	0.32	1.31	2.07	1.44	5.94	9.38	96	5.22	A	A++	4.85	5.00	1443	0.8
	1.5+2.5+2.5	1.6	2.6	2.6	1.30	6.80	8.00	0.32	1.38	2.12	1.44	6.25	9.60	96	4.95	A	A++	4.64	5.00	1507	0.9
	1.5+2.5+3.5	1.4	2.3	3.2	1.40	6.80	8.10	0.32	1.37	2.13	1.44	6.21	9.65	96	4.99	A	A++	4.66	5.00	1501	0.9
	1.5+2.5+4.2	1.2	2.1	3.5	1.40	6.80	8.10	0.32	1.36	2.11	1.44	6.16	9.56	96	5.01	A	A++	4.68	5.00	1495	0.9
	1.5+2.5+5.0	1.1	1.9	3.8	1.60	6.80	8.30	0.32	1.30	2.09	1.44	5.89	9.47	96	5.26	A	A++	4.86	5.00	1438	0.8
	1.5+3.5+3.5	1.2	2.8	2.8	1.30	6.80	8.20	0.32	1.36	2.14	1.44	6.16	9.69	96	5.02	A	A++	4.70	5.00	1489	0.9
	2.0+2.0+2.0	2.3	2.3	2.3	1.30	6.80	8.00	0.32	1.39	2.13	1.44	6.30	9.65	96	4.91	A	A++	4.61	5.00	1516	0.9
2.0+2.0+2.5	2.1	2.1	2.6	1.30	6.80	8.00	0.32	1.38	2.11	1.44	6.25	9.56	96	4.95	A	A++	4.63	5.00	1510	0.9	
2.0+2.0+3.5	1.8	1.8	3.2	1.40	6.80	8.10	0.32	1.37	2.12	1.44	6.21	9.60	96	4.98	A	A++	4.66	5.00	1501	0.9	
2.0+2.0+4.2	1.7	1.7	3.5	1.40	6.80	8.10	0.32	1.36	2.10	1.44	6.16	9.51	96	5.01	A	A++	4.68	5.00	1496	0.9	
2.0+2.0+5.0	1.5	1.5	3.8	1.60	6.80	8.30	0.32	1.29	2.08	1.44	5.85	9.42	96	5.30	A	A++	4.88	5.00	1434	0.8	
2.0+2.5+2.5	1.9	2.4	2.4	1.30	6.80	8.00	0.32	1.37	2.09	1.44	6.21	9.47	96	4.99	A	A++	4.64	5.00	1508	0.9	
2.0+2.5+3.5	1.7	2.1	3.0	1.50	6.80	8.10	0.32	1.36	2.11	1.44	6.16	9.56	96	5.03	A	A++	4.67	5.00	1499	0.9	
2.0+2.5+4.2	1.6	2.0	3.3	1.50	6.80	8.10	0.32	1.35	2.11	1.44	6.12	9.56	96	5.07	A	A++	4.68	5.00	1493	0.9	
2.0+3.5+3.5	1.5	2.6	2.6	1.50	6.80	8.20	0.32	1.35	2.15	1.44	6.12	9.74	96	5.05	A	A++	4.68	5.00	1496	0.9	
2.5+2.5+2.5	2.3	2.3	2.3	1.40	6.80	8.00	0.32	1.36	2.07	1.44	6.16	9.38	96	5.02	A	A++	4.65	5.00	1505	0.9	
2.5+2.5+3.5	2.0	2.0	2.8	1.50	6.80	8.10	0.32	1.35	2.09	1.44	6.12	9.47	96	5.05	A	A++	4.68	5.00	1496	0.9	

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
	1.5	1.60	---	---	1.52	1.60	2.49	0.40	0.42	0.59	1.82	1.98	2.71	95	---	---	---	---	---	---	
	2.0	2.00	---	---	1.66	2.00	2.68	0.42	0.43	0.60	1.91	2.08	2.75	95	---	---	---	---	---	---	
	2.5	2.50	---	---	1.74	2.50	3.44	0.44	0.44	0.82	2.00	2.62	3.77	95	---	---	---	---	---	---	
	3.5	3.50	---	---	1.93	3.50	4.86	0.46	0.46	1.43	2.09	3.84	6.53	95	---	---	---	---	---	---	
	4.2	---	---	4.20	1.93	4.20	5.33	0.46	0.46	1.44	2.09	3.93	6.57	95	---	---	---	---	---	---	
	5.0	---	---	5.00	1.94	5.00	6.03	0.44	0.44	2.13	2.00	7.20	9.77	95	---	---	---	---	---	---	
	6.0	---	---	6.00	1.94	6.00	6.51	0.44	0.44	2.13	2.00	7.29	9.77	95	---	---	---	---	---	---	
	1.5+1.5	1.50	1.50	---	1.95	3.00	4.79	0.40	0.51	1.15	1.81	2.34	5.25	95	5.96	A	255	A++	7.29	3.00	144
	1.5+2.0	1.50	2.00	---	1.95	3.50	4.96	0.40	0.62	1.22	1.81	2.84	5.58	95	5.66	A	310	A++	7.53	3.50	163
	1.5+2.5	1.50	2.50	---	1.95	4.00	5.28	0.40	0.75	1.36	1.81	3.44	6.23	95	5.36	A	375	A++	7.75	4.00	181
	1.5+3.5	1.50	3.50	---	1.95	5.00	6.17	0.39	1.04	1.83	1.77	4.76	8.39	95	4.81	A	520	A++	7.80	5.00	225
	1.5+4.2	1.50	4.20	---	1.95	5.70	6.39	0.39	1.27	1.96	1.77	5.82	8.96	95	4.51	A	635	A++	7.84	5.70	255
	1.5+5.0	1.50	5.00	---	1.95	6.50	7.08	0.38	1.50	2.23	1.73	6.87	10.22	95	4.36	A	750	A++	7.86	6.50	290
	1.5+6.0	1.36	5.44	---	1.96	6.80	7.59	0.37	1.62	2.36	1.68	7.42	10.79	95	4.21	A	810	A++	7.81	6.80	305
	2.0+2.0	2.00	2.00	---	1.95	4.00	5.12	0.40	0.75	1.29	1.81	3.44	5.91	95	5.36	A	375	A++	7.75	4.00	181
	2.0+2.5	2.00	2.50	---	1.95	4.50	5.44	0.40	0.89	1.43	1.81	4.08	6.56	95	5.06	A	445	A++	7.80	4.50	202
	2.0+3.5	2.00	3.50	---	1.95	5.50	6.30	0.39	1.17	1.91	1.77	5.36	8.76	95	4.71	A	585	A++	7.91	5.50	244
	2.0+4.2	2.00	4.20	---	1.95	6.20	6.51	0.39	1.43	2.05	1.77	6.55	9.37	95	4.36	A	715	A++	7.88	6.20	276
	2.0+5.0	1.94	4.86	---	1.95	6.80	7.26	0.38	1.59	2.36	1.73	7.28	10.79	95	4.28	A	795	A++	7.78	6.80	306
	2.0+6.0	1.70	5.10	---	1.96	6.80	7.71	0.37	1.61	2.45	1.68	7.37	11.20	95	4.23	A	805	A++	7.71	6.80	309
	2.5+2.5	2.50	2.50	---	1.95	5.00	6.10	0.41	1.01	1.78	1.89	4.63	8.15	95	4.96	A	505	A++	7.81	5.00	224
	2.5+3.5	2.50	3.50	---	1.95	6.00	6.57	0.40	1.29	2.11	1.81	5.91	9.65	95	4.66	A	645	A++	7.94	6.00	265
	2.5+4.2	2.50	4.20	---	1.95	6.70	6.95	0.40	1.51	2.38	1.81	6.92	10.88	95	4.46	A	755	A++	7.99	6.70	294
	2.5+5.0	2.27	4.53	---	1.95	6.80	7.37	0.37	1.50	2.45	1.68	6.87	11.20	95	4.56	A	750	A++	7.93	6.80	300
	2.5+6.0	2.00	4.80	---	1.96	6.80	7.71	0.35	1.48	2.45	1.60	6.78	11.20	95	4.61	A	740	A++	7.90	6.80	301
	3.5+3.5	3.40	3.40	---	1.95	6.80	7.13	0.38	1.45	2.37	1.73	6.64	10.83	95	4.70	A	725	A++	8.02	6.80	297
	3.5+4.2	3.09	3.71	---	1.95	6.80	7.24	0.38	1.45	2.46	1.73	6.64	11.24	95	4.72	A	725	A++	8.00	6.80	298
	3.5+5.0	2.80	4.00	---	1.95	6.80	7.76	0.35	1.42	2.78	1.60	6.50	12.71	95	4.82	A	710	A++	7.92	6.80	301
	3.5+6.0	2.51	4.29	---	2.26	6.80	8.07	0.40	1.40	2.72	1.81	6.41	12.46	95	4.87	A	700	A++	7.89	6.80	302
	4.2+4.2	---	3.40	3.40	1.95	6.80	7.14	0.38	1.44	2.37	1.73	6.60	10.83	95	4.74	A	720	A++	7.98	6.80	298
	4.2+5.0	---	3.10	3.70	1.95	6.80	7.77	0.35	1.41	2.78	1.60	6.46	12.71	95	4.84	A	705	A++	7.90	6.80	302
	4.2+6.0	---	2.80	4.00	2.26	6.80	8.08	0.40	1.40	2.72	1.81	6.41	12.46	95	4.89	A	700	A++	7.87	6.80	303
	5.0+5.0	---	3.40	3.40	2.34	6.80	8.22	0.43	1.38	2.98	1.98	6.32	13.65	95	4.94	A	690	A++	7.88	6.80	302
	5.0+6.0	---	3.09	3.71	2.47	6.80	8.45	0.44	1.37	2.92	2.02	6.28	13.36	95	4.99	A	685	A++	7.85	6.80	304
	1.5+1.5+1.5	1.50	1.50	1.50	1.96	4.50	6.40	0.39	0.61	1.57	1.77	2.80	7.17	95	7.46	A	305	A+++	8.54	4.50	185
	1.5+1.5+2.0	1.44	1.44	1.92	1.96	4.80	6.56	0.39	0.70	1.65	1.77	3.21	7.54	95	6.86	A	350	A+++	8.52	4.80	198
	1.5+1.5+2.5	1.36	1.36	2.27	1.96	5.00	6.72	0.39	0.80	1.73	1.77	3.67	7.90	95	6.26	A	400	A+++	8.50	5.00	206
	1.5+1.5+3.5	1.50	1.50	3.50	1.96	6.50	7.11	0.38	1.56	1.92	1.73	7.14	8.80	95	4.19	A	780	A++	7.85	6.50	290
	1.5+1.5+4.2	1.42	1.42	3.97	1.96	6.80	7.33	0.38	1.80	2.05	1.73	8.24	9.37	95	3.79	A	900	A++	7.71	6.80	309
	1.5+1.5+5.0	1.28	1.28	4.25	1.96	6.80	7.74	0.36	1.75	2.22	1.64	8.01	10.14	95	3.89	A	875	A++	7.64	6.80	312
	1.5+1.5+6.0	1.13	1.13	4.53	2.31	6.80	7.99	0.40	1.73	2.17	1.85	7.92	9.94	95	3.94	A	865	A++	7.62	6.80	313
3MXM68N2V19	1.5+2.0+2.0	1.50	2.00	2.00	1.96	5.50	6.48	0.39	1.01	1.61	1.77	4.63	7.37	95	5.46	A	505	A++	8.17	5.50	236
	1.5+2.0+2.5	1.50	2.00	2.50	1.96	6.00	6.87	0.39	1.32	1.81	1.77	6.05	8.27	95	4.56	A	660	A++	7.90	6.00	266
	1.5+2.0+3.5	1.46	1.94	3.40	1.96	6.80	7.25	0.38	1.80	2.01	1.73	8.24	9.21	95	3.79	A	900	A++	7.71	6.80	309
	1.5+2.0+4.2	1.32	1.77	3.71	1.96	6.80	7.47	0.38	1.79	2.14	1.73	8.20	9.78	95	3.81	A	895	A++	7.69	6.80	310
	1.5+2.0+5.0	1.20	1.60	4.00	1.96	6.80	7.87	0.36	1.74	2.31	1.64	7.97	10.55	95	3.91	A	870	A++	7.63	6.80	312
	1.5+2.0+6.0	1.07	1.43	4.29	2.31	6.80	8.13	0.40	1.72	2.26	1.85	7.88	10.35	95	3.96	A	860	A++	7.60	6.80	313
	1.5+2.5+2.5	1.50	2.50	2.50	1.96	6.50	7.10	0.38	1.63	1.92	1.73	7.46	8.80	95	4.01	A	815	A++	7.76	6.50	294
	1.5+2.5+3.5	1.36	2.27	3.17	1.96	6.80	7.60	0.36	1.79	2.23	1.64	8.20	10.18	95	3.81	A	895	A++	7.69	6.80	310
	1.5+2.5+4.2	1.24	2.07	3.48	1.96	6.80	7.81	0.36	1.78	2.35	1.64	8.15	10.75	95	3.83	A	890	A++	7.67	6.80	310
	1.5+2.5+5.0	1.13	1.89	3.78	1.96	6.80	7.95	0.36	1.74	2.35	1.64	7.97	10.75	95	3.93	A	870	A++	7.61	6.80	313
	1.5+2.5+6.0	1.02	1.70	4.08	2.31	6.80	8.42	0.41	1.71	2.44	1.89	7.83	11.16	95	3.98	A	855	A++	7.59	6.80	314
	1.5+3.5+3.5	1.20	2.80	2.80	1.96	6.80	7.94	0.37	1.77	2.45	1.68	8.11	11.20	95	3.85	A	885	A++	7.67	6.80	311
	1.5+3.5+4.2	1.11	2.59	3.10	1.96	6.80	8.13	0.37	1.76	2.58	1.68	8.06	11.81	95	3.87	A	880	A++	7.65	6.80	311
	1.5+3.5+5.0	1.02	2.38	3.40	1.96	6.80	8.46	0.33	1.72	2.72	1.52	7.88	12.46	95	3.97	A	860	A++	7.58	6.80	314
	1.5+3.5+6.0	0.93	2.16	3.71	2.31	6.80	8.56	0.41	1.70	2.53	1.89	7.79	11.57	95	4.02	A	850	A++	7.56	6.80	315
	1.5+4.2+4.2	1.03	2.88	2.88	1.96	6.80	8.26	0.37	1.75	2.68	1.68	8.01	12.26	95	3.89	A	875	A++	7.63	6.80	312
	1.5+4.2+5.0	0.95	2.67	3.18	1.96	6.80	8.53	0.33	1.71	2.77	1.52	7.83	12.67	95	3.99	A	855	A++	7.56	6.80	315
	2.0+2.0+2.0	2.00	2.00	2.00	1.96	6.00	6.64	0.39	1.34	1.68	1.77	6.14	7.70	95	4.51	A	670	A++	7.84	6.00	268
	2.0+2.0+2.5	2.00	2.00	2.50	1.96	6.50	7.03	0.39	1.63	1.89	1.77	7.46	8.64	95	4.01	A	815	A++	7.76	6.50	294
	2.0+2.0+3.5	1.81	1.81	3.17	1.96	6.80	7.40	0.38	1.79	2.09	1.73	8.20	9.57	95	3.81	A	895	A++	7.69	6.80	310
	2.0+2.0+4.2	1.66	1.66	3.48	1.96	6.80	7.61	0.38	1.78	2.23	1.73	8.15	10.18	95	3.83	A	890	A++	7.67	6.80	310
	2.0+2.0+5.0	1.51	1.51	3.78	1.96	6.80	8.01	0.36	1.74	2.39	1.64	7.97	10.96	95	3.93	A	870	A++	7.61	6.80	313
	2.0+2.0+6.0	1.36	1.36	4.08	2.31	6.80	8.27	0.40	1.71	2.35	1.85	7.83	10.75	95	3.98	A	855	A++	7.59	6	

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				Back-up heater capacity at -10°C
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	
	30	2.70	---	---	1.47	2.70	4.08	0.42	0.72	1.22	1.91	3.35	5.59	95	---	---	---	---	---	---	---
	40	2.72	---	---	1.48	2.72	4.09	0.43	0.73	1.28	1.95	3.39	5.64	95	---	---	---	---	---	---	---
	50	3.40	---	---	1.44	3.40	4.30	0.42	1.02	1.37	1.91	4.72	6.08	95	---	---	---	---	---	---	---
	70	4.30	---	---	1.45	4.30	4.90	0.40	1.41	1.75	1.82	6.50	7.15	95	---	---	---	---	---	---	---
	84	---	4.32	---	1.44	4.32	5.70	0.40	1.40	2.04	1.82	6.46	7.15	95	---	---	---	---	---	---	---
	100	---	5.60	---	1.66	5.60	6.90	0.39	1.82	2.59	1.78	8.43	8.70	95	---	---	---	---	---	---	---
	120	---	7.90	---	1.88	7.90	8.91	0.37	2.62	2.64	1.69	12.13	12.08	95	---	---	---	---	---	---	---
	1.5+1.5	2.65	2.65	---	1.65	5.30	7.38	0.36	1.19	1.83	1.63	5.45	8.38	95	4.45	A	A	3.85	3.80	1380	0.73
	1.5+2.0	2.44	3.26	---	1.65	5.70	7.76	0.36	1.31	1.99	1.63	6.00	9.09	95	4.35	A	A	3.85	3.80	1380	0.72
	1.5+2.5	2.29	3.81	---	1.65	6.10	7.95	0.36	1.43	2.06	1.63	6.55	9.43	95	4.27	A	A	3.87	3.80	1373	0.71
	1.5+3.5	2.07	4.83	---	1.80	6.90	8.50	0.37	1.69	2.35	1.68	7.74	10.74	95	4.10	A	A	3.86	4.30	1558	0.92
	1.5+4.2	1.97	5.53	---	1.80	7.50	8.85	0.37	1.90	2.57	1.68	8.70	11.75	95	3.97	A	A	3.88	4.30	1548	0.91
	1.5+5.0	1.89	6.31	---	2.18	8.20	10.38	0.45	2.13	2.91	2.06	9.75	13.31	95	3.86	A	A	3.87	4.50	1628	0.96
	1.5+6.0	1.72	6.88	---	2.46	8.60	10.58	0.48	2.28	2.67	2.19	10.44	12.21	95	3.78	A	A	3.91	4.80	1717	1.07
	2.0+2.0	3.25	3.25	---	1.65	6.50	7.95	0.36	1.37	2.31	1.63	6.28	9.47	95	4.75	A	A	3.91	3.80	1361	0.71
	2.0+2.5	3.07	3.83	---	1.65	6.90	8.12	0.36	1.52	2.32	1.63	6.96	9.81	95	4.56	A	A	3.92	3.80	1354	0.71
	2.0+3.5	2.73	4.77	---	1.80	7.50	8.67	0.37	1.75	2.43	1.68	8.01	11.12	95	4.30	A	A	3.86	4.30	1558	0.91
	2.0+4.2	2.58	5.42	---	1.80	8.00	9.03	0.37	1.98	2.66	1.68	9.07	12.17	95	4.06	A	A	3.88	4.30	1550	0.90
	2.0+5.0	2.46	6.14	---	2.18	8.60	10.56	0.45	2.26	3.00	2.06	10.35	13.73	95	3.82	A	A	3.90	4.50	1612	0.96
	2.0+6.0	2.15	6.45	---	2.46	8.60	10.75	0.48	2.24	2.74	2.19	10.26	12.55	95	3.84	A	A	3.93	4.80	1710	1.07
	2.5+2.5	3.60	3.60	---	1.65	7.20	8.49	0.36	1.62	2.36	1.63	7.42	10.78	95	4.46	A	A	3.85	4.00	1455	0.79
	2.5+3.5	3.29	4.61	---	1.89	7.90	9.03	0.38	1.91	2.66	1.72	8.75	12.17	95	4.14	A	A	3.83	4.30	1569	0.90
	2.5+4.2	3.10	5.20	---	1.89	8.30	9.29	0.38	2.11	2.82	1.72	9.66	12.93	95	3.95	A	A	3.86	4.30	1559	0.90
	2.5+5.0	2.87	5.73	---	2.27	8.60	10.68	0.46	2.24	3.09	2.11	10.26	14.15	95	3.86	A	A	3.84	4.50	1637	0.91
	2.5+6.0	2.53	6.07	---	2.55	8.60	10.88	0.50	2.22	2.77	2.28	10.17	12.67	95	3.88	A	A	3.91	4.80	1716	1.00
	3.5+3.5	4.30	4.30	---	2.17	8.60	9.38	0.42	2.26	2.86	1.94	10.35	13.09	95	3.81	A	A+	4.00	4.80	1680	1.07
	3.5+4.2	3.91	4.69	---	2.17	8.60	9.47	0.42	2.26	2.91	1.94	10.35	13.31	95	3.82	A	A+	4.01	4.80	1675	1.06
	3.5+5.0	3.54	5.06	---	2.56	8.60	10.90	0.51	2.22	3.13	2.32	10.17	14.32	95	3.88	A	A+	4.01	4.80	1675	1.03
	3.5+6.0	3.17	5.43	---	2.74	8.60	11.01	0.52	2.21	2.76	2.37	10.12	12.63	95	3.91	A	A+	4.06	4.80	1652	1.01
	4.2+4.2	---	4.30	4.30	2.17	8.60	9.56	0.42	2.22	2.94	1.94	10.17	13.47	95	3.88	A	A+	4.00	4.80	1679	1.04
	4.2+5.0	---	3.93	4.67	2.56	8.60	10.91	0.51	2.21	3.19	2.32	10.12	14.61	95	3.90	A	A	3.93	5.20	1851	1.20
	4.2+6.0	---	3.54	5.06	2.74	8.60	11.02	0.51	2.20	2.79	2.32	10.07	12.76	95	3.92	A	A+	4.03	5.20	1804	1.18
	5.0+5.0	---	4.30	4.30	2.94	8.60	11.10	0.59	2.17	3.11	2.71	9.94	14.23	95	3.98	A	A+	4.06	5.20	1793	1.15
	5.0+6.0	---	3.91	4.69	3.14	8.60	11.10	0.60	2.15	2.72	2.75	9.84	12.46	95	4.01	A	A+	4.09	5.20	1779	1.13
	1.5+1.5+1.5	2.17	2.17	2.17	2.01	6.50	9.92	0.41	1.33	2.26	1.89	6.09	10.36	95	4.91	A	A+	4.07	5.30	1822	1.11
	1.5+1.5+2.0	2.07	2.07	2.76	2.01	6.90	10.10	0.41	1.46	2.34	1.89	6.69	10.69	95	4.74	A	A+	4.08	5.30	1817	1.10
	1.5+1.5+2.5	2.02	2.02	3.36	2.10	7.40	10.18	0.42	1.64	2.37	1.94	7.51	10.86	95	4.53	A	A+	4.09	5.30	1810	1.09
	1.5+1.5+3.5	1.89	1.89	4.42	2.31	8.20	10.29	0.44	1.87	2.49	2.02	8.56	11.41	95	4.39	A	A+	4.14	5.30	1793	1.07
	1.5+1.5+4.2	1.79	1.79	5.02	2.31	8.60	10.29	0.44	2.03	2.49	2.02	9.30	11.41	95	4.25	A	A+	4.15	5.30	1786	1.07
	1.5+1.5+5.0	1.61	1.61	5.38	2.71	8.60	10.46	0.55	2.01	2.57	2.50	9.20	11.75	95	4.29	A	A+	4.23	5.30	1752	1.03
	1.5+1.5+6.0	1.43	1.43	5.73	2.93	8.60	10.59	0.55	1.99	2.31	2.50	9.11	10.57	95	4.33	A	A+	4.27	5.30	1735	1.01
3MXM68N2V1B9	1.5+2.0+2.0	2.35	3.13	3.13	2.01	8.60	10.26	0.41	2.05	2.41	1.89	9.39	11.03	95	4.21	A	A+	4.09	5.30	1814	1.10
	1.5+2.0+2.5	2.15	2.87	3.58	2.10	8.60	10.36	0.42	2.04	2.44	1.94	9.34	11.16	95	4.23	A	A+	4.10	5.30	1807	1.09
	1.5+2.0+3.5	1.84	2.46	4.30	2.31	8.60	10.45	0.44	2.02	2.58	2.02	9.25	11.79	95	4.26	A	A+	4.14	5.30	1793	1.07
	1.5+2.0+4.2	1.68	2.23	4.69	2.31	8.60	10.46	0.44	2.01	2.57	2.02	9.20	11.75	95	4.28	A	A+	4.15	5.30	1786	1.07
	1.5+2.0+5.0	1.52	2.02	5.06	2.71	8.60	10.88	0.55	2.00	2.64	2.50	9.16	12.08	95	4.32	A	A+	4.23	5.30	1752	1.03
	1.5+2.0+6.0	1.36	1.81	5.43	2.93	8.60	10.89	0.55	1.98	2.38	2.50	9.07	10.91	95	4.36	A	A+	4.27	5.30	1735	1.01
	1.5+2.5+2.5	1.98	3.31	3.31	2.20	8.60	10.47	0.45	2.03	2.44	2.06	9.30	11.16	95	4.25	A	A+	4.12	5.30	1800	1.08
	1.5+2.5+3.5	1.72	2.87	4.01	2.40	8.60	10.58	0.47	2.02	2.57	2.15	9.25	11.75	95	4.27	A	A+	4.16	5.30	1782	1.06
	1.5+2.5+4.2	1.57	2.62	4.40	2.41	8.60	10.58	0.47	2.00	2.57	2.15	9.16	11.75	95	4.30	A	A+	4.19	5.30	1768	1.05
	1.5+2.5+5.0	1.43	2.39	4.78	2.81	8.60	11.00	0.56	1.99	2.64	2.58	9.11	12.08	95	4.34	A	A+	4.27	5.30	1735	1.01
	1.5+2.5+6.0	1.29	2.15	5.16	3.02	8.60	11.00	0.57	1.97	2.38	2.62	9.02	10.91	95	4.38	A	A+	4.31	5.30	1719	0.99
	1.5+3.5+3.5	1.52	3.54	3.54	2.69	8.60	10.59	0.55	1.99	2.57	2.50	9.11	11.75	95	4.33	A	A+	4.20	5.30	1765	1.04
	1.5+3.5+4.2	1.40	3.27	3.93	2.69	8.60	10.59	0.55	1.98	2.56	2.50	9.07	11.71	95	4.35	A	A+	4.22	5.30	1755	1.03
	1.5+3.5+5.0	1.29	3.01	4.30	3.00	8.60	10.93	0.62	1.97	2.59	2.84	9.02	11.87	95	4.38	A	A+	4.30	5.30	1722	0.99
	1.5+3.5+6.0	1.17	2.74	4.69	2.93	8.60	10.93	0.55	1.96	2.37	2.50	8.98	10.86	95	4.40	A	A+	4.34	5.30	1707	0.98
	1.5+4.2+4.2	1.30	3.65	3.65	2.69	8.60	10.68	0.55	1.98	2.59	2.50	9.07	11.87	95	4.35	A	A+	4.24	5.30	1748	1.02
	1.5+4.2+5.0	1.21	3.38	4.02	3.00	8.60	10.99	0.62	1.96	2.67	2.84	8.98	12.21	95	4.39	A	A+	4.32	5.30	1716	0.99
	2.0+2.0+2.0	2.60	2.60	2.60	2.01	7.80	10.44	0.41	1.72	2.48	1.89	7.88	11.37	95	4.56	A	A+	4.07	5.30	1821	1.10
	2.0+2.0+2.5	2.52	2.52	3.15	2.10	8.20	10.52	0.42	1.83	2.52	1.94	8.38	11.54	95	4.49	A	A+	4.09	5.30	1814	1.10
	2.0+2.0+3.5	2.29	2.29	4.01	2.31	8.60	10.63	0.44	2.04	2.65	2.02	9.34	12.13	95	4.22	A	A+	4.13	5.30	1796	1.08
	2.0+2.0+4.2	2.10	2.10	4.40	2.31	8.60	10.63	0.44	2.02	2.65	2.02	9.25	12.13	95	4.26	A	A+	4.14	5.30	1789	1.07
	2.0+2.0+5.0	1.91	1.91	4.78	2.71	8.60	10.82	0.55	2.00	2.72	2.50	9.16	12.46	95	4.30	A	A+	4.22	5.30	1755	1.03
	2.0+2.0+																				

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
4MXM68N2V1B9	1.5	1.60	---	---	---	1.57	1.60	2.49	0.40	0.42	0.59	1.82	1.98	2.71	95	---	---	---	---	---	---	---
	2.0	2.00	---	---	---	1.65	2.00	2.68	0.42	0.43	0.60	1.91	2.08	2.75	95	---	---	---	---	---	---	---
	2.5	2.50	---	---	---	1.74	2.50	3.44	0.44	0.44	0.82	2.00	2.62	3.77	95	---	---	---	---	---	---	---
	3.5	3.50	---	---	---	1.93	3.50	4.86	0.46	0.46	1.43	2.09	3.84	6.53	95	---	---	---	---	---	---	---
	4.2	---	---	4.20	---	1.93	4.20	5.33	0.46	0.46	1.44	2.09	3.93	6.57	95	---	---	---	---	---	---	---
	5.0	---	---	5.00	---	1.94	5.00	6.03	0.44	0.44	2.13	2.00	7.20	9.77	95	---	---	---	---	---	---	---
	6.0	---	---	6.00	---	1.94	6.00	6.51	0.44	0.44	2.13	2.00	7.29	9.77	95	---	---	---	---	---	---	---
	1.5+1.5	1.50	1.50	---	---	1.95	3.00	4.79	0.40	0.51	1.15	1.81	2.34	5.25	95	5.96	A	255	A++	7.29	3.0	144
	1.5+2.0	1.50	2.00	---	---	1.95	3.50	4.96	0.40	0.62	1.22	1.81	2.84	5.58	95	5.66	A	310	A++	7.53	3.5	163
	1.5+2.5	1.50	2.50	---	---	1.95	4.00	5.28	0.40	0.75	1.36	1.81	3.44	6.23	95	5.36	A	375	A++	7.75	4.0	181
	1.5+3.5	1.50	3.50	---	---	1.95	5.00	6.17	0.39	1.04	1.83	1.77	4.76	8.39	95	4.81	A	520	A++	7.8	5.0	225
	1.5+4.2	1.50	4.20	---	---	1.95	5.70	6.39	0.39	1.27	1.96	1.77	5.82	8.96	95	4.51	A	635	A++	7.84	5.7	255
	1.5+5.0	1.50	---	5.00	---	1.95	6.50	7.08	0.38	1.50	2.23	1.73	6.87	10.22	95	4.36	A	750	A++	7.86	6.5	290
	1.5+6.0	1.36	---	5.44	---	1.96	6.80	7.59	0.37	1.62	2.36	1.68	7.42	10.79	95	4.21	A	810	A++	7.81	6.8	305
	2.0+2.0	2.00	2.00	---	---	1.95	4.00	5.12	0.40	0.75	1.29	1.81	3.44	5.91	95	5.36	A	375	A++	7.75	4.0	181
	2.0+2.5	2.00	2.50	---	---	1.95	4.50	5.44	0.40	0.89	1.43	1.81	4.08	6.56	95	5.06	A	445	A++	7.8	4.5	202
	2.0+3.5	2.00	3.50	---	---	1.95	5.50	6.30	0.39	1.17	1.91	1.77	5.36	8.76	95	4.71	A	585	A++	7.91	5.5	244
	2.0+4.2	2.00	4.20	---	---	1.95	6.20	6.51	0.39	1.43	2.05	1.77	6.55	9.37	95	4.36	A	715	A++	7.88	6.2	276
	2.0+5.0	1.94	---	4.86	---	1.95	6.80	7.26	0.38	1.59	2.36	1.73	7.28	10.79	95	4.28	A	795	A++	7.78	6.8	306
	2.0+6.0	1.70	---	5.10	---	1.96	6.80	7.71	0.37	1.61	2.45	1.68	7.37	11.20	95	4.23	A	805	A++	7.71	6.8	309
	2.5+2.5	2.50	2.50	---	---	1.95	5.00	6.10	0.41	1.01	1.78	1.89	4.63	8.15	95	4.96	A	505	A++	7.81	5.0	224
	2.5+3.5	2.50	3.50	---	---	1.95	6.00	6.57	0.40	1.29	2.11	1.81	5.91	9.65	95	4.66	A	645	A++	7.94	6.0	265
	2.5+4.2	2.50	4.20	---	---	1.95	6.70	6.95	0.40	1.51	2.38	1.81	6.92	10.88	95	4.46	A	755	A++	7.99	6.7	294
	2.5+5.0	2.27	---	4.53	---	1.95	6.80	7.37	0.37	1.50	2.45	1.68	6.87	11.20	95	4.56	A	750	A++	7.93	6.8	300
	2.5+6.0	2.00	---	4.80	---	1.96	6.80	7.71	0.35	1.48	2.45	1.60	6.78	11.20	95	4.61	A	740	A++	7.9	6.8	301
	3.5+3.5	3.40	3.40	---	---	1.95	6.80	7.13	0.38	1.45	2.37	1.73	6.64	10.83	95	4.7	A	725	A++	8.02	6.8	297
	3.5+4.2	3.09	3.71	---	---	1.95	6.80	7.24	0.38	1.45	2.46	1.73	6.64	11.24	95	4.72	A	725	A++	8	6.8	298
	3.5+5.0	2.80	---	4.00	---	1.95	6.80	7.76	0.35	1.42	2.78	1.60	6.50	12.71	95	4.82	A	710	A++	7.92	6.8	301
	3.5+6.0	2.51	---	4.29	---	2.26	6.80	8.07	0.40	1.40	2.72	1.81	6.41	12.46	95	4.87	A	700	A++	7.89	6.8	302
	4.2+4.2	3.40	3.40	---	---	1.95	6.80	7.14	0.38	1.44	2.37	1.73	6.60	10.83	95	4.74	A	720	A++	7.98	6.8	298
	4.2+5.0	3.10	---	3.70	---	1.95	6.80	7.77	0.35	1.41	2.78	1.60	6.46	12.71	95	4.84	A	705	A++	7.9	6.8	302
	4.2+6.0	2.80	---	4.00	---	2.26	6.80	8.08	0.40	1.40	2.72	1.81	6.41	12.46	95	4.89	A	700	A++	7.87	6.8	303
	5.0+5.0	---	---	3.40	3.40	2.34	6.80	8.22	0.43	1.38	2.98	1.98	6.32	13.65	95	4.94	A	690	A++	7.88	6.8	302
	5.0+6.0	---	---	3.09	3.71	2.47	6.80	8.45	0.44	1.37	2.92	2.02	6.28	13.36	95	4.99	A	685	A++	7.85	6.8	304
	1.5+1.5+1.5	1.50	1.50	1.50	---	1.96	4.50	6.40	0.39	0.61	1.57	1.77	2.80	7.17	95	7.46	A	305	A+++	8.54	4.5	185
	1.5+1.5+2.0	1.44	1.44	1.92	---	1.96	4.80	6.56	0.39	0.70	1.65	1.77	3.21	7.54	95	6.86	A	350	A+++	8.52	4.8	198
	1.5+1.5+2.5	1.36	1.36	2.27	---	1.96	5.00	6.72	0.39	0.80	1.73	1.77	3.67	7.90	95	6.26	A	400	A+++	8.5	5.0	206
	1.5+1.5+3.5	1.50	1.50	3.50	---	1.96	6.50	7.11	0.38	1.56	1.92	1.73	7.14	8.80	95	4.19	A	780	A++	7.85	6.5	290
	1.5+1.5+4.2	1.42	1.42	3.97	---	1.96	6.80	7.33	0.38	1.80	2.05	1.73	8.24	9.37	95	3.79	A	900	A++	7.71	6.8	309
	1.5+1.5+5.0	1.28	1.28	4.25	---	1.96	6.80	7.74	0.36	1.75	2.22	1.64	8.01	10.14	95	3.89	A	875	A++	7.64	6.8	312
	1.5+1.5+6.0	1.13	1.13	4.53	---	2.31	6.80	7.99	0.40	1.73	2.17	1.85	7.92	9.94	95	3.94	A	865	A++	7.62	6.8	313
	1.5+2.0+2.0	1.50	2.00	2.00	---	1.96	5.50	6.48	0.39	1.01	1.61	1.77	4.63	7.37	95	5.46	A	505	A++	8.17	5.5	236
1.5+2.0+2.5	1.50	2.00	2.50	---	1.96	6.00	6.87	0.39	1.32	1.81	1.77	6.05	8.27	95	4.56	A	660	A++	7.9	6.0	266	
1.5+2.0+3.5	1.46	1.94	3.40	---	1.96	6.80	7.25	0.38	1.80	2.01	1.73	8.24	9.21	95	3.79	A	900	A++	7.71	6.8	309	
1.5+2.0+4.2	1.32	1.77	3.71	---	1.96	6.80	7.47	0.38	1.79	2.14	1.73	8.20	9.78	95	3.81	A	895	A++	7.69	6.8	310	
1.5+2.0+5.0	1.20	1.60	4.00	---	1.96	6.80	7.87	0.36	1.74	2.31	1.64	7.97	10.55	95	3.91	A	870	A++	7.63	6.8	312	
1.5+2.0+6.0	1.07	1.43	4.29	---	2.31	6.80	8.13	0.40	1.72	2.26	1.85	7.88	10.35	95	3.96	A	860	A++	7.6	6.8	313	
1.5+2.5+2.5	1.50	2.50	2.50	---	1.96	6.50	7.10	0.38	1.63	1.92	1.73	7.46	8.80	95	4.01	A	815	A++	7.76	6.5	294	
1.5+2.5+3.5	1.36	2.27	3.17	---	1.96	6.80	7.60	0.36	1.79	2.23	1.64	8.20	10.18	95	3.81	A	895	A++	7.69	6.8	310	
1.5+2.5+4.2	1.24	2.07	3.48	---	1.96	6.80	7.81	0.36	1.78	2.35	1.64	8.15	10.75	95	3.83	A	890	A++	7.67	6.8	310	
1.5+2.5+5.0	1.13	1.89	3.78	---	1.96	6.80	7.95	0.36	1.74	2.35	1.64	7.97	10.75	95	3.93	A	870	A++	7.61	6.8	313	
1.5+2.5+6.0	1.02	1.70	4.08	---	2.31	6.80	8.42	0.41	1.71	2.44	1.89	7.83	11.16	95	3.98	A	855	A++	7.59	6.8	314	
1.5+3.5+3.5	1.20	2.80	2.80	---	1.96	6.80	7.94	0.37	1.77	2.45	1.68	8.11	11.20	95	3.85	A	885	A++	7.67	6.8	311	
1.5+3.5+4.2	1.11	2.59	3.10	---	1.96	6.80	8.13	0.37	1.76	2.58	1.68	8.06	11.81	95	3.87	A	880	A++	7.65	6.8	311	
1.5+3.5+5.0	1.02	2.38	3.40	---	1.96	6.80	8.46	0.33	1.72	2.72	1.52	7.88	12.46	95	3.97	A	860	A++	7.58	6.8	314	
1.5+3.5+6.0	0.93	2.16	3.71	---	2.31	6.80	8.56	0.41	1.70	2.53	1.89	7.79	11.57	95	4.02	A	850	A++	7.56	6.8	315	
1.5+4.2+4.2	1.03	2.88	2.88	---	1.96	6.80	8.26	0.37	1.75	2.68	1.68	8.01	12.26	95	3.89	A	875	A++	7.63	6.8	312	
1.5+4.2+5.0	0.95	2.67	3.18	---	1.96	6.80	8.53	0.33	1.71	2.77	1.52	7.83	12.67	95	3.99	A	855	A++	7.56	6.8	315	
2.0+2.0+2.0	2.00	2.00	2.00	---	1.96	6.00	6.64	0.39	1.34	1.68	1.77	6.14	7.70	95	4.51	A	670	A++	7.84	6.0	268	
2.0+2.0+2.5	2.00	2.00	2.50	---	1.96	6.50	7.03	0.39	1.63	1.89	1.77	7.46	8.64	95	4.01	A	815	A++	7.76	6.5	294	
2.0+2.0+3.5	1.81	1.81	3.17	---	1.96	6.80	7.40	0.38	1.79	2.09	1.73	8.20	9.57	95	3.81	A	895	A++	7.69	6.8	310	
2.0+2.0+4.2	1.66	1.66	3.48	---	1.96	6.80	7.61	0.38	1.78	2.23	1.73	8.15	10.18	95	3.83	A	890	A++	7.67	6.8	310	
2.0+2.0+5.0	1.51	1.51	3.78	---	1.96	6.80	8.01	0.36	1.74	2.39	1.64	7.97	10.96	95	3.93	A	870	A++	7.61	6.8	313	
2.0+2.0+6.0	1.36	1.36	4.08	---	2.31	6.80	8.27	0.40	1.71	2.35	1.85	7.83	10.75	9								

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
4MXM68N2V1B9	2.0+2.5+3.5	1.70	2.13	2.98	---	1.96	6.80	7.74	0.36	1.76	2.31	1.64	8.06	10.55	95	3.87	A	880	A++	7.69	6.8	310
	2.0+2.5+4.2	1.56	1.95	3.28	---	1.96	6.80	7.94	0.36	1.75	2.45	1.64	8.01	11.20	95	3.89	A	875	A++	7.68	6.8	310
	2.0+2.5+5.0	1.43	1.79	3.58	---	1.96	6.80	8.08	0.36	1.71	2.44	1.64	7.83	11.16	95	3.99	A	855	A++	7.61	6.8	313
	2.0+2.5+6.0	1.30	1.62	3.89	---	2.31	6.80	8.55	0.41	1.69	2.53	1.89	7.74	11.57	95	4.04	A	845	A++	7.58	6.8	314
	2.0+3.5+3.5	1.51	2.64	2.64	---	1.96	6.80	8.07	0.37	1.74	2.54	1.68	7.97	11.61	95	3.91	A	870	A++	7.67	6.8	311
	2.0+3.5+4.2	1.40	2.45	2.94	---	1.96	6.80	8.25	0.37	1.74	2.68	1.68	7.97	12.26	95	3.93	A	870	A++	7.65	6.8	311
	2.0+3.5+5.0	1.30	2.27	3.24	---	2.28	6.80	8.58	0.40	1.69	2.82	1.85	7.74	12.91	95	4.03	A	845	A++	7.58	6.8	314
	2.0+4.2+4.2	1.31	2.75	2.75	---	1.96	6.80	8.37	0.37	1.73	2.77	1.68	7.92	12.67	95	3.95	A	865	A++	7.63	6.8	312
	2.5+2.5+2.5	2.27	2.27	2.27	---	1.96	6.80	7.53	0.38	1.76	2.18	1.73	8.06	9.98	95	3.87	A	880	A++	7.7	6.8	310
	2.5+2.5+3.5	2.00	2.00	2.80	---	1.96	6.80	7.94	0.36	1.72	2.45	1.64	7.88	11.20	95	3.97	A	860	A++	7.62	6.8	313
	2.5+2.5+4.2	1.85	1.85	3.10	---	1.96	6.80	8.12	0.36	1.71	2.58	1.64	7.83	11.81	95	3.99	A	855	A++	7.6	6.8	313
	2.5+2.5+5.0	1.70	1.70	3.40	---	2.28	6.80	8.45	0.40	1.67	2.72	1.85	7.65	12.46	95	4.09	A	835	A++	7.53	6.8	316
	2.5+2.5+6.0	1.55	1.55	3.71	---	2.42	6.80	8.74	0.40	1.65	2.67	1.85	7.56	12.22	95	4.14	A	825	A++	7.51	6.8	317
	2.5+3.5+3.5	1.79	2.51	2.51	---	2.27	6.80	8.30	0.40	1.70	2.72	1.85	7.79	12.46	95	4.01	A	850	A++	7.59	6.8	314
	2.5+3.5+4.2	1.67	2.33	2.80	---	2.27	6.80	8.43	0.40	1.69	2.82	1.85	7.74	12.91	95	4.03	A	845	A++	7.58	6.8	314
	2.5+3.5+5.0	1.55	2.16	3.09	---	2.48	6.80	8.74	0.42	1.65	2.96	1.94	7.56	13.56	95	4.13	A	825	A++	7.5	6.8	317
	2.5+4.2+4.2	1.56	2.62	2.62	---	2.27	6.80	8.49	0.40	1.68	2.87	1.85	7.69	13.12	95	4.05	A	840	A++	7.56	6.8	315
	3.5+3.5+3.5	2.27	2.27	2.27	---	2.38	6.80	8.59	0.40	1.68	2.96	1.81	7.69	13.56	95	4.05	A	840	A++	7.57	6.8	315
	1.5+1.5+1.5+1.5	1.65	1.65	1.65	1.65	1.97	6.60	7.09	0.38	1.38	1.63	1.73	6.32	7.45	95	4.79	A	690	A+++	8.54	6.6	271
	1.5+1.5+1.5+2.0	1.52	1.52	1.52	2.03	1.97	6.60	7.27	0.38	1.37	1.70	1.73	6.28	7.78	95	4.85	A	685	A+++	8.52	6.6	271
	1.5+1.5+1.5+2.5	1.41	1.41	1.41	2.36	1.97	6.60	7.45	0.36	1.35	1.78	1.64	6.18	8.15	95	4.91	A	675	A+++	8.5	6.6	272
	1.5+1.5+1.5+3.5	1.28	1.28	1.28	2.98	1.97	6.80	7.87	0.37	1.58	1.99	1.68	7.24	9.12	95	4.31	A	790	A++	8.03	6.8	297
	1.5+1.5+1.5+4.2	1.17	1.17	1.17	3.28	1.97	6.80	8.04	0.37	1.58	2.07	1.68	7.24	9.49	95	4.33	A	790	A++	8.01	6.8	297
	1.5+1.5+1.5+5.0	1.07	1.07	1.07	3.58	2.45	6.80	8.48	0.42	1.54	2.32	1.94	7.05	10.63	95	4.43	A	770	A++	7.94	6.8	300
	1.5+1.5+1.5+6.0	0.97	0.97	0.97	3.89	2.48	6.80	8.38	0.40	1.52	2.08	1.81	6.96	9.53	95	4.48	A	760	A++	7.91	6.8	301
	1.5+1.5+2.0+2.0	1.46	1.46	1.94	1.94	1.97	6.80	7.45	0.38	1.60	1.78	1.73	7.33	8.15	95	4.27	A	800	A++	8.06	6.8	296
	1.5+1.5+2.0+2.5	1.36	1.36	1.81	2.27	1.97	6.80	7.62	0.36	1.58	1.87	1.64	7.24	8.55	95	4.31	A	790	A++	8.05	6.8	296
	1.5+1.5+2.0+3.5	1.20	1.20	1.60	2.80	1.97	6.80	8.03	0.37	1.57	2.07	1.68	7.19	9.49	95	4.35	A	785	A++	8.02	6.8	297
	1.5+1.5+2.0+4.2	1.11	1.11	1.48	3.10	1.97	6.80	8.19	0.37	1.56	2.16	1.68	7.14	9.90	95	4.37	A	780	A++	8.01	6.8	298
	1.5+1.5+2.0+5.0	1.02	1.02	1.36	3.40	2.45	6.80	8.63	0.42	1.53	2.41	1.94	7.01	11.04	95	4.47	A	765	A++	7.93	6.8	301
	1.5+1.5+2.0+6.0	0.93	0.93	1.24	3.71	2.48	6.80	8.56	0.40	1.51	2.18	1.81	6.92	9.98	95	4.52	A	755	A++	7.9	6.8	302
	1.5+1.5+2.5+2.5	1.28	1.28	2.13	2.13	1.97	6.80	7.70	0.36	1.58	1.90	1.64	7.24	8.72	95	4.33	A	790	A++	8.03	6.8	297
	1.5+1.5+2.5+3.5	1.13	1.13	1.89	2.64	2.32	6.80	8.11	0.46	1.56	2.12	2.11	7.14	9.69	95	4.37	A	780	A++	8.01	6.8	298
	1.5+1.5+2.5+4.2	1.05	1.05	1.75	2.94	2.32	6.80	8.27	0.46	1.55	2.21	2.11	7.10	10.10	95	4.39	A	775	A++	7.99	6.8	298
	1.5+1.5+2.5+5.0	0.97	0.97	1.62	3.24	2.45	6.80	8.70	0.42	1.52	2.46	1.94	6.96	11.24	95	4.49	A	760	A++	7.91	6.8	301
	1.5+1.5+3.5+3.5	1.02	1.02	2.38	2.38	2.32	6.80	8.57	0.46	1.55	2.39	2.11	7.10	10.92	95	4.41	A	775	A++	7.98	6.8	299
	1.5+1.5+3.5+4.2	0.95	0.95	2.22	2.67	2.44	6.80	8.65	0.50	1.54	2.44	2.27	7.05	11.16	95	4.43	A	770	A++	7.96	6.8	299
	1.5+2.0+2.0+2.0	1.36	1.81	1.81	1.81	1.97	6.80	7.61	0.38	1.59	1.87	1.73	7.28	8.55	95	4.29	A	795	A++	8.04	6.8	296
	1.5+2.0+2.0+2.5	1.28	1.70	1.70	2.13	1.97	6.80	7.78	0.36	1.58	1.95	1.64	7.24	8.92	95	4.31	A	790	A++	8.02	6.8	297
	1.5+2.0+2.0+3.5	1.13	1.51	1.51	2.64	2.32	6.80	8.18	0.46	1.57	2.16	2.11	7.19	9.90	95	4.35	A	785	A++	8	6.8	298
	1.5+2.0+2.0+4.2	1.05	1.40	1.40	2.94	2.32	6.80	8.34	0.46	1.56	2.25	2.11	7.14	10.31	95	4.37	A	780	A++	7.98	6.8	299
	1.5+2.0+2.0+5.0	0.97	1.30	1.30	3.24	2.45	6.80	8.77	0.42	1.53	2.51	1.94	7.01	11.49	95	4.47	A	765	A++	7.9	6.8	302
	1.5+2.0+2.5+2.5	1.20	1.60	2.00	2.00	1.97	6.80	7.86	0.36	1.58	1.99	1.64	7.24	9.12	95	4.33	A	790	A++	8.01	6.8	298
	1.5+2.0+2.5+3.5	1.07	1.43	1.79	2.51	2.32	6.80	8.26	0.46	1.56	2.21	2.11	7.14	10.10	95	4.37	A	780	A++	7.98	6.8	299
	1.5+2.0+2.5+4.2	1.00	1.33	1.67	2.80	2.32	6.80	8.43	0.46	1.55	2.30	2.11	7.10	10.51	95	4.39	A	775	A++	7.96	6.8	299
	1.5+2.0+2.5+5.0	0.93	1.24	1.55	3.09	2.45	6.80	8.85	0.42	1.52	2.55	1.94	6.96	11.69	95	4.49	A	760	A++	7.88	6.8	302
	1.5+2.0+3.5+3.5	0.97	1.30	2.27	2.27	1.98	6.80	8.64	0.37	1.55	2.44	1.68	7.10	11.16	95	4.41	A	775	A++	7.95	6.8	300
	1.5+2.5+2.5+2.5	1.13	1.89	1.89	1.89	1.97	6.80	8.18	0.33	1.57	2.16	1.52	7.19	9.90	95	4.35	A	785	A++	7.99	6.8	298
1.5+2.5+2.5+3.5	1.02	1.70	1.70	2.38	2.32	6.80	8.49	0.40	1.55	2.34	1.81	7.10	10.71	95	4.39	A	775	A++	7.96	6.8	299	
1.5+2.5+2.5+4.2	0.95	1.59	1.59	2.67	2.32	6.80	8.50	0.41	1.55	2.34	1.89	7.10	10.71	95	4.41	A	775	A++	7.94	6.8	300	
1.5+2.5+3.5+3.5	0.93	1.55	2.16	2.16	2.32	6.80	8.71	0.40	1.54	2.48	1.81	7.05	11.36	95	4.43	A	770	A++	7.93	6.8	300	
2.0+2.0+2.0+2.0	1.70	1.70	1.70	1.70	1.97	6.80	7.78	0.38	1.58	1.95	1.73	7.24	8.92	95	4.31	A	790	A++	8.03	6.8	297	
2.0+2.0+2.0+2.5	1.60	1.60	1.60	2.00	1.97	6.80	7.95	0.36	1.58	2.04	1.64	7.24	9.33	95	4.33	A	790	A++	8.01	6.8	297	
2.0+2.0+2.0+3.5	1.43	1.43	1.43	2.51	1.97	6.80	8.33	0.37	1.56	2.25	1.68	7.14	10.31	95	4.37	A	780	A++	7.98	6.8	298	
2.0+2.0+2.0+4.2	1.33	1.33	1.33	2.80	1.97	6.80	8.49	0.37	1.55	2.34	1.68	7.10	10.71	95	4.39	A	775	A++	7.97	6.8	299	
2.0+2.0+2.0+5.0	1.24	1.24	1.24	3.09	2.45	6.80	8.91	0.42	1.52	2.61	1.94	6.96	11.93	95	4.49	A	760	A++	7.88	6.8	302	
2.0+2.0+2.5+2.5	1.51	1.51	1.89	1.89	1.97	6.80	8.10	0.37	1.57	2.12	1.68	7.19	9.69	95	4.35	A	785	A++	7.99	6.8	298	
2.0+2.0+2.5+3.5	1.36	1.36	1.70	2.38	2.32	6.80	8.49	0.41	1.55	2.34	1.89	7.10	10.71	95	4.39	A	775	A++	7.97	6.8	299	
2.0+2.0+2.5+4.2	1.27	1.27	1.59	2.67	2.32	6.80	8.64	0.41	1.55	2.44	1.89	7.10	11.16	95	4.41	A	775	A++	7.95	6.8	300	
2.0+2.0+3.5+3.5	1.24	1.24	2.16	2.16	2.44	6.80	8.78	0.41	1.55	2.53	1.89											

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
4MXM68N2V1B9	1.5	2.70	---	---	---	1.47	2.70	4.08	0.42	0.73	1.22	1.91	3.35	5.58	95	---	---	---	---	---	---	---
	2.0	2.72	---	---	---	1.48	2.72	4.09	0.43	0.74	1.28	1.95	3.39	5.86	95	---	---	---	---	---	---	---
	2.5	3.40	---	---	---	1.44	3.40	4.30	0.42	1.03	1.37	1.91	4.72	6.27	95	---	---	---	---	---	---	---
	3.5	4.30	---	---	---	1.45	4.30	4.90	0.40	1.42	1.75	1.82	6.50	8.01	95	---	---	---	---	---	---	---
	4.2	---	---	4.32	---	1.44	4.32	5.70	0.40	1.41	2.04	1.82	6.46	9.34	95	---	---	---	---	---	---	---
	5.0	---	---	5.60	---	1.66	5.60	6.90	0.39	1.84	2.59	1.78	8.43	11.85	95	---	---	---	---	---	---	---
	6.0	---	---	7.90	---	1.88	7.90	8.91	0.37	2.65	2.64	1.69	12.13	12.08	95	---	---	---	---	---	---	---
	1.5+1.5	2.65	2.65	---	---	1.65	5.30	7.38	0.36	1.19	1.83	1.63	5.45	8.38	95	4.45	A	A	3.85	3.80	1380	0.73
	1.5+2.0	2.44	3.26	---	---	1.65	5.70	7.76	0.36	1.31	1.99	1.63	6.00	9.09	95	4.35	A	A	3.85	3.80	1380	0.72
	1.5+2.5	2.29	3.81	---	---	1.65	6.10	7.95	0.36	1.43	2.06	1.63	6.55	9.43	95	4.27	A	A	3.87	3.80	1373	0.71
	1.5+3.5	2.07	4.83	---	---	1.80	6.90	8.50	0.37	1.69	2.35	1.68	7.74	10.74	95	4.10	A	A	3.86	4.30	1558	0.92
	1.5+4.2	1.97	---	5.53	---	1.80	7.50	8.85	0.37	1.90	2.57	1.68	8.70	11.75	95	3.97	A	A	3.88	4.30	1548	0.91
	1.5+5.0	1.89	---	6.31	---	1.80	8.20	10.38	0.45	2.13	2.91	2.06	9.75	13.31	95	3.86	A	A	3.87	4.50	1628	0.96
	1.5+6.0	1.72	---	6.88	---	2.46	8.60	10.58	0.48	2.28	2.67	2.19	10.44	12.21	95	3.78	A	A	3.91	4.80	1717	1.07
	2.0+2.0	3.25	3.25	---	---	1.65	6.50	7.95	0.36	1.37	2.31	1.63	6.28	10.57	95	4.75	A	A	3.91	3.80	1361	0.71
	2.0+2.5	3.07	3.83	---	---	1.65	6.90	8.12	0.36	1.52	2.32	1.63	6.96	10.62	95	4.56	A	A	3.92	3.80	1354	0.71
	2.0+3.5	2.73	4.77	---	---	1.80	7.50	8.67	0.37	1.75	2.43	1.68	8.01	11.12	95	4.30	A	A	3.86	4.30	1558	0.91
	2.0+4.2	2.58	---	5.42	---	1.80	8.00	9.03	0.37	1.98	2.66	1.68	9.07	12.17	95	4.06	A	A	3.88	4.30	1550	0.9
	2.0+5.0	2.46	---	6.14	---	2.18	8.60	10.56	0.45	2.26	3.00	2.06	10.35	13.73	95	3.82	A	A	3.90	4.50	1612	0.96
	2.0+6.0	2.15	---	6.45	---	2.46	8.60	10.75	0.48	2.24	2.74	2.19	10.26	12.55	95	3.84	A	A	3.93	4.80	1710	1.07
	2.5+2.5	3.60	3.60	---	---	1.65	7.20	8.49	0.36	1.62	2.36	1.63	7.42	10.78	95	4.46	A	A	3.85	4.00	1455	0.79
	2.5+3.5	3.29	4.61	---	---	1.89	7.90	9.03	0.38	1.91	2.66	1.72	8.75	12.17	95	4.14	A	A	3.83	4.30	1569	0.9
	2.5+4.2	3.10	---	5.20	---	1.89	8.30	9.29	0.38	2.11	2.82	1.72	9.66	12.93	95	3.95	A	A	3.86	4.30	1559	0.9
	2.5+5.0	2.87	---	5.73	---	2.27	8.60	10.68	0.46	2.24	3.09	2.11	10.26	14.15	95	3.86	A	A	3.84	4.50	1637	0.91
	2.5+6.0	2.53	---	6.07	---	2.55	8.60	10.88	0.50	2.22	2.77	2.28	10.17	12.67	95	3.88	A	A	3.91	4.80	1716	1
	3.5+3.5	4.30	4.30	---	---	2.17	8.60	9.38	0.42	2.26	2.86	1.94	10.35	13.09	95	3.81	A	A+	4.00	4.80	1680	1.07
	3.5+4.2	3.91	---	4.69	---	2.17	8.60	9.47	0.42	2.26	2.91	1.94	10.35	13.31	95	3.82	A	A+	4.01	4.80	1675	1.06
	3.5+5.0	3.54	---	5.06	---	2.56	8.60	10.90	0.51	2.22	3.13	2.32	10.17	14.32	95	3.88	A	A+	4.01	4.80	1675	1.03
	3.5+6.0	3.17	---	5.43	---	2.74	8.60	11.01	0.52	2.21	2.76	2.37	10.12	12.63	95	3.91	A	A+	4.06	4.80	1652	1.01
	4.2+4.2	---	---	4.30	4.30	2.17	8.60	9.56	0.42	2.22	2.94	1.94	10.17	13.47	95	3.88	A	A+	4.00	4.80	1679	1.04
	4.2+5.0	---	---	3.93	4.67	2.56	8.60	10.91	0.51	2.21	3.19	2.32	10.12	14.61	95	3.90	A	A	3.93	5.20	1851	1.2
	4.2+6.0	---	---	3.54	5.06	2.74	8.60	11.02	0.51	2.20	2.79	2.32	10.07	12.76	95	3.92	A	A+	4.03	5.20	1804	1.18
	5.0+5.0	---	---	4.30	4.30	2.94	8.60	11.10	0.59	2.17	3.11	2.71	9.94	14.23	95	3.98	A	A+	4.06	5.20	1793	1.15
	5.0+6.0	---	---	3.91	4.69	3.14	8.60	11.10	0.60	2.15	2.72	2.75	9.84	12.46	95	4.01	A	A+	4.09	5.20	1779	1.13
	1.5+1.5+1.5	2.17	2.17	2.17	---	2.01	6.50	9.92	0.41	1.33	2.26	1.89	6.09	10.36	95	4.91	A	A+	4.07	5.30	1822	1.11
	1.5+1.5+2.0	2.07	2.07	2.76	---	2.01	6.90	10.10	0.41	1.46	2.34	1.89	6.69	10.69	95	4.74	A	A+	4.08	5.30	1817	1.1
	1.5+1.5+2.5	2.02	2.02	3.36	---	2.10	7.40	10.18	0.42	1.64	2.37	1.94	7.51	10.86	95	4.53	A	A+	4.09	5.30	1810	1.09
	1.5+1.5+3.5	1.89	1.89	4.42	---	2.31	8.20	10.29	0.44	1.87	2.49	2.02	8.56	11.41	95	4.39	A	A+	4.14	5.30	1793	1.07
	1.5+1.5+4.2	1.79	1.79	5.02	---	2.31	8.60	10.29	0.44	2.03	2.49	2.02	9.30	11.41	95	4.25	A	A+	4.15	5.30	1786	1.07
	1.5+1.5+5.0	1.61	1.61	5.38	---	2.71	8.60	10.46	0.55	2.01	2.57	2.50	9.20	11.75	95	4.29	A	A+	4.23	5.30	1752	1.03
	1.5+1.5+6.0	1.43	1.43	5.73	---	2.93	8.60	10.59	0.55	1.99	2.31	2.50	9.11	10.57	95	4.33	A	A+	4.27	5.30	1735	1.01
	1.5+2.0+2.0	2.35	3.13	3.13	---	2.01	8.60	10.26	0.41	2.05	2.41	1.89	9.39	11.03	95	4.21	A	A+	4.09	5.30	1814	1.1
	1.5+2.0+2.5	2.15	2.87	3.58	---	2.10	8.60	10.36	0.42	2.04	2.44	1.94	9.34	11.16	95	4.23	A	A+	4.10	5.30	1807	1.09
	1.5+2.0+3.5	1.84	2.46	4.30	---	2.31	8.60	10.45	0.44	2.02	2.58	2.02	9.25	11.79	95	4.26	A	A+	4.14	5.30	1793	1.07
	1.5+2.0+4.2	1.68	2.23	4.69	---	2.31	8.60	10.46	0.44	2.01	2.57	2.02	9.20	11.75	95	4.28	A	A+	4.15	5.30	1786	1.07
	1.5+2.0+5.0	1.52	2.02	5.06	---	2.71	8.60	10.88	0.55	2.00	2.64	2.50	9.16	12.08	95	4.32	A	A+	4.23	5.30	1752	1.03
	1.5+2.0+6.0	1.36	1.81	5.43	---	2.93	8.60	10.89	0.55	1.98	2.38	2.50	9.07	10.91	95	4.36	A	A+	4.27	5.30	1735	1.01
	1.5+2.5+2.5	1.98	3.31	3.31	---	2.20	8.60	10.47	0.45	2.03	2.44	2.06	9.30	11.16	95	4.25	A	A+	4.12	5.30	1800	1.08
	1.5+2.5+3.5	1.72	2.87	4.01	---	2.40	8.60	10.58	0.47	2.02	2.57	2.15	9.25	11.75	95	4.27	A	A+	4.16	5.30	1782	1.06
	1.5+2.5+4.2	1.57	2.62	4.40	---	2.41	8.60	10.58	0.47	2.00	2.57	2.15	9.16	11.75	95	4.30	A	A+	4.19	5.30	1768	1.05
1.5+2.5+5.0	1.43	2.39	4.78	---	2.81	8.60	11.00	0.56	1.99	2.64	2.58	9.11	12.08	95	4.34	A	A+	4.27	5.30	1735	1.01	
1.5+2.5+6.0	1.29	2.15	5.16	---	3.02	8.60	11.00	0.57	1.97	2.38	2.62	9.02	10.91	95	4.38	A	A+	4.31	5.30	1719	0.99	
1.5+3.5+3.5	1.52	3.54	3.54	---	2.69	8.60	10.59	0.55	1.99	2.57	2.50	9.11	11.75	95	4.33	A	A+	4.20	5.30	1765	1.04	
1.5+3.5+4.2	1.40	3.27	3.93	---	2.69	8.60	10.59	0.55	1.98	2.56	2.50	9.07	11.71	95	4.35	A	A+	4.22	5.30	1752	1.03	
1.5+3.5+5.0	1.29	3.01	4.30	---	3.00	8.60	10.93	0.62	1.97	2.59	2.84	9.02	11.87	95	4.38	A	A+	4.30	5.30	1722	0.99	
1.5+3.5+6.0	1.17	2.74	4.69	---	2.93	8.60	10.93	0.55	1.96	2.37	2.50	8.98	10.86	95	4.40	A	A+	4.34	5.30	1707	0.98	
1.5+4.2+4.2	1.30	---	3.65	3.65	2.69	8.60	10.68	0.55	1.98	2.59	2.50	9.07	11.87	95	4.35	A	A+	4.24	5.30	1748	1.02	
1.5+4.2+5.0	1.21	---	3.38	4.02	3.00	8.60	10.99	0.62	1.96	2.67	2.84	8.98	12.21	95	4.39	A	A+	4.32	5.30	1716	0.99	
2.0+2.0+2.0	2.60	2.60	2.60	---	2.01	7.80	10.44	0.41	1.72	2.48	1.89	8.88	11.37	95	4.56	A	A+	4.07	5.30	1821	1.1	
2.0+2.0+2.5	2.52	2.52	3.15	---	2.10	8.20	10.52	0.42	1.83	2.52	1.94	8.38	11.54	95	4.49	A	A+	4.09	5.30	1814	1.1	
2.0+2.0+3.5	2.29	2.29	4.01	---	2.31	8.60	10.63	0.44	2.04	2.65	2.02	9.34	12.13	95	4.22	A	A+	4.13	5.30	1796	1.08	
2.0+2.0+4.2	2.10	2.10	4.40	---	2.31	8.60	10.63	0.44	2.02	2.65	2.02	9.25	12.13	95	4.26	A	A+	4.14	5.30	1789	1.07	
2.0+2.0+5.0	1.91	1.91	4.78	---	2.71	8.60	10.82	0.55	2.00	2.72	2.50	9.16	12.46	95								

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
4MXM68N2V1B9	2.0+2.5+3.5	2.15	2.69	3.76	---	2.40	8.60	10.63	0.46	2.02	2.65	2.11	9.25	12.13	95	4.27	A	A+	4.14	5.30	1789	1.07
	2.0+2.5+4.2	1.98	2.47	4.15	---	2.41	8.60	10.64	0.46	2.01	2.64	2.11	9.20	12.08	95	4.29	A	A+	4.16	5.30	1782	1.06
	2.0+2.5+5.0	1.81	2.26	4.53	---	2.81	8.60	11.06	0.56	1.98	2.75	2.58	9.07	12.59	95	4.34	A	A+	4.24	5.30	1748	1.02
	2.0+2.5+6.0	1.64	2.05	4.91	---	3.02	8.60	11.07	0.56	1.98	2.43	2.58	9.07	11.12	95	4.36	A	A+	4.28	5.30	1732	1.01
	2.0+3.5+3.5	1.91	3.34	3.34	---	2.69	8.60	10.76	0.52	2.00	2.70	2.37	9.16	12.34	95	4.32	A	A+	4.18	5.30	1772	1.05
	2.0+3.5+4.2	1.77	3.10	3.72	---	2.69	8.60	10.76	0.52	1.99	2.69	2.37	9.11	12.29	95	4.33	A	A+	4.20	5.30	1765	1.04
	2.0+3.5+5.0	1.64	2.87	4.10	---	3.00	8.60	11.11	0.58	1.98	2.82	2.67	9.07	12.88	95	4.36	A	A+	4.28	5.30	1732	1.01
	2.0+4.2+4.2	1.65	---	3.47	3.47	2.69	8.60	10.77	0.52	1.97	2.69	2.37	9.02	12.29	95	4.38	A	A+	4.32	5.30	1716	0.99
	2.5+2.5+2.5	2.87	2.87	2.87	---	3.31	8.60	10.65	0.45	1.99	2.64	2.06	9.11	12.08	95	4.32	A	A+	4.12	5.30	1800	1.08
	2.5+2.5+3.5	2.53	2.53	3.54	---	2.50	8.60	10.87	0.48	1.99	2.72	2.19	9.11	12.46	95	4.34	A	A+	4.16	5.30	1782	1.06
	2.5+2.5+4.2	2.34	2.34	3.93	---	2.50	8.60	10.88	0.48	1.97	2.72	2.19	9.02	12.46	95	4.37	A	A+	4.18	5.30	1775	1.05
	2.5+2.5+5.0	2.15	2.15	4.30	---	2.91	8.60	11.07	0.58	1.96	2.78	2.67	8.98	12.72	95	4.41	A	A+	4.26	5.30	1742	1.02
	2.5+2.5+6.0	1.95	1.95	4.69	---	3.12	8.60	11.08	0.58	1.94	2.43	2.67	8.88	11.12	95	4.45	A	A+	4.30	5.30	1726	1
	2.5+3.5+3.5	2.26	3.17	3.17	---	2.78	8.60	11.00	0.53	1.96	2.72	2.41	8.98	12.46	95	4.40	A	A+	4.20	5.30	1765	1.04
	2.5+3.5+4.2	2.11	2.95	3.54	---	2.79	8.60	11.01	0.53	1.96	2.71	2.41	8.98	12.42	95	4.41	A	A+	4.22	5.30	1758	1.04
	2.5+3.5+5.0	1.95	2.74	3.91	---	3.19	8.60	11.08	0.60	1.90	2.74	2.75	8.70	12.55	95	4.54	A	A+	4.30	5.30	1726	1
	2.5+4.2+4.2	1.97	---	3.31	3.31	2.79	8.60	11.01	0.53	1.95	2.71	2.41	8.93	12.42	95	4.42	A	A+	4.23	5.30	1752	1.03
	3.5+3.5+3.5	2.87	2.87	2.87	---	2.98	8.60	11.06	0.57	1.94	2.79	2.62	8.88	12.76	95	4.44	A	A+	4.24	5.30	1748	1.02
	1.5+1.5+1.5+1.5	1.95	1.95	1.95	1.95	2.47	7.80	10.07	0.49	1.62	2.12	2.24	7.42	9.68	95	4.82	A	A+	4.18	5.80	1942	1.15
	1.5+1.5+1.5+2.0	1.89	1.89	1.89	2.52	2.47	8.20	10.25	0.49	1.77	2.19	2.24	8.11	10.02	95	4.65	A	A+	4.19	5.80	1937	1.15
	1.5+1.5+1.5+2.5	1.84	1.84	1.84	3.07	2.57	8.60	10.36	0.50	1.88	2.20	2.28	8.61	10.07	95	4.59	A	A+	4.19	5.80	1934	1.14
	1.5+1.5+1.5+3.5	1.61	1.61	1.61	3.76	2.77	8.60	10.46	0.54	1.84	2.21	2.45	8.43	10.11	95	4.68	A	A+	4.24	5.80	1915	1.13
	1.5+1.5+1.5+4.2	1.48	1.48	1.48	4.15	2.78	8.60	10.46	0.53	1.84	2.20	2.41	8.43	10.06	95	4.70	A	A+	4.27	5.80	1901	1.12
	1.5+1.5+1.5+5.0	1.36	1.36	1.36	4.53	3.10	8.60	10.52	0.59	1.83	2.13	2.71	8.38	9.73	95	4.71	A	A+	4.28	5.80	1896	1.08
	1.5+1.5+1.5+6.0	1.23	1.23	1.23	4.91	3.04	8.60	10.88	0.45	1.79	1.98	2.06	8.20	9.05	95	4.81	A	A+	4.38	5.80	1854	1.06
	1.5+1.5+2.0+2.0	1.84	1.84	2.46	2.46	2.47	8.60	10.44	0.49	1.87	2.26	2.24	8.56	10.36	95	4.60	A	A+	4.20	5.80	1931	1.14
	1.5+1.5+2.0+2.5	1.72	1.72	2.29	2.87	2.57	8.60	10.54	0.50	1.87	2.27	2.28	8.56	10.39	95	4.62	A	A+	4.21	5.80	1926	1.13
	1.5+1.5+2.0+3.5	1.52	1.52	2.02	3.54	2.77	8.60	10.64	0.54	1.84	2.26	2.45	8.43	10.34	95	4.70	A	A+	4.28	5.80	1895	1.12
	1.5+1.5+2.0+4.2	1.40	1.40	1.87	3.93	2.78	8.60	10.65	0.53	1.82	2.25	2.41	8.33	10.30	95	4.74	A	A+	4.32	5.80	1877	1.11
	1.5+1.5+2.0+5.0	1.29	1.29	1.72	4.30	3.10	8.60	10.71	0.59	1.82	2.20	2.71	8.33	10.06	95	4.75	A	A+	4.34	5.80	1871	1.07
	1.5+1.5+2.0+6.0	1.17	1.17	1.56	4.69	3.04	8.60	11.07	0.45	1.78	2.04	2.06	8.15	9.35	95	4.85	A	A+	4.44	5.80	1829	1.05
	1.5+1.5+2.5+2.5	1.61	1.61	2.69	2.69	2.67	8.60	10.55	0.52	1.86	2.23	2.37	8.52	10.19	95	4.63	A	A+	4.22	5.80	1921	1.12
	1.5+1.5+2.5+3.5	1.43	1.43	2.39	3.34	2.98	8.60	10.65	0.59	1.82	2.27	2.71	8.33	10.40	95	4.74	A	A+	4.32	5.80	1878	1.11
	1.5+1.5+2.5+4.2	1.33	1.33	2.22	3.72	2.98	8.60	10.65	0.58	1.81	2.27	2.67	8.29	10.40	95	4.77	A	A+	4.34	5.80	1869	1.1
	1.5+1.5+2.5+5.0	1.23	1.23	2.05	4.10	3.10	8.60	10.90	0.59	1.80	2.25	2.71	8.24	10.30	95	4.80	A	A+	4.38	5.80	1852	1.06
	1.5+1.5+3.5+3.5	1.29	1.29	3.01	3.01	3.18	8.60	10.75	0.64	1.78	2.30	2.93	8.15	10.53	95	4.85	A	A+	4.45	5.80	1822	1.09
	1.5+1.5+3.5+4.2	1.21	1.21	2.81	3.38	2.99	8.60	10.85	0.58	1.78	2.34	2.67	8.15	10.69	95	4.86	A	A++	4.60	5.80	1765	1.09
	1.5+2.0+2.0+2.0	1.72	2.29	2.29	2.29	2.47	8.60	10.63	0.49	1.87	2.34	2.24	8.56	10.69	95	4.62	A	A+	4.21	5.80	1926	1.13
	1.5+2.0+2.0+2.5	1.61	2.15	2.29	2.69	2.57	8.60	10.72	0.50	1.86	2.35	2.28	8.52	10.76	95	4.63	A	A+	4.22	5.80	1921	1.12
	1.5+2.0+2.0+3.5	1.43	1.91	1.91	3.34	2.77	8.60	10.83	0.54	1.81	2.36	2.45	8.29	10.80	95	4.76	A	A+	4.32	5.80	1880	1.11
	1.5+2.0+2.0+4.2	1.33	1.77	1.77	3.72	2.78	8.60	10.84	0.53	1.80	2.35	2.41	8.24	10.74	95	4.78	A	A+	4.33	5.80	1872	1.1
	1.5+2.0+2.0+5.0	1.23	1.64	1.64	4.10	3.10	8.60	10.90	0.59	1.79	2.26	2.71	8.20	10.36	95	4.82	A	A+	4.36	5.80	1859	1.06
	1.5+2.0+2.5+2.5	1.52	2.02	2.53	2.53	2.67	8.60	10.72	0.52	1.86	2.29	2.37	8.52	10.48	95	4.65	A	A+	4.23	5.80	1917	1.12
	1.5+2.0+2.5+3.5	1.36	1.81	2.26	3.17	2.98	8.60	10.83	0.59	1.80	2.35	2.71	8.24	10.74	95	4.78	A	A+	4.34	5.80	1871	1.1
	1.5+2.0+2.5+4.2	1.26	1.69	2.11	3.54	2.98	8.60	10.84	0.58	1.80	2.35	2.67	8.24	10.74	95	4.80	A	A+	4.35	5.80	1864	1.09
1.5+2.0+2.5+5.0	1.17	1.56	1.95	3.91	3.10	8.60	11.09	0.59	1.79	2.33	2.71	8.20	10.66	95	4.83	A	A+	4.38	5.80	1854	1.06	
1.5+2.0+3.5+3.5	1.23	1.64	2.87	2.87	3.18	8.60	10.93	0.64	1.78	2.37	2.93	8.15	10.86	95	4.84	A	A++	4.62	5.80	1757	1.09	
1.5+2.5+2.5+2.5	1.43	2.39	2.39	2.39	2.77	8.60	10.73	0.55	1.85	2.29	2.50	8.47	10.48	95	4.66	A	A+	4.24	5.80	1912	1.11	
1.5+2.5+2.5+3.5	1.29	2.15	2.15	3.01	3.08	8.60	10.92	0.62	1.79	2.38	2.84	8.20	10.91	95	4.81	A	A+	4.37	5.80	1858	1.09	
1.5+2.5+2.5+4.2	1.21	2.01	2.01	3.38	2.98	8.60	11.01	0.58	1.78	2.41	2.67	8.15	11.03	95	4.83	A	A+	4.39	5.80	1848	1.09	
1.5+2.5+3.5+3.5	1.17	1.95	2.74	2.74	3.18	8.60	11.02	0.64	1.76	2.41	2.93	8.06	11.03	95	4.90	A	A++	4.63	5.80	1751	1.08	
2.0+2.0+2.0+2.0	2.15	2.15	2.15	2.15	2.47	8.60	10.81	0.49	1.86	2.40	2.24	8.52	10.99	95	4.63	A	A+	4.22	5.80	1921	1.12	
2.0+2.0+2.0+2.5	2.02	2.02	2.02	2.53	2.57	8.60	10.90	0.50	1.86	2.41	2.28	8.52	11.03	95	4.65	A	A+	4.23	5.80	1917	1.12	
2.0+2.0+2.0+3.5	1.81	1.81	1.81	3.17	2.77	8.60	11.00	0.54	1.79	2.42	2.45	8.20	11.07	95	4.83	A	A+	4.38	5.80	1853	1.1	
2.0+2.0+2.0+4.2	1.69	1.69	1.69	3.54	2.78	8.60	11.01	0.53	1.80	2.42	2.41	8.24	11.07	95	4.80	A	A+	4.40	5.80	1846	1.09	
2.0+2.0+2.0+5.0	1.56	1.56	1.56	3.91	3.10	8.60	11.08	0.59	1.78	2.34	2.71	8.15	10.69	95	4.83	A	A+	4.42	5.80	1836	1.06	
2.0+2.0+2.5+2.5	1.91	1.91	2.39	2.39	2.67	8.60	10.91	0.52	1.85	2.36	2.37	8.47	10.82	95	4.66	A	A+	4.24	5.80	1912	1.11	
2.0+2.0+2.5+3.5	1.72	1.72	2.15	3.01	2.98	8.60	11.01	0.56	1.78	2.42	2.58	8.15	11.07	95	4.83	A	A+	4.39	5.80	1850	1.09	
2.0+2.0+2.5+4.2	1.61	1.61	2.01	3.38	2.98	8.60	11.01	0.56	1.78	2.42	2.58	8.15										

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
4MXM80N2V1B9	1.5	1.80	---	---	---	1.73	1.80	2.89	0.42	0.52	1.00	1.91	2.38	4.57	95	---	---	---	---	---	---	---
	2.0	2.00	---	---	---	1.78	2.00	3.05	0.45	0.60	1.04	2.04	2.75	4.75	95	---	---	---	---	---	---	---
	2.5	2.50	---	---	---	1.85	2.50	3.59	0.48	0.78	1.31	2.18	3.57	5.99	95	---	---	---	---	---	---	---
	3.5	3.50	---	---	---	1.89	3.50	4.95	0.48	1.19	1.52	2.18	5.45	6.97	95	---	---	---	---	---	---	---
	4.2	---	4.20	---	---	1.94	4.20	5.02	0.49	1.43	1.53	2.22	6.55	7.01	95	---	---	---	---	---	---	---
	5.0	---	5.00	---	---	2.05	5.00	5.76	0.46	1.67	1.76	2.09	7.65	8.04	95	---	---	---	---	---	---	---
	6.0	---	6.00	---	---	2.15	6.00	6.73	0.46	2.01	2.36	2.09	9.20	10.79	95	---	---	---	---	---	---	---
	7.1	---	7.10	---	---	2.26	7.10	7.41	0.49	2.71	2.75	2.22	12.41	12.56	95	---	---	---	---	---	---	---
	1.5+1.5	1.50	1.50	---	---	1.87	3.00	4.19	0.42	0.56	0.89	1.94	2.60	4.10	95	5.36	A	280	A++	6.56	3.00	165
	1.5+2.0	1.50	2.00	---	---	1.89	3.50	4.69	0.46	0.69	1.05	2.11	3.20	4.90	95	5.10	A	343	A++	6.74	3.50	183
	1.5+2.5	1.50	2.50	---	---	1.95	4.00	5.18	0.42	0.83	1.23	1.94	3.90	5.70	95	4.80	A	417	A++	6.91	4.00	205
	1.5+3.5	1.50	3.50	---	---	2.05	5.00	6.00	0.42	1.16	1.55	1.94	5.40	7.10	95	4.31	A	581	A++	6.93	5.00	257
	1.5+4.2	1.50	4.20	---	---	2.12	5.70	6.52	0.46	1.43	1.79	2.11	6.60	8.30	95	3.98	A	716	A++	6.89	5.70	294
	1.5+5.0	1.50	5.00	---	---	2.20	6.50	7.12	0.47	1.70	2.01	2.15	7.80	9.20	95	3.83	A	850	A++	6.92	6.50	329
	1.5+6.0	1.48	5.92	---	---	2.32	7.40	7.82	0.51	2.16	2.40	2.32	9.90	11.00	95	3.43	A	1079	A++	6.73	7.40	387
	1.5+7.1	1.40	6.60	---	---	2.47	8.00	8.43	0.54	2.45	2.81	2.48	11.30	13.00	95	3.26	A	1226	A++	6.63	8.00	422
	2.0+2.0	2.00	2.00	---	---	1.95	4.00	5.51	0.46	0.84	1.36	2.11	3.90	6.30	95	4.79	A	418	A++	6.90	4.00	205
	2.0+2.5	2.00	2.50	---	---	2.00	4.50	5.85	0.46	0.99	1.50	2.11	4.60	7.00	95	4.53	A	497	A++	6.91	4.50	231
	2.0+3.5	2.00	3.50	---	---	2.10	5.50	6.51	0.46	1.35	1.79	2.11	6.20	8.30	95	4.08	A	674	A++	6.90	5.50	281
	2.0+4.2	2.00	4.20	---	---	2.17	6.20	6.91	0.46	1.64	2.00	2.11	7.60	9.20	95	3.78	A	820	A++	6.83	6.20	319
	2.0+5.0	2.00	5.00	---	---	2.25	7.00	7.51	0.47	1.95	2.23	2.15	9.00	10.30	95	3.59	A	975	A++	6.81	7.00	361
	2.0+6.0	1.85	5.55	---	---	2.39	7.40	8.08	0.51	2.16	2.57	2.32	9.90	11.80	95	3.43	A	1079	A++	6.73	7.40	387
	2.0+7.1	1.76	6.24	---	---	2.53	8.00	8.65	0.54	2.45	3.00	2.48	11.30	13.80	95	3.26	A	1226	A++	6.63	8.00	422
	2.5+2.5	2.50	2.50	---	---	2.05	5.00	6.28	0.42	1.17	1.69	1.94	5.40	7.80	95	4.29	A	583	A++	6.91	5.00	256
	2.5+3.5	2.50	3.50	---	---	2.15	6.00	6.82	0.46	1.55	1.95	2.11	7.10	9.00	95	3.88	A	773	A++	6.85	6.00	307
	2.5+4.2	2.50	4.20	---	---	2.22	6.70	7.29	0.46	1.89	2.21	2.11	8.70	10.20	95	3.55	A	943	A++	6.76	6.70	349
	2.5+5.0	2.47	4.93	---	---	2.32	7.40	7.80	0.50	2.16	2.39	2.27	9.90	11.00	95	3.42	A	1081	A++	6.72	7.40	387
	2.5+6.0	2.35	5.65	---	---	2.46	8.00	8.35	0.54	2.45	2.75	2.48	11.30	12.60	95	3.26	A	1226	A++	6.63	8.00	422
	2.5+7.1	2.08	5.92	---	---	2.60	8.00	8.89	0.54	2.45	3.19	2.48	11.30	14.60	95	3.27	A	1224	A++	6.64	8.00	423
	3.5+3.5	3.50	3.50	---	---	2.25	7.00	7.51	0.46	2.04	2.33	2.11	9.40	10.70	95	3.44	A	1019	A++	6.71	7.00	368
	3.5+4.2	3.50	4.20	---	---	2.35	7.70	7.93	0.50	2.47	2.61	2.27	11.40	12.00	95	3.11	B	1236	A++	6.52	7.70	417
	3.5+5.0	3.29	4.71	---	---	2.46	8.00	8.36	0.53	2.45	2.75	2.44	11.30	12.70	95	3.27	A	1225	A++	6.64	8.00	423
	3.5+6.0	2.95	5.05	---	---	2.58	8.00	8.86	0.54	2.49	3.13	2.48	11.50	14.40	95	3.21	A	1247	A++	6.64	8.00	425
	3.5+7.1	2.64	5.36	---	---	2.74	8.00	8.51	0.58	2.46	2.82	2.65	11.30	13.00	95	3.25	A	1230	A++	6.66	8.00	421
	4.2+4.2	4.00	4.00	---	---	2.44	8.00	8.31	0.53	2.66	2.91	2.44	12.20	13.40	95	3.00	B	1331	A++	6.43	8.00	437
	4.2+5.0	3.65	4.35	---	---	2.54	8.00	8.68	0.53	2.45	3.00	2.44	11.20	13.80	95	3.27	A	1223	A++	6.65	8.00	423
	4.2+6.0	3.29	4.71	---	---	2.68	8.00	9.09	0.58	2.49	3.32	2.65	11.50	15.30	95	3.21	A	1246	A++	6.64	8.00	425
	4.2+7.1	2.97	5.03	---	---	2.83	8.00	9.37	0.62	2.46	3.59	2.82	11.30	16.50	95	3.26	A	1228	A++	6.69	8.00	419
	5.0+5.0	4.00	4.00	---	---	2.65	8.00	8.88	0.57	2.39	2.96	2.61	11.00	13.60	95	3.35	A	1194	A++	6.77	8.00	418
	5.0+6.0	3.64	4.36	---	---	2.79	8.00	9.39	0.62	2.35	3.36	2.82	10.80	15.40	95	3.41	A	1175	A++	6.80	8.00	414
	5.0+7.1	3.31	4.69	---	---	2.94	8.00	9.55	0.62	2.35	3.50	2.82	10.80	16.10	95	3.41	A	1173	A++	6.81	8.00	414
	6.0+6.0	4.36	3.64	---	---	2.93	8.00	9.60	0.62	2.35	3.56	2.82	10.80	16.40	95	3.41	A	1175	A++	6.80	8.00	414
	6.0+7.1	3.66	4.34	---	---	3.22	8.00	9.81	0.58	2.34	3.71	2.70	10.70	17.00	95	3.42	A	1168	A++	6.85	8.00	413
	7.1+7.1	4.00	4.00	---	---	3.38	8.00	9.83	0.61	2.30	3.71	2.90	10.60	17.10	95	3.47	A	1152	A++	6.87	8.00	408
	1.5+1.5+1.5	1.50	1.50	1.50	---	2.00	4.50	5.58	0.44	0.90	1.23	2.02	4.20	5.70	95	4.98	A	452	A++	7.21	4.50	223
	1.5+1.5+2.0	1.50	1.50	2.00	---	2.05	5.00	5.98	0.48	1.04	1.37	2.19	4.80	6.30	95	4.79	A	522	A++	7.23	5.00	243
1.5+1.5+2.5	1.50	1.50	2.50	---	2.10	5.50	6.37	0.48	1.21	1.51	2.19	5.60	7.00	95	4.55	A	604	A++	7.23	5.50	270	
1.5+1.5+3.5	1.50	1.50	3.50	---	2.20	6.50	7.13	0.48	1.55	1.82	2.19	7.20	8.40	95	4.18	A	777	A++	7.19	6.50	318	
1.5+1.5+4.2	1.50	1.50	4.20	---	2.28	7.20	7.60	0.48	1.86	2.03	2.19	8.50	9.40	95	3.88	A	928	A++	7.10	7.20	358	
1.5+1.5+5.0	1.39	1.39	4.63	---	2.39	7.40	8.10	0.52	1.87	2.21	2.36	8.60	10.20	95	3.95	A	937	A++	7.20	7.40	360	
1.5+1.5+6.0	1.33	1.33	5.33	---	2.52	8.00	8.55	0.55	2.15	2.45	2.53	9.90	11.30	95	3.72	A	1075	A++	7.08	8.00	396	
1.5+1.5+7.1	1.19	1.19	5.62	---	2.67	8.00	9.07	0.59	2.15	2.76	2.69	9.90	12.70	95	3.72	A	1074	A++	7.09	8.00	396	
1.5+2.0+2.0	1.50	2.00	2.00	---	2.10	5.50	6.36	0.48	1.21	1.51	2.19	5.60	7.00	95	4.55	A	605	A++	7.23	5.50	270	
1.5+2.0+2.5	1.50	2.00	2.50	---	2.15	6.00	6.74	0.48	1.39	1.66	2.19	6.40	7.70	95	4.32	A	694	A++	7.21	6.00	296	
1.5+2.0+3.5	1.50	2.00	3.50	---	2.25	7.00	7.47	0.48	1.76	1.98	2.19	8.10	9.10	95	3.98	A	880	A++	7.15	7.00	343	
1.5+2.0+4.2	1.50	2.00	4.20	---	2.35	7.70	7.92	0.51	2.09	2.20	2.32	9.60	10.10	95	3.69	A	1043	A++	7.02	7.70	384	
1.5+2.0+5.0	1.41	1.88	4.71	---	2.46	8.00	8.31	0.54	2.18	2.33	2.48	10.00	10.70	95	3.66	A	1092	A++	7.06	8.00	401	
1.5+2.0+6.0	1.26	1.68	5.05	---	2.58	8.00	8.86	0.55	2.15	2.63	2.53	9.90	12.10	95	3.72	A	1075	A++	7.08	8.00	396	
1.5+2.0+7.1	1.13	1.51	5.36	---	2.74	8.00	9.26	0.59	2.15	2.89	2.69	9.90	13.30	95	3.72	A	1074	A++	7.09	8.00	396	
1.5+2.5+2.5	1.50	2.50	2.50	---	2.20	6.50	7.11	0.48	1.56	1.82	2.19	7.20	8.40	95	4.17	A	780	A++	7.18	6.50	317	
1.5+2.5+3.5	1.48	2.47	3.45	---	2.32	7.40	7.82	0.51	1.95	2.14	2.32	9.00	9.90	95	3.79	A	977	A++	7.07	7.40	370	
1.5+2.5+4.2	1.46	2.44	4.10	---	2.42	8.00	8.25	0.51	2.25	2.37	2.32	10.30	10.90	95	3.56	A	1123	A++	6.94	8.00	405	
1.5+2.5+5.0	1.33	2.22	4.40	---	2.52	8.00	8.64	0.54	2.18	2.51	2.48	10.00	11.50	95	3.67	A	1091	A++	7.06	8.00	401	
1.5+2.5+6.0	1.20	2.00	4.80	---	2.65	8.00	9.07	0.55	2.15	2.76	2.53	9.90										

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
4MXM80N2V1B9	1.5+3.5+5.0	1.20	2.80	4.00	---	2.65	8.00	8.99	0.58	2.15	2.69	2.65	9.90	12.40	95	3.73	A	1073	A++	7.09	8.00	396
	1.5+3.5+6.0	1.09	2.55	4.36	---	2.79	8.00	9.40	0.59	2.14	2.95	2.69	9.80	13.60	95	3.74	A	1070	A++	7.11	8.00	397
	1.5+3.5+7.1	0.99	2.31	4.69	---	2.94	8.00	9.60	0.62	2.14	3.09	2.82	9.80	14.20	95	3.74	A	1069	A++	7.11	8.00	397
	1.5+4.2+4.2	1.21	3.39	3.39	---	2.64	8.00	8.98	0.58	2.24	2.80	2.65	10.30	12.90	95	3.58	A	1118	A++	6.97	8.00	406
	1.5+4.2+5.0	1.12	3.14	3.74	---	2.75	8.00	9.29	0.58	2.14	2.89	2.65	9.90	13.30	95	3.73	A	1072	A++	7.10	8.00	397
	1.5+4.2+6.0	1.03	2.87	4.10	---	2.89	8.00	9.51	0.62	2.14	3.02	2.82	9.80	13.90	95	3.74	A	1069	A++	7.11	8.00	397
	1.5+4.2+7.1	0.94	2.63	4.44	---	3.04	8.00	9.70	0.65	2.14	3.16	2.99	9.80	14.50	95	3.75	A	1068	A++	7.12	8.00	397
	1.5+5.0+5.0	1.04	3.48	3.48	---	2.86	8.00	9.48	0.62	2.09	2.90	2.82	9.60	13.40	95	3.83	A	1044	A++	7.24	8.00	390
	1.5+5.0+6.0	0.96	3.20	3.84	---	3.00	8.00	9.70	0.63	2.08	3.04	2.86	9.60	14.00	95	3.84	A	1041	A++	7.25	8.00	391
	1.5+5.0+7.1	0.88	2.94	4.18	---	3.32	8.00	9.81	0.58	2.08	3.11	2.70	9.60	14.30	95	3.85	A	1040	A++	7.26	8.00	391
	1.5+6.0+6.0	0.89	3.56	3.56	---	3.13	8.00	9.83	0.66	2.05	3.11	3.03	9.40	14.30	95	3.90	A	1026	A++	7.27	8.00	385
	2.0+2.0+2.0	2.00	2.00	2.00	---	2.15	6.00	6.85	0.48	1.39	1.71	2.19	6.40	7.90	95	4.32	A	695	A++	7.21	6.00	296
	2.0+2.0+2.5	2.00	2.00	2.50	---	2.20	6.50	7.10	0.48	1.58	1.82	2.19	7.30	8.40	95	4.11	A	791	A++	7.16	6.50	323
	2.0+2.0+3.5	1.97	1.97	3.45	---	2.32	7.40	7.80	0.51	1.96	2.14	2.32	9.00	9.90	95	3.78	A	979	A++	7.07	7.40	370
	2.0+2.0+4.2	1.95	1.95	4.10	---	2.42	8.00	8.23	0.51	2.25	2.37	2.32	10.30	10.90	95	3.56	A	1125	A++	6.93	8.00	405
	2.0+2.0+5.0	1.78	1.78	4.44	---	2.52	8.00	8.63	0.54	2.18	2.51	2.48	10.00	11.50	95	3.66	A	1092	A++	7.06	8.00	401
	2.0+2.0+6.0	1.60	1.60	4.80	---	2.65	8.00	9.06	0.55	2.15	2.76	2.53	9.90	12.70	95	3.72	A	1075	A++	7.08	8.00	396
	2.0+2.0+7.1	1.44	1.44	5.12	---	2.80	8.00	9.45	0.59	2.15	3.02	2.69	9.90	13.90	95	3.72	A	1074	A++	7.09	8.00	396
	2.0+2.5+2.5	2.00	2.50	2.50	---	2.25	7.00	7.45	0.48	1.79	1.98	2.19	8.20	9.10	95	3.91	A	894	A++	7.13	7.00	348
	2.0+2.5+3.5	1.85	2.31	3.24	---	2.39	7.40	8.13	0.51	1.95	2.31	2.32	9.00	10.70	95	3.79	A	977	A++	7.07	7.40	370
	2.0+2.5+4.2	1.84	2.30	3.86	---	2.48	8.00	8.45	0.54	2.25	2.49	2.48	10.30	11.50	95	3.56	A	1123	A++	6.94	8.00	405
	2.0+2.5+5.0	1.68	2.11	4.21	---	2.58	8.00	8.84	0.54	2.18	2.63	2.48	10.00	12.10	95	3.67	A	1091	A++	7.06	8.00	401
	2.0+2.5+6.0	1.52	1.90	4.57	---	2.72	8.00	9.26	0.59	2.15	2.88	2.69	9.90	13.30	95	3.72	A	1074	A++	7.09	8.00	396
	2.0+2.5+7.1	1.38	1.72	4.90	---	2.87	8.00	9.55	0.62	2.15	3.08	2.82	9.90	14.20	95	3.73	A	1073	A++	7.09	8.00	396
	2.0+3.5+3.5	1.78	3.11	3.11	---	2.52	8.00	8.58	0.54	2.24	2.56	2.48	10.30	11.80	95	3.57	A	1120	A++	6.96	8.00	406
	2.0+3.5+4.2	1.65	2.89	3.46	---	2.61	8.00	8.88	0.58	2.24	2.74	2.65	10.30	12.60	95	3.58	A	1119	A++	6.96	8.00	406
	2.0+3.5+5.0	1.52	2.67	3.81	---	2.72	8.00	9.18	0.58	2.15	2.82	2.65	9.90	13.00	95	3.73	A	1073	A++	7.09	8.00	396
	2.0+3.5+6.0	1.39	2.43	4.17	---	2.86	8.00	9.49	0.62	2.14	3.02	2.82	9.80	13.90	95	3.74	A	1070	A++	7.11	8.00	397
	2.0+3.5+7.1	1.27	2.22	4.51	---	3.01	8.00	9.33	0.62	2.14	2.89	2.82	9.80	13.30	95	3.74	A	1069	A++	7.11	8.00	397
	2.0+4.2+4.2	1.54	3.23	3.23	---	2.71	8.00	9.25	0.58	2.24	3.00	2.65	10.30	13.80	95	3.58	A	1118	A++	6.97	8.00	406
	2.0+4.2+5.0	1.43	3.00	3.57	---	2.82	8.00	9.47	0.62	2.14	3.02	2.82	9.90	13.90	95	3.73	A	1072	A++	7.10	8.00	397
	2.0+4.2+6.0	1.31	2.75	3.93	---	2.95	8.00	9.69	0.62	2.14	3.15	2.82	9.80	14.50	95	3.74	A	1069	A++	7.11	8.00	397
	2.0+4.2+7.1	1.20	2.53	4.27	---	3.11	8.00	9.88	0.65	2.14	3.29	2.99	9.80	15.20	95	3.75	A	1068	A++	7.12	8.00	397
	2.0+5.0+5.0	1.33	3.33	3.33	---	2.93	8.00	9.67	0.62	2.09	3.04	2.82	9.60	14.00	95	3.83	A	1044	A++	7.24	8.00	390
	2.0+5.0+6.0	1.23	3.08	3.69	---	3.06	8.00	9.79	0.65	2.08	3.11	2.99	9.60	14.30	95	3.84	A	1041	A++	7.25	8.00	391
	2.0+5.0+7.1	1.13	2.84	4.03	---	3.32	8.00	9.81	0.58	2.08	3.11	2.70	9.60	14.30	95	3.85	A	1040	A++	7.26	8.00	391
	2.0+6.0+6.0	1.14	3.43	3.43	---	3.32	8.00	9.83	0.58	2.05	3.11	2.70	9.40	14.30	95	3.90	A	1026	A++	7.27	8.00	385
	2.5+2.5+2.5	2.47	2.47	2.47	---	2.32	7.40	7.79	0.51	1.96	2.14	2.32	9.00	9.90	95	3.78	A	980	A++	7.06	7.40	370
	2.5+2.5+3.5	2.35	2.35	3.29	---	2.46	8.00	8.35	0.54	2.25	2.43	2.48	10.30	11.20	95	3.56	A	1123	A++	6.94	8.00	405
	2.5+2.5+4.2	2.17	2.17	3.65	---	2.54	8.00	8.75	0.54	2.24	2.68	2.48	10.30	12.30	95	3.57	A	1122	A++	6.95	8.00	406
	2.5+2.5+5.0	2.00	2.00	4.00	---	2.65	8.00	9.05	0.58	2.15	2.76	2.65	9.90	12.70	95	3.72	A	1076	A++	7.08	8.00	396
	2.5+2.5+6.0	1.82	1.82	4.36	---	2.79	8.00	9.37	0.59	2.15	2.95	2.69	9.90	13.60	95	3.73	A	1073	A++	7.09	8.00	396
2.5+2.5+7.1	1.65	1.65	4.69	---	2.94	8.00	9.66	0.62	2.14	3.15	2.82	9.90	14.50	95	3.73	A	1071	A++	7.10	8.00	397	
2.5+3.5+3.5	2.11	2.95	2.95	---	2.58	8.00	8.60	0.54	2.24	2.56	2.48	10.30	11.80	95	3.58	A	1118	A++	6.96	8.00	406	
2.5+3.5+4.2	1.96	2.75	3.29	---	2.68	8.00	9.08	0.58	2.23	2.87	2.65	10.30	13.20	95	3.58	A	1117	A++	6.97	8.00	406	
2.5+3.5+5.0	1.82	2.55	3.64	---	2.79	8.00	9.38	0.62	2.14	2.95	2.82	9.90	13.60	95	3.73	A	1072	A++	7.10	8.00	397	
2.5+3.5+6.0	1.67	2.33	4.00	---	2.93	8.00	9.60	0.62	2.14	3.09	2.82	9.80	14.20	95	3.74	A	1069	A++	7.11	8.00	397	
2.5+3.5+7.1	1.53	2.14	4.34	---	3.08	8.00	9.34	0.65	2.14	2.89	2.99	9.80	13.30	95	3.75	A	1068	A++	7.12	8.00	397	
2.5+4.2+4.2	1.83	3.08	3.08	---	2.78	8.00	9.27	0.62	2.23	3.00	2.82	10.30	13.80	95	3.58	A	1116	A++	6.97	8.00	406	
2.5+4.2+5.0	1.71	2.87	3.42	---	2.89	8.00	9.58	0.62	2.14	3.09	2.82	9.90	14.20	95	3.73	A	1071	A++	7.10	8.00	397	
2.5+4.2+6.0	1.57	2.65	3.78	---	3.02	8.00	9.79	0.62	2.14	3.22	2.82	9.80	14.80	95	3.74	A	1068	A++	7.12	8.00	397	
2.5+4.2+7.1	1.45	2.43	4.12	---	3.29	8.00	9.89	0.58	2.13	3.29	2.70	9.80	15.20	95	3.75	A	1067	A++	7.15	8.00	396	
2.5+5.0+5.0	1.60	3.20	3.20	---	3.00	8.00	9.68	0.65	2.09	3.04	2.99	9.60	14.00	95	3.84	A	1043	A++	7.24	8.00	390	
2.5+5.0+6.0	1.48	2.96	3.56	---	3.13	8.00	9.81	0.65	2.08	3.11	2.99	9.60	14.30	95	3.85	A	1040	A++	7.26	8.00	391	
2.5+6.0+6.0	1.38	3.31	3.31	---	3.32	8.00	9.84	0.58	2.05	3.11	2.70	9.40	14.30	95	3.90	A	1025	A++	7.28	8.00	385	
3.5+3.5+3.5	2.67	2.67	2.67	---	2.72	8.00	8.93	0.58	2.20	2.75	2.65	10.10	12.60	95	3.64	A	1100	A++	6.99	8.00	401	
3.5+3.5+4.2	2.50	2.50	3.00	---	2.82	8.00	9.48	0.62	2.20	3.13	2.82	10.10	14.40	95	3.64	A	1099	A++	7.02	8.00	400	
3.5+3.5+5.0	2.33	2.33	3.33	---	2.93	8.00	9.61	0.62	2.14	3.09	2.82	9.80	14.20	95	3.74	A	1068	A++	7.12	8.00	397	
3.5+3.5+6.0	2.15	2.15	3.69	---	3.06	8.00	9.37	0.65	2.13	2.89	2.99	9.80	13.30	95	3.75	A	1065	A++	7.16	8.00	396	
3.5+3.5+7.1	1.99	1.99	4.03	---	3.30	8.00	9.84	0.58	2.10	3.23	2.70	9.70	14.80	95	3.81	A	1051	A++	7.18	8.00	390	
3.5+4.2+4.2	2.35	2.82	2.82	---	2.91	8.00	9.41	0.62	2.20	3.												

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
4MXM80N2V1B9	4.2+4.2+6.0	2.33	2.33	3.33	---	3.30	8.00	9.85	0.58	2.10	3.23	2.70	9.70	14.90	95	3.81	A	1050	A++	7.18	8.00	391
	4.2+5.0+5.0	2.37	2.82	2.82	---	3.32	8.00	9.83	0.58	2.05	3.11	2.70	9.40	14.30	95	3.90	A	1026	A++	7.28	8.00	385
	1.5+1.5+1.5+1.5	2.00	2.00	2.00	---	2.15	6.00	6.76	0.49	1.27	1.52	2.23	5.90	7.10	95	4.73	A	634	A++	7.92	6.00	267
	1.5+1.5+1.5+2.0	2.17	2.17	2.17	---	2.20	6.50	7.16	0.49	1.44	1.67	2.23	6.70	7.70	95	4.50	A	722	A++	8.14	6.50	284
	1.5+1.5+1.5+2.5	2.33	2.33	2.33	---	2.25	7.00	7.43	0.49	1.53	1.78	2.23	7.00	8.20	95	4.59	A	763	A+++	8.50	7.00	288
	1.5+1.5+1.5+3.5	2.47	2.47	2.47	---	2.39	7.40	8.09	0.52	1.77	2.06	2.36	8.10	9.50	95	4.19	A	883	A++	8.09	7.40	322
	1.5+1.5+1.5+4.2	2.67	2.67	2.67	---	2.48	8.00	8.46	0.52	2.03	2.23	2.36	9.40	10.30	95	3.94	A	1016	A++	7.64	8.00	370
	1.5+1.5+1.5+5.0	2.67	2.67	2.67	---	2.58	8.00	8.82	0.55	1.99	2.36	2.53	9.10	10.90	95	4.03	A	993	A++	7.41	8.00	382
	1.5+1.5+1.5+6.0	2.67	2.67	2.67	---	2.72	8.00	9.19	0.56	1.98	2.55	2.57	9.10	11.70	95	4.04	A	991	A++	7.44	8.00	381
	1.5+1.5+1.5+7.1	2.67	2.67	2.67	---	2.87	8.00	9.53	0.59	1.98	2.74	2.69	9.10	12.60	95	4.04	A	990	A++	7.45	8.00	381
	1.5+1.5+2.0+2.0	2.10	2.10	2.80	---	2.25	7.00	7.55	0.49	1.53	1.83	2.23	7.00	8.50	95	4.59	A	763	A+++	8.50	7.00	288
	1.5+1.5+2.0+2.5	2.22	2.22	2.96	---	2.32	7.40	7.82	0.52	1.77	1.94	2.36	8.20	9.00	95	4.18	A	886	A++	8.09	7.40	322
	1.5+1.5+2.0+3.5	1.41	1.41	1.88	3.29	2.46	8.00	8.34	0.52	2.03	2.17	2.36	9.40	10.00	95	3.93	A	1017	A++	7.76	8.00	365
	1.5+1.5+2.0+4.2	1.30	1.30	1.74	3.65	2.54	8.00	8.70	0.55	2.03	2.35	2.53	9.40	10.90	95	3.94	A	1016	A++	7.58	8.00	374
	1.5+1.5+2.0+5.0	1.20	1.20	1.60	4.00	2.65	8.00	9.05	0.55	1.99	2.48	2.53	9.10	11.40	95	4.03	A	993	A++	7.41	8.00	382
	1.5+1.5+2.0+6.0	1.09	1.09	1.45	4.36	2.79	8.00	9.41	0.59	1.98	2.67	2.69	9.10	12.30	95	4.04	A	991	A++	7.44	8.00	381
	1.5+1.5+2.0+7.1	0.99	0.99	1.32	4.69	2.94	8.00	9.64	0.63	1.98	2.80	2.86	9.10	12.90	95	4.04	A	990	A++	7.45	8.00	381
	1.5+1.5+2.5+2.5	1.39	1.39	2.31	2.31	2.39	7.40	8.07	0.52	1.77	2.06	2.36	8.20	9.50	95	4.18	A	885	A++	7.41	7.40	351
	1.5+1.5+2.5+3.5	1.33	1.33	2.22	3.11	2.52	8.00	8.58	0.55	2.03	2.29	2.53	9.30	10.60	95	3.94	A	1016	A++	7.33	8.00	386
	1.5+1.5+2.5+4.2	1.24	1.24	2.06	3.46	2.61	8.00	8.93	0.55	2.03	2.47	2.53	9.30	11.40	95	3.94	A	1015	A++	7.33	8.00	386
	1.5+1.5+2.5+5.0	1.14	1.14	1.90	3.81	2.72	8.00	9.17	0.59	1.98	2.55	2.69	9.10	11.70	95	4.03	A	992	A++	7.41	8.00	382
	1.5+1.5+2.5+6.0	1.04	1.04	1.74	4.17	2.86	8.00	9.53	0.59	1.98	2.74	2.69	9.10	12.60	95	4.04	A	990	A++	7.45	8.00	381
	1.5+1.5+2.5+7.1	0.95	0.95	1.59	4.51	3.01	8.00	9.75	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	1.5+1.5+3.5+3.5	1.20	1.20	2.80	2.80	2.65	8.00	9.07	0.55	2.00	2.54	2.53	9.20	11.70	95	4.00	A	1001	A++	7.36	8.00	381
	1.5+1.5+3.5+4.2	1.12	1.12	2.62	3.14	2.75	8.00	9.30	0.59	2.00	2.66	2.69	9.20	12.30	95	4.00	A	1000	A++	7.36	8.00	381
	1.5+1.5+3.5+5.0	1.04	1.04	2.43	3.48	2.86	8.00	9.54	0.59	1.98	2.74	2.69	9.10	12.60	95	4.04	A	990	A++	7.45	8.00	381
	1.5+1.5+3.5+6.0	0.96	0.96	2.24	3.84	3.00	8.00	9.67	0.63	1.95	2.81	2.86	9.00	12.90	95	4.10	A	976	A++	7.47	8.00	375
	1.5+1.5+3.5+7.1	0.88	0.88	2.06	4.18	3.15	8.00	9.78	0.66	1.95	2.87	3.03	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375
	1.5+1.5+4.2+4.2	1.05	1.05	2.95	2.95	2.84	8.00	9.52	0.59	2.00	2.79	2.69	9.20	12.90	95	4.00	A	999	A++	7.36	8.00	381
	1.5+1.5+4.2+5.0	0.98	0.98	2.75	3.28	2.95	8.00	9.65	0.63	1.98	2.81	2.86	9.10	12.90	95	4.04	A	989	A++	7.45	8.00	381
	1.5+1.5+4.2+6.0	0.91	0.91	2.55	3.64	3.09	8.00	9.78	0.63	1.95	2.87	2.86	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375
	1.5+1.5+4.2+7.1	0.84	0.84	2.35	3.97	3.38	8.00	9.79	0.57	1.95	2.87	2.70	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375
	1.5+1.5+5.0+5.0	0.92	0.92	3.08	3.08	3.06	8.00	9.77	0.63	1.94	2.82	2.86	8.90	13.00	95	4.13	A	969	A++	7.52	8.00	376
	1.5+1.5+5.0+6.0	0.86	0.86	2.86	3.43	3.20	8.00	9.78	0.66	1.93	2.82	3.03	8.90	13.00	95	4.13	A	967	A++	7.53	8.00	376
	1.5+2.0+2.0+2.0	1.48	1.97	1.97	1.97	2.32	7.40	7.81	0.52	1.77	1.94	2.36	8.20	9.00	95	4.17	A	887	A++	7.40	7.40	351
	1.5+2.0+2.0+2.5	1.39	1.85	1.85	2.31	2.39	7.40	8.07	0.52	1.77	2.06	2.36	8.20	9.50	95	4.18	A	886	A++	7.41	7.40	351
	1.5+2.0+2.0+3.5	1.33	1.78	1.78	3.11	2.52	8.00	8.57	0.55	2.03	2.29	2.53	9.40	10.60	95	3.93	A	1017	A++	7.33	8.00	386
	1.5+2.0+2.0+4.2	1.24	1.65	1.65	3.46	2.61	8.00	8.92	0.55	2.03	2.47	2.53	9.40	11.40	95	3.94	A	1016	A++	7.33	8.00	386
	1.5+2.0+2.0+5.0	1.14	1.52	1.52	3.81	2.72	8.00	9.17	0.59	1.99	2.54	2.69	9.10	11.70	95	4.03	A	993	A++	7.41	8.00	382
	1.5+2.0+2.0+6.0	1.04	1.39	1.39	4.17	2.86	8.00	9.52	0.59	1.98	2.74	2.69	9.10	12.60	95	4.04	A	991	A++	7.44	8.00	381
	1.5+2.0+2.0+7.1	0.95	1.27	1.27	4.51	3.01	8.00	9.74	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	1.5+2.0+2.5+2.5	1.41	1.88	2.35	2.35	2.46	8.00	8.32	0.52	2.04	2.17	2.36	9.40	10.00	95	3.93	A	1019	A++	7.31	8.00	386
	1.5+2.0+2.5+3.5	1.26	1.68	2.11	2.95	2.58	8.00	8.81	0.55	2.03	2.41	2.53	9.30	11.10	95	3.94	A	1016	A++	7.33	8.00	386
	1.5+2.0+2.5+4.2	1.18	1.57	1.96	3.29	2.68	8.00	9.15	0.59	2.03	2.60	2.69	9.30	11.90	95	3.94	A	1015	A++	7.33	8.00	386
	1.5+2.0+2.5+5.0	1.09	1.45	1.82	3.64	2.79	8.00	9.40	0.59	1.98	2.67	2.69	9.10	12.30	95	4.03	A	992	A++	7.41	8.00	382
	1.5+2.0+2.5+6.0	1.00	1.33	1.67	4.00	2.93	8.00	9.64	0.63	1.98	2.80	2.86	9.10	12.90	95	4.04	A	990	A++	7.45	8.00	381
	1.5+2.0+2.5+7.1	0.92	1.22	1.53	4.34	3.08	8.00	9.75	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	1.5+2.0+3.5+3.5	1.14	1.52	2.67	2.67	2.72	8.00	9.18	0.59	2.00	2.60	2.69	9.20	12.00	95	4.00	A	1001	A++	7.36	8.00	381
1.5+2.0+3.5+4.2	1.07	1.43	2.50	3.00	2.82	8.00	9.40	0.59	2.00	2.73	2.69	9.20	12.50	95	4.00	A	1000	A++	7.36	8.00	381	
1.5+2.0+3.5+5.0	1.00	1.33	2.33	3.33	2.93	8.00	9.64	0.63	1.98	2.81	2.86	9.10	12.90	95	4.04	A	990	A++	7.45	8.00	381	
1.5+2.0+3.5+6.0	0.92	1.23	2.15	3.69	3.06	8.00	9.77	0.63	1.95	2.87	2.86	9.00	13.20	95	4.10	A	976	A++	7.47	8.00	375	
1.5+2.0+3.5+7.1	0.85	1.13	1.99	4.03	3.38	8.00	9.78	0.57	1.95	2.87	2.70	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375	
1.5+2.0+4.2+4.2	1.01	1.34	2.82	2.82	2.91	8.00	9.62	0.62	2.00	2.86	2.82	9.20	13.20	95	4.00	A	999	A++	7.36	8.00	381	
1.5+2.0+4.2+5.0	0.94	1.26	2.65	3.15	3.02	8.00	9.76	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	989	A++	7.45	8.00	381	
1.5+2.0+4.2+6.0	0.88	1.17	2.45	3.50	3.16	8.00	9.78	0.66	1.95	2.87	3.03	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375	
1.5+2.0+5.0+5.0	0.89	1.19	2.96	2.96	3.13	8.00	9.77	0.65	1.94	2.82	2.99	8.90	13.00	95	4.13	A	969	A++	7.52	8.00	376	
1.5+2.0+5.0+6.0	0.83	1.10	2.76	3.31	3.40	8.00	9.78	0.57	1.93	2.82	2.70	8.90	13.00	95	4.13	A	967	A++	7.53	8.00	376	
1.5+2.5+2.5+2.5	1.33	2.22	2.22	2.22	2.52	8.00	8.56	0.55	2.04	2.29	2.53	9.40	10.60	95	3.93	A	1018	A++	7.32	8.00	386	
1.5+2.5+2.5+3.5	1.20	2.00	2.00	2.80	2.65	8.00	9.05	0.55	2.03	2.54	2.53	9.30	11.70									

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
4MXM80N2V1B9	1.5+2.5+3.5+6.0	0.89	1.48	2.07	3.56	3.13	8.00	9.78	0.66	1.95	2.87	3.03	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375
	1.5+2.5+4.2+4.2	0.97	1.61	2.71	2.71	2.98	8.00	9.63	0.62	2.00	2.86	2.82	9.20	13.20	95	4.01	A	999	A++	7.37	8.00	381
	1.5+2.5+4.2+5.0	0.91	1.52	2.55	3.03	3.09	8.00	9.77	0.65	1.98	2.87	2.99	9.10	13.20	95	4.05	A	989	A++	7.46	8.00	381
	1.5+2.5+4.2+6.0	0.85	1.41	2.37	3.38	3.38	8.00	9.79	0.57	1.95	2.87	2.70	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375
	1.5+2.5+5.0+5.0	0.86	1.43	2.86	2.86	3.20	8.00	9.77	0.65	1.94	2.82	2.99	8.90	13.00	95	4.13	A	968	A++	7.53	8.00	376
	1.5+3.5+3.5+3.5	1.00	2.33	2.33	2.33	2.93	8.00	9.65	0.62	1.99	2.86	2.82	9.20	13.20	95	4.01	A	997	A++	7.38	8.00	381
	1.5+3.5+3.5+4.2	0.94	2.20	2.20	2.65	3.02	8.00	9.76	0.62	1.99	2.93	2.82	9.20	13.50	95	4.01	A	997	A++	7.38	8.00	381
	1.5+3.5+3.5+5.0	0.89	2.07	2.07	2.96	3.13	8.00	9.79	0.65	1.95	2.87	2.99	9.00	13.20	95	4.10	A	975	A++	7.48	8.00	375
	1.5+3.5+3.5+6.0	0.83	1.93	1.93	3.31	3.39	8.00	9.81	0.57	1.95	2.88	2.70	9.00	13.20	95	4.11	A	973	A++	7.49	8.00	375
	1.5+3.5+4.2+4.2	0.90	2.09	2.51	2.51	3.12	8.00	9.77	0.65	1.99	2.93	2.99	9.20	13.50	95	4.02	A	996	A++	7.39	8.00	381
	1.5+3.5+4.2+5.0	0.85	1.97	2.37	2.82	3.38	8.00	9.80	0.57	1.95	2.88	2.70	9.00	13.20	95	4.11	A	974	A++	7.48	8.00	375
	1.5+4.2+4.2+4.2	0.85	2.38	2.38	2.38	3.36	8.00	9.78	0.57	1.99	2.93	2.70	9.20	13.50	95	4.02	A	996	A++	7.39	8.00	381
	2.0+2.0+2.0+2.0	1.85	1.85	1.85	1.85	2.39	7.40	8.18	0.52	1.77	2.11	2.36	8.20	9.80	95	4.17	A	887	A++	7.40	7.40	351
	2.0+2.0+2.0+2.5	1.88	1.88	1.88	2.35	2.46	8.00	8.42	0.52	2.04	2.23	2.36	9.40	10.30	95	3.92	A	1020	A++	7.31	8.00	386
	2.0+2.0+2.0+3.5	1.68	1.68	1.68	2.95	2.58	8.00	8.80	0.55	2.03	2.41	2.53	9.40	11.10	95	3.93	A	1017	A++	7.33	8.00	386
	2.0+2.0+2.0+4.2	1.57	1.57	1.57	3.29	2.68	8.00	9.14	0.59	2.02	2.60	2.69	9.40	11.90	95	3.94	A	1016	A++	7.33	8.00	386
	2.0+2.0+2.0+5.0	1.45	1.45	1.45	3.64	2.79	8.00	9.39	0.59	1.99	2.67	2.69	9.10	12.30	95	4.03	A	993	A++	7.41	8.00	382
	2.0+2.0+2.0+6.0	1.33	1.33	1.33	4.00	2.93	8.00	9.63	0.63	1.98	2.80	2.86	9.10	12.90	95	4.04	A	991	A++	7.44	8.00	381
	2.0+2.0+2.0+7.1	1.22	1.22	1.22	4.34	3.08	8.00	9.74	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	2.0+2.0+2.5+2.5	1.73	1.73	2.17	2.17	2.52	7.80	8.67	0.55	1.94	2.35	2.53	8.90	10.80	95	4.03	A	969	A++	7.34	7.80	373
	2.0+2.0+2.5+3.5	1.60	1.60	2.00	2.80	2.65	8.00	9.04	0.55	2.03	2.54	2.53	9.30	11.70	95	3.94	A	1016	A++	7.33	8.00	386
	2.0+2.0+2.5+4.2	1.50	1.50	1.87	3.14	2.75	8.00	9.26	0.59	2.03	2.66	2.69	9.30	12.30	95	3.94	A	1015	A++	7.33	8.00	386
	2.0+2.0+2.5+5.0	1.39	1.39	1.74	3.48	2.86	8.00	9.51	0.59	1.98	2.74	2.69	9.10	12.60	95	4.03	A	992	A++	7.41	8.00	382
	2.0+2.0+2.5+6.0	1.28	1.28	1.60	3.84	3.00	8.00	9.74	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	2.0+2.0+2.5+7.1	1.18	1.18	1.47	4.18	3.15	8.00	9.86	0.66	1.98	2.94	3.03	9.10	13.50	95	4.04	A	990	A++	7.45	8.00	381
	2.0+2.0+3.5+3.5	1.45	1.45	2.55	2.55	2.79	8.00	9.18	0.59	2.00	2.60	2.69	9.20	12.00	95	4.00	A	1001	A++	7.36	8.00	381
	2.0+2.0+3.5+4.2	1.37	1.37	2.39	2.87	2.89	8.00	9.51	0.62	2.00	2.79	2.82	9.20	12.90	95	4.00	A	1000	A++	7.36	8.00	381
	2.0+2.0+3.5+5.0	1.28	1.28	2.24	3.20	3.00	8.00	9.75	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	2.0+2.0+3.5+6.0	1.19	1.19	2.07	3.56	3.13	8.00	9.77	0.66	1.95	2.87	3.03	9.00	13.20	95	4.10	A	976	A++	7.47	8.00	375
	2.0+2.0+4.2+4.2	1.29	1.29	2.71	2.71	2.98	8.00	9.72	0.62	2.00	2.93	2.82	9.20	13.50	95	4.00	A	999	A++	7.36	8.00	381
	2.0+2.0+4.2+5.0	1.21	1.21	2.55	3.03	3.09	8.00	9.76	0.65	1.98	2.87	2.99	9.10	13.20	95	4.04	A	989	A++	7.45	8.00	381
	2.0+2.0+4.2+6.0	1.13	1.13	2.37	3.38	3.38	8.00	9.88	0.57	1.95	2.94	2.70	9.00	13.60	95	4.10	A	975	A++	7.48	8.00	375
	2.0+2.0+5.0+5.0	1.14	1.14	2.86	2.86	3.20	8.00	9.87	0.65	1.94	2.88	2.99	8.90	13.30	95	4.13	A	969	A++	7.52	8.00	376
	2.0+2.5+2.5+2.5	1.68	2.11	2.11	2.11	2.58	8.00	8.90	0.55	2.04	2.47	2.53	9.40	11.40	95	3.93	A	1018	A++	7.32	8.00	386
	2.0+2.5+2.5+3.5	1.52	1.90	1.90	2.67	2.72	8.00	9.27	0.59	2.03	2.66	2.69	9.30	12.30	95	3.94	A	1015	A++	7.34	8.00	387
	2.0+2.5+2.5+4.2	1.43	1.79	1.79	3.00	2.82	8.00	9.49	0.59	2.03	2.79	2.69	9.30	12.90	95	3.94	A	1014	A++	7.34	8.00	387
	2.0+2.5+2.5+5.0	1.33	1.67	1.67	3.33	2.93	8.00	9.62	0.63	1.98	2.80	2.86	9.10	12.90	95	4.03	A	991	A++	7.44	8.00	381
	2.0+2.5+2.5+6.0	1.23	1.54	1.54	3.69	3.06	8.00	9.75	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	990	A++	7.45	8.00	381
	2.0+2.5+2.5+7.1	1.13	1.42	1.42	4.03	3.38	8.00	9.87	0.57	1.98	2.94	2.70	9.10	13.50	95	4.04	A	989	A++	7.46	8.00	381
	2.0+2.5+3.5+3.5	1.39	1.74	2.43	2.43	2.86	8.00	9.41	0.62	2.00	2.73	2.82	9.20	12.50	95	4.00	A	1000	A++	7.36	8.00	381
	2.0+2.5+3.5+4.2	1.31	1.64	2.30	2.75	2.95	8.00	9.73	0.62	2.00	2.93	2.82	9.20	13.50	95	4.00	A	999	A++	7.37	8.00	381
	2.0+2.5+3.5+5.0	1.23	1.54	2.15	3.08	3.06	8.00	9.76	0.65	1.98	2.87	2.99	9.10	13.20	95	4.04	A	989	A++	7.46	8.00	381
	2.0+2.5+3.5+6.0	1.14	1.43	2.00	3.43	3.20	8.00	9.89	0.66	1.95	2.94	3.03	9.00	13.60	95	4.10	A	975	A++	7.48	8.00	375
	2.0+2.5+4.2+4.2	1.24	1.55	2.60	2.60	3.05	8.00	9.73	0.65	2.00	2.93	2.99	9.20	13.50	95	4.01	A	999	A++	7.37	8.00	381
	2.0+2.5+4.2+5.0	1.17	1.46	2.45	2.92	3.16	8.00	9.87	0.65	1.98	2.94	2.99	9.10	13.50	95	4.05	A	989	A++	7.46	8.00	381
	2.0+2.5+5.0+5.0	1.10	1.38	2.76	2.76	3.40	8.00	9.88	0.57	1.94	2.88	2.70	8.90	13.30	95	4.13	A	968	A++	7.53	8.00	376
	2.0+3.5+3.5+3.5	1.28	2.24	2.24	2.24	3.00	8.00	9.44	0.62	1.99	2.73	2.82	9.20	12.60	95	4.01	A	997	A++	7.38	8.00	381
	2.0+3.5+3.5+4.2	1.21	2.12	2.12	2.55	3.09	8.00	9.76	0.65	1.99	2.93	2.99	9.20	13.50	95	4.01	A	997	A++	7.38	8.00	381
	2.0+3.5+3.5+5.0	1.14	2.00	2.00	2.86	3.20	8.00	9.89	0.65	1.95	2.94	2.99	9.00	13.60	95	4.10	A	975	A++	7.48	8.00	375
	2.0+3.5+4.2+4.2	1.15	2.01	2.42	2.42	3.36	8.00	9.87	0.57	1.99	3.00	2.70	9.20	13.80	95	4.02	A	996	A++	7.39	8.00	381
2.5+2.5+2.5+2.5	2.00	2.00	2.00	2.00	2.65	8.00	9.03	0.55	2.03	2.53	2.53	9.40	11.70	95	3.93	A	1017	A++	7.33	8.00	386	
2.5+2.5+2.5+3.5	1.82	1.82	1.82	2.55	2.79	8.00	9.17	0.59	2.03	2.60	2.69	9.30	11.90	95	3.94	A	1014	A++	7.34	8.00	387	
2.5+2.5+2.5+4.2	1.71	1.71	1.71	2.87	2.89	8.00	9.60	0.62	2.00	2.86	2.82	9.20	13.10	95	4.00	A	1001	A++	7.36	8.00	381	
2.5+2.5+2.5+5.0	1.60	1.60	1.60	3.20	3.00	8.00	9.74	0.63	1.98	2.87	2.86	9.10	13.20	95	4.04	A	991	A++	7.45	8.00	381	
2.5+2.5+2.5+6.0	1.48	1.48	1.48	3.56	3.13	8.00	9.87	0.66	1.98	2.94	3.03	9.10	13.50	95	4.04	A	989	A++	7.46	8.00	381	
2.5+2.5+3.5+3.5	1.67	1.67	2.33	2.33	2.93	8.00	9.31	0.62	2.00	2.67	2.82	9.20	12.30	95	4.00	A	999	A++	7.37	8.00	381	
2.5+2.5+3.5+4.2	1.57	1.57	2.20	2.65	3.02	8.00	9.74	0.62	2.00	2.93	2.82	9.20	13.50	95	4.01	A	998	A++	7.37	8.00	381	
2.5+2.5+3.5+5.0	1.48	1.48	2.07	2.96	3.13	8.00	9.87	0.65	1.95	2.94	2.99	9.00	13.50	95	4.10	A	976	A++	7.47	8.00	375	
2.5+2.5+3.5+6.0	1.38	1.38	1.93	3.31	3.38	8.00																

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
4MXM80N2V1B9	1.5	1.88	---	---	---	1.25	1.88	4.10	0.29	0.51	1.23	1.33	2.34	5.63	95	---	---	---	---	---	---	---
	2.0	2.46	---	---	---	1.28	2.46	4.26	0.30	0.66	1.29	1.38	3.01	5.90	95	---	---	---	---	---	---	---
	2.5	3.08	---	---	---	1.33	3.08	4.73	0.32	0.86	1.38	1.46	3.95	6.32	95	---	---	---	---	---	---	---
	3.5	4.31	---	---	---	1.45	4.31	5.31	0.33	1.39	1.68	1.51	6.37	7.68	95	---	---	---	---	---	---	---
	4.2	---	5.18	---	---	1.49	5.18	6.16	0.34	1.63	1.90	1.55	7.45	8.70	95	---	---	---	---	---	---	---
	5.0	---	6.15	---	---	1.86	6.15	7.40	0.43	1.74	2.77	1.95	7.99	12.68	95	---	---	---	---	---	---	---
	6.0	---	7.38	---	---	2.15	7.38	9.00	0.53	2.15	3.11	2.44	9.83	14.23	95	---	---	---	---	---	---	---
	7.1	---	8.74	---	---	2.45	8.74	9.36	0.57	2.71	3.45	2.62	12.43	15.79	95	---	---	---	---	---	---	---
	1.5+1.5	1.85	1.85	---	---	1.45	3.70	7.54	0.41	0.69	7.54	1.89	3.2	8.8	95	5.34	A	A+	4.20	3.27	1090	0.44
	1.5+2.0	1.84	2.46	---	---	1.51	4.30	7.94	0.41	0.85	7.94	1.89	3.9	9.6	95	5.06	A	A+	4.20	3.27	1089	0.44
	1.5+2.5	1.84	3.06	---	---	1.65	4.90	8.08	0.45	1.02	8.08	2.06	4.7	9.8	95	4.82	A	A+	4.21	3.27	1087	0.19
	1.5+3.5	1.83	4.27	---	---	1.94	6.10	8.61	0.52	1.40	8.61	2.37	6.4	10.9	95	4.36	A	A+	4.23	3.57	1182	0.29
	1.5+4.2	1.84	5.16	---	---	2.14	7.00	9.02	0.55	1.71	9.02	2.54	7.9	11.5	95	4.10	A	A+	4.26	3.57	1174	0.28
	1.5+5.0	1.85	6.15	---	---	2.38	8.00	10.50	0.50	1.98	10.50	2.28	9.1	14	95	4.03	A	A+	4.30	4.27	1390	0.62
	1.5+6.0	1.80	7.20	---	---	2.68	9.00	10.63	0.44	2.38	10.63	2.10	10.9	14.2	95	3.78	A	A+	4.31	4.27	1387	0.56
	1.5+7.1	1.67	7.93	---	---	3.01	9.60	10.77	0.50	2.62	10.77	2.40	12	14.4	95	3.66	A	A+	4.32	4.27	1384	0.56
	2.0+2.0	2.45	2.45	---	---	1.65	4.90	8.08	0.32	1.02	8.08	1.46	4.7	9.8	95	4.82	A	A+	4.21	3.27	1087	0.19
	2.0+2.5	2.44	3.06	---	---	1.80	5.50	8.22	0.35	1.20	8.22	1.59	5.5	10.1	95	4.60	A	A+	4.22	3.27	1086	0.19
	2.0+3.5	2.44	4.26	---	---	2.09	6.70	8.74	0.40	1.60	8.74	1.85	7.4	11.2	95	4.18	A	A+	4.23	3.57	1181	0.29
	2.0+4.2	2.45	5.15	---	---	2.28	7.60	9.15	0.44	1.93	9.15	2.02	8.9	11.8	95	3.94	A	A+	4.26	3.57	1172	0.28
	2.0+5.0	2.43	6.07	---	---	2.68	8.50	10.63	0.44	2.16	10.63	2.10	9.9	14.2	95	3.93	A	A+	4.31	4.27	1388	0.61
	2.0+6.0	2.33	6.98	---	---	2.84	9.30	10.89	0.47	2.50	10.89	2.20	11.5	14.7	95	3.73	A	A+	4.32	4.27	1385	0.56
	2.0+7.1	2.11	7.49	---	---	3.17	9.60	11.02	0.54	2.61	11.02	2.50	12	14.9	95	3.68	A	A+	4.33	4.27	1382	0.56
	2.5+2.5	3.05	3.05	---	---	1.94	6.10	8.61	0.39	1.39	8.61	1.76	6.4	10.9	95	4.39	A	A+	4.22	3.27	1084	0.18
	2.5+3.5	3.04	4.26	---	---	2.23	7.30	9.13	0.52	1.84	9.13	2.37	8.5	12	95	3.96	A	A+	4.24	3.57	1179	0.29
	2.5+4.2	3.06	5.14	---	---	2.44	8.20	9.41	0.54	2.16	9.41	2.45	9.9	12.3	95	3.79	A	A+	4.27	3.57	1170	0.28
	2.5+5.0	3.00	6.00	---	---	2.68	9.00	10.76	0.44	2.37	10.76	2.10	10.9	14.5	95	3.79	A	A+	4.31	4.27	1385	0.61
	2.5+6.0	2.82	6.78	---	---	3.00	9.60	11.02	0.50	2.61	11.02	2.40	12	15	95	3.67	A	A+	4.32	4.27	1383	0.61
	2.5+7.1	2.50	7.10	---	---	3.33	9.60	10.91	0.57	2.60	10.91	2.70	11.9	14.6	95	3.70	A	A+	4.33	4.27	1380	0.56
	3.5+3.5	4.25	4.25	---	---	2.52	8.50	9.63	0.55	2.37	9.63	2.54	10.9	13.1	95	3.59	B	A+	4.22	4.27	1417	0.61
	3.5+4.2	4.09	4.91	---	---	2.72	9.00	10.28	0.45	2.53	10.28	2.20	11.6	14.4	95	3.56	B	A+	4.22	4.27	1416	0.59
	3.5+5.0	3.91	5.59	---	---	3.01	9.50	11.01	0.50	2.60	11.01	2.40	12	15.1	95	3.65	A	A+	4.21	4.97	1655	0.93
	3.5+6.0	3.54	6.06	---	---	3.33	9.60	11.14	0.57	2.61	11.14	2.70	12	15.3	95	3.67	A	A+	4.22	4.97	1651	0.88
	3.5+7.1	3.17	6.43	---	---	3.65	9.60	11.15	0.64	2.60	11.15	3.00	11.9	15.2	95	3.70	A	A+	4.23	4.97	1646	0.88
	4.2+4.2	4.75	4.75	---	---	3.03	9.50	10.07	0.51	2.63	10.07	2.40	12.1	13.5	95	3.61	A	A+	4.26	4.27	1404	0.63
	4.2+5.0	4.38	5.22	---	---	3.16	9.60	11.05	0.53	2.57	11.05	2.50	11.8	14.7	95	3.74	A	A+	4.25	4.97	1639	0.92
	4.2+6.0	3.95	5.65	---	---	3.48	9.60	11.06	0.60	2.55	11.06	2.80	11.7	14.6	95	3.76	A	A+	4.25	4.97	1635	0.86
	4.2+7.1	3.57	6.03	---	---	3.80	9.60	11.07	0.66	2.54	11.07	3.10	11.7	14.6	95	3.78	A	A+	4.27	4.97	1631	0.86
	5.0+5.0	4.80	4.80	---	---	3.45	9.60	11.15	0.58	2.42	11.15	2.70	11.1	14	95	3.96	A	A+	4.19	6.23	2084	1.57
	5.0+6.0	4.36	5.24	---	---	3.77	9.60	11.15	0.64	2.41	11.15	3.00	11.1	13.9	95	3.98	A	A+	4.20	6.23	2078	1.57
	5.0+7.1	3.97	5.63	---	---	3.93	9.60	11.16	0.67	2.40	11.16	3.20	11	13.8	95	4.01	A	A+	4.21	6.23	2072	1.56
	6.0+6.0	4.80	4.80	---	---	3.93	9.60	11.16	0.67	2.40	11.16	3.20	11	13.8	95	4.00	A	A+	4.21	6.23	2073	1.57
	6.0+7.1	4.40	5.20	---	---	4.25	9.60	11.17	0.74	2.38	11.17	3.40	11	13.7	95	4.03	A	A+	4.22	6.23	2067	1.56
	7.1+7.1	4.80	4.80	---	---	4.56	9.60	11.31	0.80	2.37	11.31	3.80	10.9	14	95	4.05	A	A+	4.23	6.23	2061	1.56
	1.5+1.5+1.5	1.83	1.83	0.58	---	1.80	5.50	10.07	0.40	1.08	10.07	1.85	5	12.1	95	5.10	A	A+	4.36	4.57	1467	0.69
1.5+1.5+2.0	1.83	1.83	2.71	---	1.94	6.10	10.21	0.41	1.24	10.21	1.89	5.7	12.3	95	4.92	A	A+	4.37	4.57	1465	0.69	
1.5+1.5+2.5	1.83	1.83	3.35	---	2.09	6.70	10.21	0.43	1.41	10.21	1.98	6.5	12.3	95	4.74	A	A+	4.37	4.57	1463	0.69	
1.5+1.5+3.5	1.85	1.85	5.09	---	2.38	8.00	10.34	0.47	1.84	10.34	2.15	8.5	12.5	95	4.35	A	A+	4.28	5.27	1723	1.00	
1.5+1.5+4.2	1.81	1.81	5.62	---	2.63	8.70	10.37	0.43	2.05	10.37	2.00	9.4	12.3	95	4.24	A	A+	4.32	5.27	1708	0.99	
1.5+1.5+5.0	1.74	1.74	6.46	---	2.94	9.30	10.56	0.47	2.16	10.56	2.20	9.9	11.9	95	4.30	A	A+	4.31	6.23	2025	1.53	
1.5+1.5+6.0	1.58	1.58	7.13	---	3.10	9.50	11.23	0.50	2.24	11.23	2.40	10.3	13.1	95	4.25	A	A+	4.32	6.23	2021	1.53	
1.5+1.5+7.1	1.43	1.43	7.57	---	3.42	9.60	11.23	0.56	2.25	11.23	2.60	10.3	13.1	95	4.27	A	A+	4.33	6.23	2015	1.52	
1.5+2.0+2.0	1.83	2.44	1.33	---	2.09	6.70	10.34	0.43	1.41	10.34	1.98	6.5	12.5	95	4.74	A	A+	4.37	4.57	1463	0.69	
1.5+2.0+2.5	1.83	2.43	3.32	---	2.23	7.30	10.48	0.45	1.61	10.48	2.06	7.4	12.7	95	4.54	A	A+	4.38	4.57	1461	0.69	
1.5+2.0+3.5	1.82	2.43	4.96	---	2.64	8.50	10.61	0.43	2.02	10.61	2.00	9.3	13	95	4.21	A	A+	4.29	5.27	1720	1.00	
1.5+2.0+4.2	1.75	2.34	5.40	---	2.80	9.00	10.50	0.46	2.16	10.50	2.20	9.9	12.5	95	4.18	A	A+	4.33	5.27	1705	0.98	
1.5+2.0+5.0	1.69	2.26	6.23	---	3.10	9.60	10.96	0.50	2.28	10.96	2.40	10.5	12.6	95	4.21	A	A+	4.31	6.23	2022	1.53	
1.5+2.0+6.0	1.52	2.02	6.78	---	3.26	9.60	11.23	0.53	2.25	11.23	2.50	10.4	13.1	95	4.26	A	A+	4.32	6.23	2017	1.53	
1.5+2.0+7.1	1.36	1.81	7.17	---	3.58	9.60	11.24	0.59	2.24	11.24	2.80	10.3	13	95	4.28	A	A+	4.33	6.23	2012	1.52	
1.5+2.5+2.5	1.85	3.08	1.89	---	2.38	8.00	10.61	0.47	1.82	10.61	2.15	8.4	13	95	4.38	A	A+	4.39	4.57	1459	0.68	
1.5+2.5+3.5	1.80	3.00	4.85	---	2.81	9.00	10.61	0.46	2.19	10.61	2.20	10.1	13	95	4.11	A	A+	4.30	5.27	1717	0.99	
1.5+2.5+4.2	1.76	2.93	5.38	---	2.96	9.60	10.64	0.48	2.39	10.64	2.30	11	12.7	95	4.01	A	A+	4.33	5.27	1702	0.98	
1.5+2.5+5.0	1.60	2.67	5.85	---	3.10	9.60	11.10	0.50	2.25	11.10	2.40	10.4	12.9	95	4.26	A	A+	4.32	6.23	2018	1.53	
1.5+2.5+6.0	1.44	2.40	6.40	---	3.42	9.60	11.24	0.56	2.24	11.24	2.60	10.3	13									

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
4MXM80N2V1B9	1.5+3.5+5.0	1.44	3.36	5.22	---	3.42	9.60	10.97	0.56	2.25	10.97	2.70	10.4	12.6	95	4.26	A	A+	4.32	6.23	2018	1.53
	1.5+3.5+6.0	1.31	3.05	5.76	---	3.74	9.60	11.24	0.62	2.24	11.24	2.90	10.3	13.1	95	4.28	A	A+	4.33	6.23	2014	1.52
	1.5+3.5+7.1	1.19	2.78	6.20	---	4.06	9.60	11.24	0.68	2.23	11.24	3.20	10.3	13	95	4.30	A	A+	4.34	6.23	2009	1.52
	1.5+4.2+4.2	1.45	4.07	3.33	---	3.44	9.60	10.80	0.57	2.35	10.80	2.70	10.8	12.7	95	4.09	A	A+	4.25	6.23	2050	1.55
	1.5+4.2+5.0	1.35	3.77	4.85	---	3.57	9.60	11.12	0.59	2.22	11.12	2.80	10.2	12.6	95	4.33	A	A+	4.37	6.23	1998	1.51
	1.5+4.2+6.0	1.23	3.45	5.38	---	3.89	9.60	11.26	0.64	2.21	11.26	3.00	10.1	12.9	95	4.35	A	A+	4.38	6.23	1994	1.51
	1.5+4.2+7.1	1.13	3.15	5.83	---	4.21	9.60	11.26	0.70	2.20	11.26	3.30	10.1	12.8	95	4.37	A	A+	4.39	6.23	1989	1.51
	1.5+5.0+5.0	1.25	4.17	3.75	---	3.88	9.60	11.15	0.63	2.13	11.15	3.00	9.8	12.1	95	4.52	A	A+	4.46	6.23	1957	1.49
	1.5+5.0+6.0	1.15	3.84	5.01	---	4.20	9.60	11.29	0.69	2.12	11.29	3.20	9.7	12.3	95	4.53	A	A+	4.46	6.23	1954	1.49
	1.5+5.0+7.1	1.06	3.53	5.45	---	4.35	9.60	11.43	0.72	2.11	11.43	3.30	9.7	12.5	95	4.55	A	A+	4.47	6.23	1950	1.49
	1.5+6.0+6.0	1.07	4.27	4.24	---	4.35	9.60	11.56	0.72	2.11	11.56	3.30	9.7	12.8	95	4.55	A	A+	4.47	6.23	1951	1.49
	2.0+2.0+2.0	2.50	2.50	1.11	---	2.23	7.50	10.48	0.45	1.67	10.48	2.06	7.7	12.7	95	4.49	A	A+	4.38	4.57	1461	0.69
	2.0+2.0+2.5	2.46	2.46	3.33	---	2.38	8.00	10.61	0.47	1.83	10.61	2.15	8.4	13	95	4.38	A	A+	4.39	4.57	1459	0.68
	2.0+2.0+3.5	2.40	2.40	4.85	---	2.81	9.00	10.75	0.46	2.19	10.75	2.20	10.1	13.2	95	4.11	A	A+	4.29	5.37	1751	1.00
	2.0+2.0+4.2	2.29	2.29	5.26	---	2.96	9.40	10.77	0.48	2.30	10.77	2.30	10.6	13	95	4.08	A	A+	4.33	5.37	1736	1.03
	2.0+2.0+5.0	2.13	2.13	5.85	---	3.10	9.60	10.97	0.50	2.25	10.97	2.40	10.4	12.6	95	4.26	A	A+	4.32	6.23	2018	1.53
	2.0+2.0+6.0	1.92	1.92	6.40	---	3.42	9.60	11.24	0.56	2.24	11.24	2.60	10.3	13.1	95	4.28	A	A+	4.33	6.23	2014	1.52
	2.0+2.0+7.1	1.73	1.73	6.82	---	3.74	9.60	11.24	0.62	2.23	11.24	2.90	10.3	13	95	4.30	A	A+	4.34	6.23	2009	1.52
	2.0+2.5+2.5	2.43	3.04	1.91	---	2.64	8.50	10.62	0.43	2.00	10.62	2.00	9.2	12.9	95	4.24	A	A+	4.37	4.77	1528	0.78
	2.0+2.5+3.5	2.33	2.91	4.65	---	2.80	9.30	10.75	0.46	2.32	10.75	2.20	10.6	13.2	95	4.02	A	A+	4.30	5.37	1748	1.00
	2.0+2.5+4.2	2.21	2.76	5.04	---	3.12	9.60	10.78	0.51	2.38	10.78	2.40	11	12.9	95	4.03	A	A+	4.34	5.37	1733	1.03
	2.0+2.5+5.0	2.02	2.53	5.52	---	3.26	9.60	11.10	0.53	2.25	11.10	2.50	10.3	12.8	95	4.27	A	A+	4.33	6.23	2015	1.52
	2.0+2.5+6.0	1.83	2.29	6.06	---	3.58	9.60	11.24	0.59	2.24	11.24	2.80	10.3	13	95	4.29	A	A+	4.34	6.23	2010	1.52
	2.0+2.5+7.1	1.66	2.07	6.49	---	3.90	9.60	11.25	0.65	2.23	11.25	3.00	10.2	13	95	4.31	A	A+	4.35	6.23	2005	1.52
	2.0+3.5+3.5	2.13	3.73	2.90	---	3.13	9.60	10.88	0.52	2.43	10.88	2.40	11.2	13.5	95	3.94	A	A+	4.18	6.23	2089	1.58
	2.0+3.5+4.2	1.98	3.46	4.48	---	3.28	9.60	10.78	0.54	2.38	10.78	2.60	11	12.9	95	4.03	A	A+	4.22	6.23	2067	1.56
	2.0+3.5+5.0	1.83	3.20	4.95	---	3.58	9.60	11.24	0.59	2.25	11.24	2.80	10.3	13.1	95	4.27	A	A+	4.33	6.23	2015	1.52
	2.0+3.5+6.0	1.67	2.92	5.49	---	3.90	9.60	11.24	0.65	2.24	11.24	3.00	10.3	13	95	4.29	A	A+	4.34	6.23	2010	1.52
	2.0+3.5+7.1	1.52	2.67	5.93	---	4.22	9.60	11.25	0.71	2.23	11.25	3.30	10.2	13	95	4.31	A	A+	4.35	6.23	2005	1.52
	2.0+4.2+4.2	1.85	3.88	3.20	---	3.60	9.60	10.80	0.60	2.34	10.80	2.80	10.7	12.7	95	4.11	A	A+	4.26	6.23	2047	1.55
	2.0+4.2+5.0	1.71	3.60	4.62	---	3.73	9.60	10.99	0.61	2.21	10.99	2.90	10.2	12.4	95	4.35	A	A+	4.37	6.23	1994	1.51
	2.0+4.2+6.0	1.57	3.30	5.14	---	4.05	9.60	11.26	0.67	2.20	11.26	3.20	10.1	12.8	95	4.36	A	A+	4.38	6.23	1990	1.51
	2.0+4.2+7.1	1.44	3.03	5.59	---	4.37	9.60	11.26	0.74	2.19	11.26	3.40	10.1	12.8	95	4.38	A	A+	4.39	6.23	1986	1.51
	2.0+5.0+5.0	1.60	4.00	3.61	---	4.04	9.60	11.15	0.66	2.12	11.15	3.10	9.7	12.1	95	4.53	A	A+	4.46	6.23	1954	1.49
	2.0+5.0+6.0	1.48	3.69	4.80	---	4.19	9.60	11.29	0.69	2.11	11.29	3.20	9.7	12.3	95	4.54	A	A+	4.47	6.23	1951	1.49
	2.0+5.0+7.1	1.36	3.40	5.24	---	4.51	9.60	11.43	0.75	2.10	11.43	3.50	9.7	12.5	95	4.56	A	A+	4.48	6.23	1948	1.49
	2.0+6.0+6.0	1.37	4.11	4.09	---	4.51	9.60	11.56	0.75	2.11	11.56	3.50	9.7	12.7	95	4.56	A	A+	4.48	6.23	1948	1.49
	2.5+2.5+2.5	3.20	3.20	1.71	---	2.80	9.60	10.76	0.46	2.42	10.76	2.20	11.1	13.1	95	3.96	A	A+	4.38	4.77	1526	0.73
	2.5+2.5+3.5	2.82	2.82	4.48	---	2.97	9.60	11.02	0.49	2.42	11.02	2.30	11.1	13.7	95	3.96	A	A+	4.31	5.37	1745	0.99
	2.5+2.5+4.2	2.61	2.61	4.74	---	3.28	9.60	11.04	0.54	2.37	11.04	2.60	10.9	13.4	95	4.04	A	A+	4.35	5.37	1730	0.98
	2.5+2.5+5.0	2.40	2.40	5.22	---	3.42	9.60	11.11	0.56	2.24	11.11	2.60	10.3	12.8	95	4.29	A	A+	4.34	6.23	2011	1.52
	2.5+2.5+6.0	2.18	2.18	5.76	---	3.74	9.60	11.24	0.62	2.23	11.24	2.90	10.3	13	95	4.31	A	A+	4.35	6.23	2007	1.52
2.5+2.5+7.1	1.98	1.98	6.20	---	4.06	9.60	11.25	0.68	2.22	11.25	3.20	10.2	12.9	95	4.33	A	A+	4.36	6.23	2002	1.52	
2.5+3.5+3.5	2.53	3.54	2.78	---	3.29	9.60	11.15	0.55	2.42	11.15	2.60	11.1	14	95	3.96	A	A+	4.18	6.23	2084	1.57	
2.5+3.5+4.2	2.35	3.29	4.24	---	3.44	9.60	11.04	0.57	2.37	11.04	2.70	10.9	13.4	95	4.04	A	A+	4.23	6.23	2063	1.56	
2.5+3.5+5.0	2.18	3.05	4.71	---	3.74	9.60	11.11	0.62	2.24	11.11	2.90	10.3	12.8	95	4.29	A	A+	4.34	6.23	2011	1.52	
2.5+3.5+6.0	2.00	2.80	5.24	---	3.90	9.60	11.24	0.65	2.23	11.24	3.00	10.3	13	95	4.31	A	A+	4.35	6.23	2007	1.52	
2.5+3.5+7.1	1.83	2.56	5.68	---	4.22	9.60	11.25	0.71	2.22	11.25	3.30	10.2	12.9	95	4.33	A	A+	4.36	6.23	2002	1.52	
2.5+4.2+4.2	2.20	3.70	3.08	---	3.76	9.60	11.07	0.63	2.33	11.07	2.90	10.7	13.2	95	4.12	A	A+	4.27	6.23	2043	1.54	
2.5+4.2+5.0	2.05	3.45	4.40	---	3.89	9.60	11.12	0.64	2.20	11.12	3.00	10.1	12.6	95	4.36	A	A+	4.38	6.23	1991	1.51	
2.5+4.2+6.0	1.89	3.17	4.92	---	4.21	9.60	11.26	0.70	2.19	11.26	3.30	10.1	12.8	95	4.38	A	A+	4.39	6.23	1987	1.51	
2.5+4.2+7.1	1.74	2.92	5.37	---	4.53	9.60	11.27	0.77	2.18	11.27	3.60	10	12.7	95	4.40	A	A+	4.40	6.23	1983	1.51	
2.5+5.0+5.0	1.92	3.84	3.48	---	4.20	9.60	11.16	0.69	2.11	11.16	3.20	9.7	12.1	95	4.54	A	A+	4.47	6.23	1952	1.49	
2.5+5.0+6.0	1.78	3.56	4.61	---	4.35	9.60	11.29	0.72	2.11	11.29	3.30	9.7	12.3	95	4.56	A	A+	4.48	6.23	1949	1.49	
2.5+6.0+6.0	1.66	3.97	4.27	---	4.67	9.60	11.57	0.78	2.10	11.57	3.60	9.7	12.7	95	4.57	A	A+	4.48	6.23	1946	1.49	
3.5+3.5+3.5	3.20	3.20	2.32	---	3.61	9.60	11.15	0.61	2.42	11.15	2.90	11.1	14	95	3.96	A	A+	4.18	6.23	2084	1.57	
3.5+3.5+4.2	3.00	3.00	3.84	---	3.76	9.60	11.17	0.64	2.37	11.17	3.00	10.9	13.7	95	4.04	A	A+	4.23	6.23	2063	1.56	
3.5+3.5+5.0	2.80	2.80	4.29	---	3.90	9.60	11.11	0.65	2.24	11.11	3.00	10.3	12.8	95	4.29	A	A+	4.34	6.23	2011	1.52	
3.5+3.5+6.0	2.58	2.58	4.80	---	4.22	9.60	11.24	0.71	2.23	11.24	3.30	10.3	13	95	4.31	A	A+	4.35	6.23	2007	1.52	
3.5+3.5+7.1	2.38	2.38	5.24	---	4.54	9.60	11.25	0.77	2.22	11.25	3.60	10.2	12.9	95	4.33	A	A+	4.36	6.23	2002	1.52	
3.5+4.2+4.2	2.82	3.39	2.86	---	3.92	9.60	10.81	0.66														

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
4MXM80N2V1B9	4.2+4.2+6.0	2.80	2.80	4.30	---	4.68	9.60	11.28	0.79	2.16	11.28	3.70	9.9	12.6	95	4.45	A	A+	4.42	6.23	1972	1.50
	4.2+5.0+5.0	2.84	3.38	3.33	---	4.67	9.60	11.16	0.77	2.09	11.16	3.60	9.6	11.9	95	4.60	A	A+	4.50	6.23	1940	1.49
	1.5+1.5+1.5+1.5	2.43	2.43	0.77	---	2.23	7.30	10.18	0.39	1.46	10.18	1.76	6.7	10.7	95	5.02	A	A+	4.42	6.23	1974	1.85
	1.5+1.5+1.5+2.0	2.67	2.67	2.67	---	2.38	8.00	10.32	0.39	1.64	10.32	1.81	7.6	10.9	95	4.87	A	A+	4.43	6.23	1971	1.50
	1.5+1.5+1.5+2.5	2.83	2.83	2.83	---	2.58	8.50	10.46	0.41	1.80	10.46	2.00	8.3	11.1	95	4.72	A	A+	4.43	6.23	1968	1.50
	1.5+1.5+1.5+3.5	3.10	3.10	3.10	---	2.91	9.30	10.60	0.46	2.05	10.60	2.20	9.4	11.3	95	4.54	A	A+	4.43	6.23	1968	1.50
	1.5+1.5+1.5+4.2	3.20	3.20	3.20	---	3.06	9.60	11.29	0.49	2.12	11.29	2.30	9.7	12.4	95	4.53	A	A+	4.46	6.23	1954	1.49
	1.5+1.5+1.5+5.0	3.20	3.20	3.20	---	3.37	9.60	11.30	0.53	2.05	11.30	2.50	9.4	11.9	95	4.68	A	A+	4.53	6.23	1923	1.48
	1.5+1.5+1.5+6.0	3.20	3.20	3.20	---	3.53	9.60	11.57	0.56	2.04	11.57	2.70	9.4	12.4	95	4.70	A	A+	4.54	6.23	1921	1.48
	1.5+1.5+1.5+7.1	3.20	3.20	3.20	---	3.85	9.60	11.57	0.62	2.04	11.57	2.90	9.4	12.3	95	4.71	A	A+	4.55	6.23	1918	1.48
	1.5+1.5+2.0+2.0	2.55	2.55	3.78	---	2.58	8.50	10.60	0.41	1.80	10.60	2.00	8.3	11.3	95	4.72	A	A+	4.43	6.23	1968	1.50
	1.5+1.5+2.0+2.5	2.70	2.70	3.60	---	2.74	9.00	10.60	0.44	1.95	10.60	2.10	9	11.3	95	4.62	A	A+	4.44	6.23	1965	1.50
	1.5+1.5+2.0+3.5	1.69	1.69	3.84	3.95	3.07	9.60	10.74	0.49	2.14	10.74	2.30	9.9	11.5	95	4.48	A	A+	4.44	6.23	1965	1.50
	1.5+1.5+2.0+4.2	1.57	1.57	2.26	4.38	3.23	9.60	11.29	0.51	2.11	11.29	2.40	9.7	12.3	95	4.54	A	A+	4.47	6.23	1952	1.49
	1.5+1.5+2.0+5.0	1.44	1.44	2.09	4.80	3.37	9.60	11.30	0.53	2.05	11.30	2.50	9.4	11.9	95	4.69	A	A+	4.54	6.23	1922	1.48
	1.5+1.5+2.0+6.0	1.31	1.31	1.92	5.24	3.69	9.60	11.57	0.59	2.04	11.57	2.80	9.4	12.3	95	4.71	A	A+	4.54	6.23	1919	1.48
	1.5+1.5+2.0+7.1	1.19	1.19	1.75	5.63	4.01	9.60	11.57	0.64	2.03	11.57	3.00	9.4	12.3	95	4.72	A	A+	4.55	6.23	1917	1.48
	1.5+1.5+2.5+2.5	1.80	1.80	1.98	3.00	2.90	9.60	10.60	0.46	2.14	10.60	2.20	9.8	11.3	95	4.49	A	A+	4.44	6.23	1963	1.50
	1.5+1.5+2.5+3.5	1.60	1.60	3.00	3.73	3.23	9.60	11.28	0.52	2.14	11.28	2.40	9.8	12.5	95	4.49	A	A+	4.44	6.23	1963	1.50
	1.5+1.5+2.5+4.2	1.48	1.48	2.67	4.16	3.39	9.60	11.29	0.54	2.11	11.29	2.60	9.7	12.3	95	4.55	A	A+	4.47	6.23	1949	1.49
	1.5+1.5+2.5+5.0	1.37	1.37	2.47	4.57	3.53	9.60	11.30	0.56	2.04	11.30	2.60	9.4	11.9	95	4.70	A	A+	4.54	6.23	1920	1.48
	1.5+1.5+2.5+6.0	1.25	1.25	2.29	5.01	3.85	9.60	11.57	0.61	2.04	11.57	2.90	9.4	12.3	95	4.71	A	A+	4.55	6.23	1917	1.48
	1.5+1.5+2.5+7.1	1.14	1.14	2.09	5.41	4.17	9.60	11.57	0.67	2.03	11.57	3.20	9.3	12.3	95	4.73	A	A+	4.55	6.23	1915	1.48
	1.5+1.5+3.5+3.5	1.44	1.44	2.67	3.36	3.39	9.60	11.28	0.55	2.14	11.28	2.60	9.8	12.5	95	4.49	A	A+	4.44	6.23	1963	1.50
	1.5+1.5+3.5+4.2	1.35	1.35	3.36	3.77	3.55	9.60	11.29	0.57	2.11	11.29	2.70	9.7	12.3	95	4.55	A	A+	4.47	6.23	1949	1.49
	1.5+1.5+3.5+5.0	1.25	1.25	3.14	4.17	3.86	9.60	11.30	0.62	2.04	11.30	2.90	9.4	11.9	95	4.70	A	A+	4.54	6.23	1920	1.48
	1.5+1.5+3.5+6.0	1.15	1.15	2.92	4.61	4.18	9.60	11.57	0.67	2.04	11.57	3.20	9.4	12.3	95	4.71	A	A+	4.55	6.23	1917	1.48
	1.5+1.5+3.5+7.1	1.06	1.06	2.69	5.01	4.49	9.60	11.71	0.73	2.03	11.71	3.40	9.3	12.5	95	4.73	A	A+	4.55	6.23	1915	1.48
	1.5+1.5+4.2+4.2	1.26	1.26	2.96	3.54	3.87	9.60	11.30	0.62	2.08	2.63	2.90	9.6	12.1	95	4.61	A	A+	4.50	6.23	1937	1.49
	1.5+1.5+4.2+5.0	1.18	1.18	3.54	3.93	4.01	9.60	11.43	0.64	2.02	2.60	3.00	9.3	11.9	95	4.75	A	A+	4.56	6.23	1911	1.48
	1.5+1.5+4.2+6.0	1.09	1.09	3.30	4.36	4.33	9.60	11.57	0.70	2.02	2.64	3.30	9.3	12.2	95	4.76	A	A+	4.57	6.23	1909	1.48
	1.5+1.5+4.2+7.1	1.01	1.01	3.05	4.77	4.65	9.60	11.70	0.76	2.01	2.68	3.50	9.3	12.4	95	4.77	A	A+	4.57	6.23	1907	1.49
	1.5+1.5+5.0+5.0	1.11	1.11	3.36	3.69	4.32	9.60	11.55	0.69	1.98	2.58	3.20	9.1	11.9	95	4.85	A	A++	4.63	6.23	1885	1.49
	1.5+1.5+5.0+6.0	1.03	1.03	3.69	4.11	4.48	9.60	11.81	0.72	1.98	2.68	3.30	9.1	12.3	95	4.85	A	A++	4.63	6.23	1884	1.50
	1.5+2.0+2.0+2.0	1.90	2.53	1.36	2.53	2.74	9.50	10.74	0.44	2.12	2.50	2.10	9.8	11.5	95	4.48	A	A+	4.44	6.23	1965	1.50
	1.5+2.0+2.0+2.5	1.80	2.40	2.56	3.00	2.90	9.60	10.88	0.46	2.14	2.55	2.20	9.8	11.7	95	4.49	A	A+	4.44	6.23	1963	1.50
	1.5+2.0+2.0+3.5	1.60	2.13	2.40	3.73	3.23	9.60	11.28	0.52	2.14	2.70	2.40	9.8	12.5	95	4.49	A	A+	4.44	6.23	1963	1.50
	1.5+2.0+2.0+4.2	1.48	1.98	2.13	4.16	3.39	9.60	11.29	0.54	2.11	2.67	2.60	9.7	12.3	95	4.55	A	A+	4.47	6.23	1949	1.49
	1.5+2.0+2.0+5.0	1.37	1.83	1.98	4.57	3.53	9.60	11.30	0.56	2.04	2.58	2.60	9.4	11.9	95	4.70	A	A+	4.54	6.23	1920	1.48
	1.5+2.0+2.0+6.0	1.25	1.67	1.83	5.01	3.85	9.60	11.57	0.61	2.04	2.67	2.90	9.4	12.3	95	4.71	A	A+	4.55	6.23	1918	1.48
	1.5+2.0+2.0+7.1	1.14	1.52	1.67	5.41	4.17	9.60	11.57	0.67	2.03	2.66	3.20	9.3	12.3	95	4.73	A	A+	4.55	6.23	1915	1.48
	1.5+2.0+2.5+2.5	1.69	2.26	1.90	2.82	3.07	9.60	10.88	0.49	2.13	2.54	2.30	9.8	11.7	95	4.50	A	A+	4.45	6.23	1960	1.49
	1.5+2.0+2.5+3.5	1.52	2.02	2.82	3.54	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.8	12.2	95	4.50	A	A+	4.45	6.23	1960	1.49
	1.5+2.0+2.5+4.2	1.41	1.88	2.53	3.95	3.55	9.60	11.29	0.57	2.10	2.66	2.70	9.7	12.2	95	4.57	A	A+	4.48	6.23	1947	1.49
	1.5+2.0+2.5+5.0	1.31	1.75	2.35	4.36	3.69	9.60	11.30	0.59	2.04	2.57	2.80	9.4	11.9	95	4.71	A	A+	4.55	6.23	1918	1.48
	1.5+2.0+2.5+6.0	1.20	1.60	2.18	4.80	4.01	9.60	11.57	0.64	2.03	2.66	3.00	9.4	12.3	95	4.72	A	A+	4.55	6.23	1916	1.48
	1.5+2.0+2.5+7.1	1.10	1.47	2.00	5.20	4.33	9.60	11.57	0.70	2.03	2.66	3.30	9.3	12.2	95	4.74	A	A+	4.56	6.23	1913	1.48
	1.5+2.0+3.5+3.5	1.37	1.83	2.56	3.20	3.56	9.60	11.29	0.57	2.13	2.70	2.70	9.8	12.4	95	4.50	A	A+	4.45	6.23	1960	1.49
	1.5+2.0+3.5+4.2	1.29	1.71	3.20	3.60	3.71	9.60	11.29	0.60	2.10	2.66	2.80	9.7	12.2	95	4.57	A	A+	4.48	6.23	1947	1.49
	1.5+2.0+3.5+5.0	1.20	1.60	3.00	4.00	4.02	9.60	11.30	0.64	2.04	2.57	3.00	9.4	11.9	95	4.71	A	A+	4.55	6.23	1918	1.48
1.5+2.0+3.5+6.0	1.11	1.48	2.80	4.43	4.17	9.60	11.57	0.67	2.03	2.66	3.20	9.4	12.3	95	4.72	A	A+	4.55	6.23	1916	1.48	
1.5+2.0+3.5+7.1	1.02	1.36	2.58	4.83	4.49	9.60	11.71	0.73	2.03	2.71	3.40	9.3	12.5	95	4.74	A	A+	4.56	6.23	1913	1.48	
1.5+2.0+4.2+4.2	1.21	1.61	2.86	3.39	4.03	9.60	11.30	0.65	2.08	2.62	3.10	9.6	12.1	95	4.62	A	A+	4.51	6.23	1935	1.49	
1.5+2.0+4.2+5.0	1.13	1.51	3.39	3.78	4.17	9.60	11.43	0.67	2.02	2.59	3.10	9.3	11.9	95	4.76	A	A+	4.57	6.23	1910	1.48	
1.5+2.0+4.2+6.0	1.05	1.40	3.17	4.20	4.49	9.60	11.57	0.73	2.01	2.64	3.40	9.3	12.1	95	4.77	A	A+	4.57	6.23	1908	1.49	
1.5+2.0+5.0+5.0	1.07	1.42	3.50	3.56	4.32	9.60	11.54	0.69	1.98	2.58	3.20	9.1	11.9	95	4.85	A	A++	4.63	6.23	1884	1.50	
1.5+2.0+5.0+6.0	0.99	1.32	3.56	3.97	4.63	9.60	11.81	0.75	1.99	2.67	3.50	9.2	12.3	95	4.82	A	A++	4.63	6.23	1883	1.50	
1.5+2.5+2.5+2.5	1.60	2.67	1.66	2.67	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.8	12.1	95	4.52	A	A+	4.46	6.23	1957	1.49	
1.5+2.5+2.5+3.5	1.44	2.40	2.67	3.36	3.39	9.60	11.15	0.54	2.13	2.64												

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)				Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
4MXM80N2V1B9	1.5+2.5+3.5+6.0	1.07	1.78	2.69	4.27	4.33	9.60	11.57	0.70	2.03	2.66	3.30	9.3	12.2	95	4.73	A	A+	4.56	6.23	1914	1.48
	1.5+2.5+4.2+4.2	1.16	1.94	2.99	3.25	4.02	9.60	11.30	0.65	2.07	2.62	3.00	9.5	12	95	4.63	A	A+	4.51	6.23	1933	1.49
	1.5+2.5+4.2+5.0	1.09	1.82	3.25	3.64	4.33	9.60	11.43	0.70	2.01	2.59	3.30	9.3	11.9	95	4.77	A	A+	4.57	6.23	1908	1.49
	1.5+2.5+4.2+6.0	1.01	1.69	3.05	4.06	4.65	9.60	11.57	0.75	2.01	2.63	3.50	9.3	12.1	95	4.78	A	A+	4.58	6.23	1906	1.49
	1.5+2.5+5.0+5.0	1.03	1.71	3.38	3.43	4.48	9.60	11.54	0.72	1.98	2.58	3.30	9.1	11.9	95	4.86	A	A++	4.63	6.23	1883	1.50
	1.5+3.5+3.5+3.5	1.20	2.80	2.40	2.80	4.04	9.60	11.29	0.66	2.13	2.69	3.10	9.8	12.4	95	4.52	A	A+	4.46	6.23	1957	1.49
	1.5+3.5+3.5+4.2	1.13	2.65	2.80	3.17	4.19	9.60	11.30	0.68	2.10	2.65	3.20	9.6	12.2	95	4.58	A	A+	4.49	6.23	1944	1.49
	1.5+3.5+3.5+5.0	1.07	2.49	2.65	3.56	4.33	9.60	11.44	0.70	2.03	2.61	3.30	9.4	12	95	4.72	A	A+	4.55	6.23	1916	1.48
	1.5+3.5+2.0+5.0	0.99	2.32	2.49	3.97	4.65	9.60	11.57	0.76	2.02	2.66	3.50	9.3	12.2	95	4.73	A	A+	4.56	6.23	1914	1.48
	1.5+3.5+4.2+4.2	1.07	2.51	2.78	3.01	4.34	9.60	11.30	0.71	2.07	2.62	3.30	9.5	12	95	4.63	A	A+	4.51	6.23	1933	1.49
	1.5+3.5+4.2+5.0	1.01	2.37	3.01	3.38	4.65	9.60	11.43	0.76	2.01	2.59	3.50	9.3	11.9	95	4.77	A	A+	4.57	6.23	1908	1.49
	1.5+4.2+4.2+4.2	1.02	2.86	2.84	2.86	4.50	9.60	11.30	0.73	2.05	2.58	3.40	9.4	11.9	95	4.69	A	A+	4.54	6.23	1923	1.48
	2.0+2.0+2.0+5.0	2.40	2.40	1.36	2.40	2.90	9.60	10.88	0.46	2.10	2.55	2.20	9.6	11.7	95	4.58	A	A+	4.55	6.23	1917	1.50
	2.0+2.0+2.0+2.5	2.26	2.26	2.40	2.82	3.07	9.60	11.01	0.49	2.13	2.59	2.30	9.8	11.9	95	4.50	A	A+	4.57	6.23	1908	1.49
	2.0+2.0+2.0+3.5	2.02	2.02	2.26	3.54	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.8	12.2	95	4.50	A	A++	4.60	6.23	1896	1.49
	2.0+2.0+2.0+4.2	1.88	1.88	2.02	3.95	3.55	9.60	11.29	0.57	2.10	2.66	2.70	9.7	12.2	95	4.57	A	A++	4.61	6.23	1891	1.49
	2.0+2.0+2.0+5.0	1.75	1.75	1.88	4.36	3.69	9.60	11.30	0.59	2.04	2.57	2.80	9.4	11.9	95	4.71	A	A++	4.64	6.23	1878	1.48
	2.0+2.0+2.0+6.0	1.60	1.60	1.75	4.80	4.01	9.60	11.57	0.64	2.03	2.66	3.00	9.4	12.3	95	4.72	A	A++	4.65	6.23	1877	1.48
	2.0+2.0+2.0+7.1	1.47	1.47	1.60	5.20	4.33	9.60	11.57	0.70	2.03	2.66	3.30	9.3	12.2	95	4.74	A	A++	4.65	6.23	1876	1.48
	2.0+2.0+2.5+2.5	2.13	2.13	1.83	2.67	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.8	12.1	95	4.52	A	A+	4.46	6.23	1957	1.49
	2.0+2.0+2.5+3.5	1.92	1.92	2.67	3.36	3.39	9.60	11.15	0.54	2.13	2.64	2.60	9.8	12.1	95	4.52	A	A++	4.60	6.23	1895	1.49
	2.0+2.0+2.5+4.2	1.79	1.79	2.40	3.77	3.55	9.60	11.30	0.57	2.10	2.65	2.70	9.6	12.2	95	4.58	A	A++	4.62	6.23	1890	1.49
	2.0+2.0+2.5+5.0	1.67	1.67	2.24	4.17	3.85	9.60	11.30	0.61	2.03	2.57	2.90	9.4	11.8	95	4.72	A	A++	4.65	6.23	1878	1.48
	2.0+2.0+2.5+6.0	1.54	1.54	2.09	4.61	4.17	9.60	11.57	0.67	2.03	2.66	3.20	9.3	12.2	95	4.73	A	A++	4.65	6.23	1877	1.48
	2.0+2.0+2.5+7.1	1.41	1.41	1.92	5.01	4.49	9.60	11.57	0.73	2.02	2.65	3.40	9.3	12.2	95	4.74	A	A++	4.65	6.23	1876	1.48
	2.0+2.0+3.5+3.5	1.75	1.75	2.47	3.05	3.72	9.60	11.29	0.60	2.13	2.69	2.80	9.8	12.4	95	4.52	A	A++	4.60	6.23	1895	1.49
	2.0+2.0+3.5+4.2	1.64	1.64	3.05	3.45	3.87	9.60	11.30	0.63	2.10	2.65	2.90	9.6	12.2	95	4.58	A	A++	4.62	6.23	1890	1.49
	2.0+2.0+3.5+5.0	1.54	1.54	2.87	3.84	4.17	9.60	11.30	0.67	2.03	2.57	3.20	9.4	11.8	95	4.72	A	A++	4.65	6.23	1878	1.48
	2.0+2.0+3.5+6.0	1.42	1.42	2.69	4.27	4.33	9.60	11.57	0.70	2.03	2.66	3.30	9.3	12.2	95	4.73	A	A++	4.65	6.23	1877	1.48
	2.0+2.0+4.2+4.2	1.55	1.55	2.99	3.25	4.02	9.60	11.30	0.65	2.07	2.62	3.00	9.5	12	95	4.63	A	A++	4.63	6.23	1885	1.49
	2.0+2.0+4.2+5.0	1.45	1.45	3.25	3.64	4.33	9.60	11.43	0.70	2.01	2.59	3.30	9.3	11.9	95	4.77	A	A++	4.65	6.23	1874	1.49
	2.0+2.0+4.2+6.0	1.35	1.35	3.05	4.06	4.65	9.60	11.57	0.75	2.01	2.63	3.50	9.3	12.1	95	4.78	A	A++	4.66	6.23	1873	1.49
	2.0+2.0+5.0+5.0	1.37	1.37	3.38	3.43	4.48	9.60	11.54	0.72	1.98	2.58	3.30	9.1	11.9	95	4.86	A	A++	4.63	6.23	1883	1.50
	2.0+2.5+2.5+2.5	2.02	2.53	1.71	2.53	3.23	9.60	11.15	0.52	2.12	2.63	2.40	9.8	12.1	95	4.53	A	A++	4.61	6.23	1894	1.49
	2.0+2.5+2.5+3.5	1.83	2.29	2.53	3.20	3.55	9.60	11.15	0.57	2.12	2.63	2.70	9.8	12.1	95	4.53	A	A++	4.61	6.23	1894	1.49
	2.0+2.5+2.5+4.2	1.71	2.14	2.29	3.60	3.71	9.60	11.16	0.60	2.09	2.59	2.80	9.6	11.9	95	4.59	A	A++	4.62	6.23	1889	1.49
	2.0+2.5+2.5+5.0	1.60	2.00	2.14	4.00	4.01	9.60	11.30	0.64	2.03	2.56	3.00	9.3	11.8	95	4.73	A	A++	4.65	6.23	1877	1.48
	2.0+2.5+2.5+6.0	1.48	1.85	2.00	4.43	4.17	9.60	11.57	0.67	2.02	2.65	3.10	9.3	12.2	95	4.74	A	A++	4.65	6.23	1876	1.48
	2.0+2.5+2.5+7.1	1.36	1.70	1.85	4.83	4.49	9.60	11.57	0.73	2.02	2.65	3.40	9.3	12.2	95	4.75	A	A++	4.65	6.23	1875	1.48
	2.0+2.5+3.5+3.5	1.67	2.09	2.38	2.92	3.88	9.60	11.29	0.63	2.12	2.68	2.90	9.8	12.4	95	4.53	A	A++	4.61	6.23	1894	1.49
	2.0+2.5+3.5+4.2	1.57	1.97	2.92	3.30	4.03	9.60	11.30	0.65	2.09	2.64	3.10	9.6	12.2	95	4.59	A	A++	4.62	6.23	1889	1.49
	2.0+2.5+3.5+5.0	1.48	1.85	2.75	3.69	4.17	9.60	11.30	0.67	2.03	2.56	3.20	9.3	11.8	95	4.73	A	A++	4.65	6.23	1877	1.48
	2.0+2.5+3.5+6.0	1.37	1.71	2.58	4.11	4.49	9.60	11.57	0.73	2.02	2.65	3.40	9.3	12.2	95	4.74	A	A++	4.65	6.23	1876	1.48
	2.0+2.5+4.2+4.2	1.49	1.86	2.88	3.13	4.18	9.60	11.30	0.68	2.07	2.61	3.20	9.5	12	95	4.65	A	A++	4.63	6.23	1884	1.48
	2.0+2.5+4.2+5.0	1.40	1.75	3.13	3.50	4.49	9.60	11.43	0.73	2.01	2.58	3.40	9.3	11.9	95	4.77	A	A++	4.66	6.23	1873	1.49
	2.0+2.5+5.0+5.0	1.32	1.66	3.50	3.31	4.63	9.60	11.54	0.75	1.99	2.57	3.50	9.2	11.9	95	4.83	A	A++	4.63	6.23	1882	1.50
	2.0+3.5+3.5+3.5	1.54	2.69	2.32	2.69	4.20	9.60	11.29	0.69	2.12	2.68	3.20	9.8	12.4	95	4.53	A	A++	4.61	6.23	1894	1.49
	2.0+3.5+3.5+4.2	1.45	2.55	2.69	3.05	4.35	9.60	11.30	0.71	2.09	2.64	3.30	9.6	12.2	95	4.59	A	A++	4.62	6.23	1889	1.49
	2.0+3.5+3.5+5.0	1.37	2.40	2.55	3.43	4.49	9.60	11.44	0.73	2.03	2.61	3.40	9.3	12	95	4.73	A	A++	4.65	6.23	1877	1.48
	2.0+3.5+4.2+4.2	1.38	2.42	2.88	2.90	4.50	9.60	11.30	0.74	2.07	2.61	3.40	9.5	12	95	4.65	A	A++	4.63	6.23	1884	1.48
2.5+2.5+2.5+2.5	2.40	2.40	1.73	2.40	3.39	9.60	11.16	0.54	2.11	2.62	2.60	9.7	12.1	95	4.54	A	A++	4.61	6.23	1893	1.49	
2.5+2.5+2.5+3.5	2.18	2.18	2.40	3.05	3.71	9.60	11.16	0.60	2.11	2.62	2.80	9.7	12.1	95	4.54	A	A++	4.61	6.23	1893	1.49	
2.5+2.5+2.5+4.2	2.05	2.05	2.18	3.45	3.87	9.60	11.16	0.62	2.09	2.59	2.90	9.6	11.9	95	4.60	A	A++	4.62	6.23	1888	1.49	
2.5+2.5+2.5+5.0	1.92	1.92	2.05	3.84	4.17	9.60	11.30	0.67	2.03	2.55	3.10	9.3	11.8	95	4.74	A	A++	4.65	6.23	1876	1.48	
2.5+2.5+2.5+6.0	1.78	1.78	1.92	4.27	4.33	9.60	11.57	0.70	2.02	2.65	3.30	9.3	12.2	95	4.75	A	A++	4.65	6.23	1875	1.48	
2.5+2.5+3.5+3.5	2.00	2.00	2.49	2.80	4.03	9.60	11.29	0.66	2.11	2.67	3.10	9.7	12.3	95	4.54	A	A++	4.61	6.23	1893	1.49	
2.5+2.5+3.5+4.2	1.89	1.89	2.80	3.17	4.19	9.60	11.30	0.68	2.09	2.64	3.20	9.6	12.1	95	4.60	A	A++	4.62	6.23	1888	1.49	
2.5+2.5+3.5+5.0	1.78	1.78	2.65	3.56	4.33	9.60	11.30	0.70	2.03	2.55	3.30	9.3	11.8	95	4.74	A	A++	4.65	6.23	1876	1.48	
2.5+2.5+3.5+6.0	1.66	1.66	2.49	3.97																		

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
5MXM90N2V1B9	1.5	1.80	---	---	---	---	1.78	1.80	2.98	0.43	0.48	0.93	1.95	2.20	4.26	95	---	---	---	---	---	---	---
	2.0	2.00	---	---	---	---	1.86	2.00	3.09	0.44	0.56	0.99	2.00	2.57	4.53	95	---	---	---	---	---	---	---
	2.5	2.50	---	---	---	---	1.98	2.50	3.61	0.48	0.71	1.14	2.18	3.25	5.24	95	---	---	---	---	---	---	---
	3.5	3.50	---	---	---	---	2.03	3.50	4.92	0.50	1.14	1.43	2.31	5.22	6.53	95	---	---	---	---	---	---	---
	4.2	---	---	4.20	---	---	2.06	4.20	5.06	0.51	1.46	1.54	2.35	6.69	7.06	95	---	---	---	---	---	---	---
	5.0	---	---	5.00	---	---	2.20	5.00	5.94	0.48	1.52	1.74	2.18	6.96	7.95	95	---	---	---	---	---	---	---
	6.0	---	---	6.00	---	---	2.31	6.00	6.73	0.49	1.89	2.17	2.22	8.65	9.94	95	---	---	---	---	---	---	---
	7.1	---	---	7.10	---	---	2.43	7.10	7.53	0.51	2.57	2.66	2.35	11.77	12.16	95	---	---	---	---	---	---	---
	1.5+1.5	1.50	1.50	---	---	---	2.01	3.00	4.23	0.42	0.54	0.87	1.94	2.50	4.10	95	5.53	A	271	A++	6.72	3.00	162
	1.5+2.0	1.50	2.00	---	---	---	2.03	3.50	4.61	0.46	0.67	0.99	2.11	3.10	4.60	95	5.25	A	333	A++	6.91	3.50	180
	1.5+2.5	1.50	2.50	---	---	---	2.09	4.00	5.11	0.42	0.81	1.16	1.94	3.80	5.40	95	4.94	A	405	A++	7.09	4.00	202
	1.5+3.5	1.50	3.50	---	---	---	2.20	5.00	5.95	0.42	1.11	1.47	1.94	5.10	6.80	95	4.50	A	556	A++	7.12	5.00	247
	1.5+4.2	1.50	4.20	---	---	---	2.27	5.70	6.59	0.42	1.37	1.76	1.94	6.30	8.10	95	4.15	A	686	A++	7.09	5.70	283
	1.5+5.0	1.50	5.00	---	---	---	2.36	6.50	7.20	0.46	1.65	1.97	2.11	7.60	9.10	95	3.94	A	825	A++	7.11	6.50	323
	1.5+6.0	1.50	6.00	---	---	---	2.48	7.50	7.81	0.50	2.12	2.29	2.27	9.80	10.60	95	3.53	A	1061	A++	6.93	7.50	380
	1.5+7.1	1.40	6.60	---	---	---	2.64	8.00	8.51	0.52	2.40	2.76	2.40	11.10	12.70	95	3.33	A	1202	A++	6.84	8.00	410
	2.0+2.0	2.00	2.00	---	---	---	2.09	4.00	5.45	0.46	0.81	1.29	2.11	3.80	6.00	95	4.93	A	405	A++	7.08	4.00	202
	2.0+2.5	2.00	2.50	---	---	---	2.14	4.50	5.91	0.46	0.97	1.47	2.11	4.50	6.80	95	4.66	A	483	A++	7.13	4.50	226
	2.0+3.5	2.00	3.50	---	---	---	2.25	5.50	6.58	0.46	1.31	1.76	2.11	6.00	8.10	95	4.20	A	654	A++	7.09	5.50	276
	2.0+4.2	2.00	4.20	---	---	---	2.33	6.20	6.98	0.46	1.59	1.96	2.11	7.30	9.00	95	3.89	A	796	A++	7.02	6.20	313
	2.0+5.0	2.00	5.00	---	---	---	2.42	7.00	7.49	0.46	1.89	2.13	2.11	8.70	9.80	95	3.70	A	946	A++	7.06	7.00	351
	2.0+6.0	1.88	5.63	---	---	---	2.55	7.50	8.16	0.50	2.12	2.52	2.27	9.80	11.60	95	3.53	A	1061	A++	6.93	7.50	380
	2.0+7.1	1.76	6.24	---	---	---	2.71	8.00	8.67	0.52	2.40	2.88	2.40	11.10	13.20	95	3.33	A	1202	A++	6.84	8.00	410
	2.5+2.5	2.50	2.50	---	---	---	2.20	5.00	6.34	0.42	1.12	1.66	1.94	5.20	7.70	95	4.48	A	558	A++	7.11	5.00	246
	2.5+3.5	2.50	3.50	---	---	---	2.31	6.00	6.79	0.46	1.50	1.86	2.11	6.90	8.60	95	4.00	A	750	A++	7.04	6.00	301
	2.5+4.2	2.50	4.20	---	---	---	2.39	6.70	7.27	0.46	1.81	2.12	2.11	8.30	9.80	95	3.71	A	904	A++	6.98	6.70	336
	2.5+5.0	2.50	5.00	---	---	---	2.48	7.50	7.88	0.49	2.13	2.35	2.23	9.80	10.80	95	3.53	A	1064	A++	6.92	7.50	380
	2.5+6.0	2.35	5.65	---	---	---	2.63	8.00	8.43	0.52	2.40	2.70	2.40	11.10	12.40	95	3.33	A	1202	A++	6.83	8.00	410
	2.5+7.1	2.21	6.29	---	---	---	2.79	8.50	8.69	0.55	2.75	2.88	2.53	12.60	13.20	95	3.09	B	1373	A++	6.67	8.50	447
	3.5+3.5	3.50	3.50	---	---	---	2.42	7.00	7.49	0.49	1.95	2.23	2.23	9.00	10.30	95	3.59	A	976	A++	6.91	7.00	356
	3.5+4.2	3.50	4.20	---	---	---	2.51	7.70	7.85	0.49	2.37	2.45	2.23	10.90	11.30	95	3.25	A	1185	A++	6.71	7.70	405
	3.5+5.0	3.29	4.71	---	---	---	2.63	8.00	8.02	0.52	2.40	2.41	2.40	11.00	11.10	95	3.33	A	1201	A++	6.84	8.00	410
	3.5+6.0	2.95	5.05	---	---	---	2.77	8.00	8.65	0.55	2.39	2.82	2.53	11.00	13.00	95	3.34	A	1196	A++	6.86	8.00	411
	3.5+7.1	2.97	6.03	---	---	---	2.93	9.00	8.68	0.59	2.94	2.82	2.69	13.50	13.00	95	3.06	B	1471	A++	6.61	9.00	477
	4.2+4.2	4.00	4.00	---	---	---	2.61	8.00	7.86	0.52	2.55	2.45	2.36	11.70	11.30	95	3.13	B	1276	A++	6.64	8.00	423
	4.2+5.0	3.65	4.35	---	---	---	2.73	8.00	8.21	0.55	2.40	2.52	2.53	11.00	11.60	95	3.34	A	1199	A++	6.85	8.00	411
	4.2+6.0	3.50	5.00	---	---	---	2.88	8.50	8.67	0.55	2.65	2.82	2.53	12.20	13.00	95	3.21	A	1323	A++	6.72	8.50	443
	4.2+7.1	3.35	5.65	---	---	---	3.04	9.00	8.85	0.59	2.94	2.95	2.69	13.50	13.60	95	3.06	B	1469	A++	6.61	9.00	478
	5.0+5.0	4.25	4.25	---	---	---	2.85	8.50	8.37	0.55	2.59	2.48	2.53	11.90	11.40	95	3.29	A	1293	A++	6.87	8.50	435
	5.0+6.0	4.09	4.91	---	---	---	2.99	9.00	8.85	0.59	2.90	2.78	2.69	13.30	12.80	95	3.10	B	1451	A++	6.73	9.00	469
	5.0+7.1	3.72	5.28	---	---	---	3.25	9.00	9.12	0.57	2.90	2.97	2.70	13.30	13.70	95	3.11	B	1448	A++	6.76	9.00	468
	6.0+6.0	4.50	4.50	---	---	---	3.25	9.00	9.46	0.57	2.89	3.23	2.70	13.30	14.90	95	3.11	B	1446	A++	6.77	9.00	468
	6.0+7.1	4.12	4.88	---	---	---	3.41	9.00	9.48	0.60	2.79	3.23	2.80	12.80	14.90	95	3.22	A	1397	A++	6.81	9.00	463
	7.1+7.1	4.50	4.50	---	---	---	3.57	9.00	9.51	0.64	2.79	3.24	3.00	12.80	14.90	95	3.23	A	1395	A++	6.82	9.00	463
	1.5+1.5+1.5	1.50	1.50	1.50	---	---	2.14	4.50	5.64	0.43	0.87	1.20	1.98	4.00	5.60	95	5.19	A	433	A++	7.41	4.50	213
	1.5+1.5+2.0	1.50	1.50	2.00	---	---	2.20	5.00	6.04	0.43	1.01	1.34	1.98	4.70	6.20	95	4.93	A	507	A++	7.42	5.00	239
	1.5+1.5+2.5	1.50	1.50	2.50	---	---	2.25	5.50	6.44	0.43	1.16	1.48	1.98	5.30	6.90	95	4.75	A	579	A++	7.44	5.50	259
	1.5+1.5+3.5	1.50	1.50	3.50	---	---	2.36	6.50	7.20	0.46	1.51	1.78	2.11	7.00	8.20	95	4.31	A	754	A++	7.41	6.50	311
	1.5+1.5+4.2	1.50	1.50	4.20	---	---	2.44	7.20	7.67	0.46	1.78	1.99	2.11	8.20	9.20	95	4.05	A	889	A++	7.30	7.20	345
	1.5+1.5+5.0	1.41	1.41	4.69	---	---	2.55	7.50	8.18	0.50	1.87	2.17	2.27	8.60	10.00	95	4.02	A	934	A++	7.40	7.50	359
	1.5+1.5+6.0	1.33	1.33	5.33	---	---	2.70	8.00	8.75	0.53	2.09	2.46	2.44	9.60	11.30	95	3.83	A	1044	A++	7.31	8.00	387
	1.5+1.5+7.1	1.26	1.26	5.98	---	---	2.86	8.50	9.26	0.56	2.33	2.77	2.57	10.70	12.70	95	3.65	A	1164	A++	7.20	8.50	415
	1.5+2.0+2.0	1.50	2.00	2.00	---	---	2.25	5.50	6.43	0.46	1.16	1.48	2.11	5.40	6.90	95	4.74	A	580	A++	7.43	5.50	259
	1.5+2.0+2.5	1.50	2.00	2.50	---	---	2.31	6.00	6.81	0.43	1.33	1.63	1.98	6.10	7.50	95	4.51	A	665	A++	7.42	6.00	285
	1.5+2.0+3.5	1.50	2.00	3.50	---	---	2.42	7.00	7.55	0.46	1.71	1.94	2.11	7.90	8.90	95	4.10	A	855	A++	7.35	7.00	337
1.5+2.0+4.2	1.50	2.00	4.20	---	---	2.51	7.70	8.00	0.50	2.02	2.16	2.27	9.30	9.90	95	3.80	A	1012	A++	7.22	7.70	377	
1.5+2.0+5.0	1.41	1.88	4.71	---	---	2.63	8.00	8.50	0.50	2.09	2.34	2.27	9.60	10.80	95	3.82	A	1047	A++	7.29	8.00	387	
1.5+2.0+6.0	1.26	1.68	5.05	---	---	2.77	8.00	9.05	0.53	2.09	2.64	2.44	9.60	12.20	95	3.83	A	1044	A++	7.31	8.00	387	
1.5+2.0+7.1	1.27	1.70	6.03	---	---	2.93	9.00	9.36	0.56	2.62	2.83	2.57	12.00	13.00	95	3.43	A	1311	A++	7.07	9.00	448	
1.5+2.5+2.5	1.50	2.50	2.50	---	---	2.36	6.50	7.18	0.46	1.51	1.78	2.11	7.00	8.20	95	4.30	A	757	A++	7.40	6.50	311	
1.5+2.5+3.5	1.50	2.50	3.50	---	---	2.48	7.50	7.90	0.50	1.92	2.10	2.27	8.80	9.70	95	3.90	A	961	A++	7.28	7.50	363	
1.5+2.5+4.2	1.46	2.44	4.10	---	---	2.58	8.00	8.33	0.50	2.15	2.33	2.27	9.90	10.70	95	3.71	A	1077	A++	7.17	8.00	391	
1																							

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
5MXM90N2V1B9	2.0+2.0+2.5	2.00	2.00	2.50	---	---	2.36	6.50	7.17	0.46	1.52	1.78	2.11	7.00	8.20	95	4.29	A	758	A++	7.39	6.50	310
	2.0+2.0+3.5	2.00	2.00	3.50	---	---	2.48	7.50	7.88	0.50	1.93	2.10	2.27	8.90	9.70	95	3.90	A	963	A++	7.27	7.50	363
	2.0+2.0+4.2	2.00	2.00	4.20	---	---	2.58	8.20	8.31	0.50	2.27	2.33	2.27	10.40	10.70	95	3.62	A	1133	A++	7.11	8.20	404
	2.0+2.0+5.0	1.78	1.78	4.44	---	---	2.70	8.00	8.71	0.52	2.09	2.46	2.40	9.60	11.30	95	3.82	A	1047	A++	7.29	8.00	387
	2.0+2.0+6.0	1.70	1.70	5.10	---	---	2.85	8.50	9.24	0.53	2.33	2.76	2.44	10.70	12.70	95	3.65	A	1166	A++	7.19	8.50	415
	2.0+2.0+7.1	1.62	1.62	5.76	---	---	3.01	9.00	9.54	0.56	2.62	2.96	2.57	12.00	13.60	95	3.43	A	1311	A++	7.07	9.00	448
	2.0+2.5+2.5	2.00	2.50	2.50	---	---	2.42	7.00	7.52	0.46	1.71	1.94	2.11	7.90	8.90	95	4.08	A	857	A++	7.33	7.00	337
	2.0+2.5+3.5	1.88	2.34	3.28	---	---	2.55	7.50	8.22	0.50	1.92	2.27	2.27	8.80	10.40	95	3.90	A	961	A++	7.28	7.50	363
	2.0+2.5+4.2	1.84	2.30	3.86	---	---	2.66	8.00	8.53	0.52	2.15	2.44	2.40	9.90	11.30	95	3.71	A	1077	A++	7.17	8.00	391
	2.0+2.5+5.0	1.68	2.11	4.21	---	---	2.77	8.00	8.83	0.52	2.09	2.52	2.40	9.60	11.60	95	3.83	A	1045	A++	7.30	8.00	387
	2.0+2.5+6.0	1.66	2.07	4.97	---	---	2.92	8.70	9.36	0.56	2.44	2.83	2.57	11.20	13.00	95	3.56	A	1221	A++	7.17	8.70	428
	2.0+2.5+7.1	1.55	1.94	5.51	---	---	3.08	9.00	9.56	0.59	2.62	2.96	2.69	12.00	13.60	95	3.44	A	1309	A++	7.08	9.00	449
	2.0+3.5+3.5	1.78	3.11	3.11	---	---	2.70	8.00	8.67	0.52	2.15	2.51	2.40	9.90	11.50	95	3.73	A	1073	A++	7.18	8.00	392
	2.0+3.5+4.2	1.75	3.07	3.68	---	---	2.80	8.50	8.68	0.55	2.42	2.51	2.53	11.10	11.50	95	3.51	A	1212	A++	7.07	8.50	424
	2.0+3.5+5.0	1.66	2.90	4.14	---	---	2.92	8.70	8.87	0.56	2.44	2.52	2.57	11.20	11.60	95	3.56	A	1220	A++	7.17	8.70	428
	2.0+3.5+6.0	1.57	2.74	4.70	---	---	3.07	9.00	9.50	0.59	2.58	2.90	2.69	11.90	13.30	95	3.49	A	1290	A++	7.13	9.00	442
	2.0+3.5+7.1	1.43	2.50	5.07	---	---	3.32	9.00	9.51	0.57	2.58	2.90	2.70	11.80	13.30	95	3.49	A	1289	A++	7.14	9.00	443
	2.0+4.2+4.2	1.67	3.51	3.51	---	---	2.91	8.70	8.69	0.55	2.54	2.51	2.53	11.70	11.50	95	3.42	A	1270	A++	7.04	8.70	437
	2.0+4.2+5.0	1.61	3.38	4.02	---	---	3.02	9.00	9.09	0.59	2.62	2.64	2.69	12.00	12.20	95	3.44	A	1309	A++	7.08	9.00	449
	2.0+4.2+6.0	1.48	3.10	4.43	---	---	3.32	9.00	9.51	0.57	2.58	2.90	2.70	11.90	13.30	95	3.49	A	1289	A++	7.13	9.00	442
	2.0+4.2+7.1	1.35	2.84	4.80	---	---	3.49	9.00	9.53	0.60	2.58	2.90	2.80	11.80	13.30	95	3.49	A	1288	A++	7.14	9.00	443
	2.0+5.0+5.0	1.50	3.75	3.75	---	---	3.14	9.00	9.27	0.59	2.52	2.66	2.69	11.60	12.20	95	3.58	A	1259	A++	7.21	9.00	439
	2.0+5.0+6.0	1.38	3.46	4.15	---	---	3.35	9.00	9.70	0.56	2.51	2.91	2.70	11.50	13.40	95	3.58	A	1256	A++	7.23	9.00	440
	2.0+5.0+7.1	1.28	3.19	4.53	---	---	3.53	9.00	9.72	0.60	2.51	2.92	2.80	11.50	13.40	95	3.59	A	1254	A++	7.23	9.00	440
	2.0+6.0+6.0	1.29	3.86	3.86	---	---	3.53	9.00	10.20	0.60	2.47	3.25	2.80	11.40	15.00	95	3.64	A	1237	A++	7.25	9.00	435
	2.0+6.0+7.1	1.19	3.58	4.23	---	---	3.70	9.00	10.65	0.64	2.47	3.60	3.00	11.40	16.60	95	3.64	A	1236	A++	7.26	9.00	435
	2.5+2.5+2.5	2.50	2.50	2.50	---	---	2.48	7.50	7.87	0.50	1.93	2.10	2.27	8.90	9.70	95	3.89	A	964	A++	7.26	7.50	363
	2.5+2.5+3.5	2.35	2.35	3.29	---	---	2.63	8.00	8.44	0.52	2.15	2.39	2.40	9.90	11.00	95	3.72	A	1076	A++	7.17	8.00	391
	2.5+2.5+4.2	2.17	2.17	3.65	---	---	2.73	8.00	8.65	0.52	2.15	2.50	2.40	9.90	11.50	95	3.72	A	1075	A++	7.18	8.00	391
	2.5+2.5+5.0	2.13	2.13	4.25	---	---	2.85	8.50	8.84	0.56	2.33	2.52	2.57	10.70	11.60	95	3.65	A	1166	A++	7.19	8.50	415
	2.5+2.5+6.0	2.05	2.05	4.91	---	---	2.99	9.00	9.37	0.56	2.62	2.83	2.57	12.00	13.00	95	3.44	A	1310	A++	7.08	9.00	449
	2.5+2.5+7.1	1.86	1.86	5.28	---	---	3.32	9.00	9.58	0.57	2.62	2.96	2.70	12.00	13.60	95	3.44	A	1308	A++	7.11	9.00	447
	2.5+3.5+3.5	2.11	2.95	2.95	---	---	2.77	8.00	8.68	0.55	2.14	2.51	2.53	9.90	11.50	95	3.73	A	1072	A++	7.19	8.00	392
	2.5+3.5+4.2	2.08	2.92	3.50	---	---	2.88	8.50	8.69	0.55	2.42	2.51	2.53	11.10	11.50	95	3.51	A	1211	A++	7.07	8.50	425
	2.5+3.5+5.0	2.05	2.86	4.09	---	---	2.99	9.00	8.89	0.59	2.62	2.52	2.69	12.00	11.60	95	3.44	A	1308	A++	7.11	9.00	447
	2.5+3.5+6.0	1.88	2.63	4.50	---	---	3.14	9.00	9.51	0.59	2.58	2.90	2.69	11.80	13.30	95	3.49	A	1289	A++	7.14	9.00	442
	2.5+3.5+7.1	1.72	2.40	4.88	---	---	3.33	9.00	9.53	0.57	2.57	2.90	2.70	11.80	13.30	95	3.50	A	1287	A++	7.14	9.00	443
	2.5+4.2+4.2	2.06	3.47	3.47	---	---	2.98	9.00	8.71	0.59	2.72	2.51	2.69	12.50	11.50	95	3.30	A	1362	A++	6.98	9.00	456
	2.5+4.2+5.0	1.92	3.23	3.85	---	---	3.10	9.00	9.10	0.59	2.58	2.64	2.69	11.90	12.20	95	3.48	A	1291	A++	7.13	9.00	442
	2.5+4.2+6.0	1.77	2.98	4.25	---	---	3.32	9.00	9.52	0.57	2.58	2.90	2.70	11.80	13.30	95	3.49	A	1288	A++	7.14	9.00	443
	2.5+4.2+7.1	1.63	2.74	4.63	---	---	3.50	9.00	9.54	0.60	2.57	2.90	2.80	11.80	13.40	95	3.50	A	1286	A++	7.15	9.00	443
	2.5+5.0+5.0	1.80	3.60	3.60	---	---	3.35	9.00	9.28	0.56	2.51	2.66	2.70	11.60	12.20	95	3.58	A	1257	A++	7.22	9.00	440
2.5+5.0+6.0	1.67	3.33	4.00	---	---	3.53	9.00	9.72	0.60	2.51	2.92	2.80	11.50	13.40	95	3.59	A	1254	A++	7.23	9.00	440	
2.5+5.0+7.1	1.54	3.08	4.38	---	---	3.53	9.00	9.73	0.60	2.48	2.92	2.80	11.40	13.40	95	3.64	A	1238	A++	7.25	9.00	435	
2.5+6.0+6.0	1.55	3.72	3.72	---	---	3.53	9.00	10.22	0.60	2.47	3.25	2.80	11.40	15.00	95	3.64	A	1236	A++	7.26	9.00	435	
2.5+6.0+7.1	1.44	3.46	4.10	---	---	3.71	9.00	10.66	0.64	2.47	3.60	3.00	11.40	16.60	95	3.64	A	1235	A++	7.26	9.00	435	
3.5+3.5+3.5	2.90	2.90	2.90	---	---	2.92	8.70	8.83	0.59	2.50	2.57	2.69	11.50	11.80	95	3.48	A	1251	A++	7.07	8.70	432	
3.5+3.5+4.2	2.81	2.81	3.38	---	---	3.02	9.00	8.84	0.59	2.68	2.57	2.69	12.30	11.90	95	3.36	A	1341	A++	7.01	9.00	451	
3.5+3.5+5.0	2.63	2.63	3.75	---	---	3.14	9.00	9.03	0.62	2.58	2.59	2.82	11.80	11.90	95	3.49	A	1288	A++	7.14	9.00	443	
3.5+3.5+6.0	2.42	2.42	4.15	---	---	3.33	9.00	9.56	0.57	2.57	2.90	2.70	11.80	13.40	95	3.50	A	1285	A++	7.15	9.00	443	
3.5+3.5+7.1	2.23	2.23	4.53	---	---	3.50	9.00	9.58	0.60	2.57	2.90	2.80	11.80	13.40	95	3.51	A	1283	A++	7.16	9.00	443	
3.5+4.2+4.2	2.65	3.18	3.18	---	---	3.13	9.00	9.05	0.62	2.68	2.69	2.82	12.30	12.40	95	3.36	A	1340	A++	7.01	9.00	451	
3.5+4.2+5.0	2.48	2.98	3.54	---	---	3.33	9.00	9.25	0.57	2.57	2.71	2.70	11.80	12.50	95	3.50	A	1287	A++	7.15	9.00	443	
3.5+4.2+6.0	2.30	2.76	3.94	---	---	3.50	9.00	9.57	0.60	2.57	2.90	2.80	11.80	13.40	95	3.51	A	1283	A++	7.16	9.00	443	
3.5+4.2+7.1	2.13	2.55	4.32	---	---	3.67	9.00	10.04	0.64	2.56	3.23	3.00	11.80	14.90	95	3.51	A	1282	A++	7.17	9.00	444	
3.5+5.0+5.0	2.33	3.33	3.33	---	---	3.53	9.00	9.22	0.60	2.48	2.60	2.80	11.40	11.90	95	3.63	A	1238	A++	7.25	9.00	435	
3.5+5.0+6.0	2.17	3.10	3.72	---	---	3.53	9.00	9.76	0.60	2.47	2.92	2.80	11.40	13.40	95	3.64	A	1235	A++	7.26	9.00	435	
3.5+5.0+7.1	2.02	2.88	4.10	---	---	3.71	9.00	10.15	0.64	2.47	3.19	3.00	11.30	14.60	95	3.65	A	1234	A++	7.29	9.00	434	
3.5+6.0+6.0	2.03	3.48	3.48	---	---	3.71	9.00	10.61	0.64	2.47	3.54	3.00	11.30	16.30	95	3.65	A						

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
5MXM90N2V1B9	1.5+1.5+2.0+6.0	1.23	1.23	1.64	4.91	---	2.99	9.00	9.72	0.56	2.36	2.75	2.57	10.90	12.60	95	3.81	A	1181	A++	7.46	9.00	424
	1.5+1.5+2.0+7.1	1.12	1.12	1.49	5.28	---	3.16	9.00	10.05	0.60	2.36	2.95	2.74	10.90	13.60	95	3.81	A	1180	A++	7.47	9.00	424
	1.5+1.5+2.5+2.5	1.41	1.41	2.34	2.34	---	2.55	7.50	8.16	0.50	1.74	2.02	2.27	8.00	9.30	95	4.31	A	871	A++	7.63	7.50	345
	1.5+1.5+2.5+3.5	1.33	1.33	2.22	3.11	---	2.70	8.00	8.79	0.53	1.95	2.31	2.44	9.00	10.60	95	4.11	A	974	A++	7.54	8.00	374
	1.5+1.5+2.5+4.2	1.31	1.31	2.19	3.68	---	2.80	8.50	9.14	0.53	2.17	2.49	2.44	10.00	11.40	95	3.91	A	1087	A++	7.47	8.50	401
	1.5+1.5+2.5+5.0	1.24	1.24	2.07	4.14	---	2.92	8.70	9.49	0.56	2.23	2.62	2.57	10.30	12.10	95	3.90	A	1115	A++	7.51	8.70	410
	1.5+1.5+2.5+6.0	1.17	1.17	1.96	4.70	---	3.07	9.00	9.84	0.56	2.36	2.81	2.57	10.90	13.00	95	3.81	A	1180	A++	7.47	9.00	424
	1.5+1.5+2.5+7.1	1.07	1.07	1.79	5.07	---	3.23	9.00	10.16	0.60	2.36	3.01	2.74	10.80	13.90	95	3.82	A	1179	A++	7.47	9.00	424
	1.5+1.5+3.5+3.5	1.28	1.28	2.98	2.98	---	2.85	8.50	9.27	0.53	2.17	2.55	2.44	10.00	11.70	95	3.92	A	1085	A++	7.48	8.50	401
	1.5+1.5+3.5+4.2	1.26	1.26	2.94	3.53	---	2.95	9.00	9.39	0.56	2.41	2.61	2.57	11.10	12.00	95	3.73	A	1206	A++	7.40	9.00	428
	1.5+1.5+3.5+5.0	1.17	1.17	2.74	3.91	---	3.07	9.00	9.74	0.59	2.36	2.75	2.69	10.80	12.70	95	3.82	A	1180	A++	7.47	9.00	424
	1.5+1.5+3.5+6.0	1.08	1.08	2.52	4.32	---	3.21	9.00	10.18	0.59	2.36	3.02	2.69	10.80	13.90	95	3.82	A	1178	A++	7.51	9.00	423
	1.5+1.5+3.5+7.1	0.99	0.99	2.32	4.70	---	3.42	9.00	10.20	0.56	2.35	3.02	2.70	10.80	13.90	95	3.82	A	1177	A++	7.52	9.00	423
	1.5+1.5+4.2+4.2	1.18	1.18	3.32	3.32	---	3.05	9.00	9.61	0.59	2.41	2.74	2.69	11.10	12.60	95	3.73	A	1206	A++	7.40	9.00	428
	1.5+1.5+4.2+5.0	1.11	1.11	3.10	3.69	---	3.17	9.00	9.75	0.59	2.36	2.75	2.69	10.80	12.70	95	3.82	A	1179	A++	7.48	9.00	424
	1.5+1.5+4.2+6.0	1.02	1.02	2.86	4.09	---	3.41	9.00	10.19	0.56	2.35	3.02	2.70	10.80	13.90	95	3.82	A	1177	A++	7.51	9.00	423
	1.5+1.5+4.2+7.1	0.94	0.94	2.64	4.47	---	3.60	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95	3.83	A	1176	A++	7.52	9.00	423
	1.5+1.5+5.0+5.0	1.04	1.04	3.46	3.46	---	3.43	9.00	9.97	0.56	2.31	2.83	2.70	10.60	13.00	95	3.90	A	1155	A++	7.57	9.00	418
	1.5+1.5+5.0+6.0	0.96	0.96	3.21	3.86	---	3.44	9.00	10.42	0.56	2.31	3.10	2.70	10.60	14.20	95	3.90	A	1153	A++	7.58	9.00	418
	1.5+1.5+5.0+7.1	0.89	0.89	2.98	4.23	---	3.62	9.00	10.73	0.60	2.30	3.30	2.80	10.60	15.20	95	3.90	A	1152	A++	7.59	9.00	418
	1.5+1.5+6.0+6.0	0.90	0.90	3.60	3.60	---	3.62	9.00	10.74	0.60	2.30	3.31	2.80	10.60	15.20	95	3.91	A	1152	A++	7.59	9.00	418
	1.5+2.0+2.0+2.0	1.50	2.00	2.00	2.00	---	2.48	7.50	7.89	0.47	1.74	1.91	2.15	8.00	8.80	95	4.30	A	872	A++	7.59	7.50	346
	1.5+2.0+2.0+2.5	1.41	1.88	1.88	2.34	---	2.55	7.50	8.15	0.50	1.74	2.02	2.27	8.00	9.30	95	4.30	A	871	A++	7.62	7.50	345
	1.5+2.0+2.0+3.5	1.33	1.78	1.78	3.11	---	2.70	8.00	8.78	0.53	1.95	2.30	2.44	9.00	10.60	95	4.10	A	975	A++	7.54	8.00	373
	1.5+2.0+2.0+4.2	1.31	1.75	1.75	3.68	---	2.80	8.50	9.12	0.53	2.18	2.49	2.44	10.00	11.40	95	3.91	A	1088	A++	7.46	8.50	401
	1.5+2.0+2.0+5.0	1.24	1.66	1.66	4.14	---	2.92	8.70	9.48	0.56	2.23	2.62	2.57	10.30	12.00	95	3.90	A	1116	A++	7.51	8.70	410
	1.5+2.0+2.0+6.0	1.17	1.57	1.57	4.70	---	3.07	9.00	9.94	0.56	2.36	2.88	2.57	10.90	13.20	95	3.81	A	1181	A++	7.46	9.00	424
	1.5+2.0+2.0+7.1	1.07	1.43	1.43	5.07	---	3.23	9.00	10.26	0.60	2.36	3.08	2.74	10.90	14.20	95	3.81	A	1180	A++	7.47	9.00	424
	1.5+2.0+2.5+2.5	1.41	1.88	2.35	2.35	---	2.63	8.00	8.52	0.50	1.95	2.19	2.27	9.00	10.10	95	4.10	A	976	A++	7.53	8.00	373
	1.5+2.0+2.5+3.5	1.26	1.68	2.11	2.95	---	2.77	8.00	9.02	0.53	1.95	2.42	2.44	9.00	11.20	95	4.11	A	974	A++	7.54	8.00	374
	1.5+2.0+2.5+4.2	1.25	1.67	2.08	3.50	---	2.88	8.50	9.36	0.56	2.17	2.61	2.57	10.00	12.00	95	3.91	A	1087	A++	7.47	8.50	401
	1.5+2.0+2.5+5.0	1.23	1.64	2.05	4.09	---	2.99	9.00	9.49	0.56	2.36	2.62	2.57	10.90	12.10	95	3.81	A	1182	A++	7.46	9.00	424
	1.5+2.0+2.5+6.0	1.13	1.50	1.88	4.50	---	3.14	9.00	10.05	0.59	2.36	2.95	2.69	10.90	13.60	95	3.81	A	1180	A++	7.47	9.00	424
	1.5+2.0+2.5+7.1	1.03	1.37	1.72	4.88	---	3.41	9.00	10.16	0.56	2.36	3.01	2.70	10.80	13.90	95	3.82	A	1179	A++	7.47	9.00	424
	1.5+2.0+3.5+3.5	1.24	1.66	2.90	2.90	---	2.92	8.70	9.38	0.56	2.28	2.61	2.57	10.50	12.00	95	3.82	A	1138	A++	7.42	8.70	416
	1.5+2.0+3.5+4.2	1.21	1.61	2.81	3.38	---	3.02	9.00	9.60	0.56	2.41	2.74	2.57	11.10	12.60	95	3.73	A	1206	A++	7.40	9.00	428
	1.5+2.0+3.5+5.0	1.13	1.50	2.63	3.75	---	3.14	9.00	9.74	0.59	2.36	2.75	2.69	10.80	12.70	95	3.82	A	1180	A++	7.47	9.00	424
	1.5+2.0+3.5+6.0	1.04	1.38	2.42	4.15	---	3.41	9.00	10.18	0.56	2.36	3.02	2.70	10.80	13.90	95	3.82	A	1178	A++	7.51	9.00	423
	1.5+2.0+3.5+7.1	0.96	1.28	2.23	4.53	---	3.59	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95	3.82	A	1177	A++	7.52	9.00	423
	1.5+2.0+4.2+4.2	1.13	1.51	3.18	3.18	---	3.13	9.00	9.61	0.59	2.41	2.74	2.69	11.10	12.60	95	3.73	A	1206	A++	7.40	9.00	428
	1.5+2.0+4.2+5.0	1.06	1.42	2.98	3.54	---	3.41	9.00	9.75	0.56	2.36	3.02	2.70	10.80	12.70	95	3.82	A	1179	A++	7.48	9.00	424
	1.5+2.0+4.2+6.0	0.99	1.31	2.76	3.94	---	3.41	9.00	10.19	0.56	2.35	3.02	2.70	10.80	13.90	95	3.82	A	1177	A++	7.51	9.00	423
1.5+2.0+4.2+7.1	0.91	1.22	2.55	4.32	---	3.60	9.00	10.69	0.60	2.35	3.36	2.80	10.80	15.50	95	3.83	A	1176	A++	7.52	9.00	423	
1.5+2.0+5.0+5.0	1.00	1.33	3.33	3.33	---	3.43	9.00	9.97	0.56	2.31	2.83	2.70	10.60	13.00	95	3.90	A	1155	A++	7.57	9.00	418	
1.5+2.0+5.0+6.0	0.93	1.24	3.10	3.72	---	3.62	9.00	10.42	0.60	2.31	3.10	2.80	10.60	14.20	95	3.90	A	1153	A++	7.58	9.00	418	
1.5+2.0+5.0+7.1	0.87	1.15	2.88	4.10	---	3.80	9.00	10.73	0.63	2.30	3.30	3.00	10.60	15.20	95	3.90	A	1152	A++	7.59	9.00	418	
1.5+2.0+6.0+6.0	0.87	1.16	3.48	3.48	---	3.80	9.00	10.74	0.63	2.30	3.31	3.00	10.60	15.20	95	3.91	A	1152	A++	7.59	9.00	418	
1.5+2.5+2.5+2.5	1.33	2.22	2.22	2.22	---	2.70	8.00	8.77	0.53	1.95	2.30	2.44	9.00	10.60	95	4.10	A	976	A++	7.53	8.00	373	
1.5+2.5+2.5+3.5	1.28	2.13	2.13	2.98	---	2.85	8.50	9.25	0.53	2.17	2.55	2.44	10.00	11.70	95	3.91	A	1087	A++	7.47	8.50	401	
1.5+2.5+2.5+4.2	1.26	2.10	2.10	3.53	---	2.95	9.00	9.37	0.56	2.42	2.61	2.57	11.10	12.00	95	3.72	A	1209	A++	7.38	9.00	428	
1.5+2.5+2.5+5.0	1.17	1.96	1.96	3.91	---	3.07	9.00	9.72	0.59	2.36	2.75	2.69	10.90	12.60	95	3.81	A	1181	A++	7.46	9.00	424	
1.5+2.5+2.5+6.0	1.08	1.80	1.80	4.32	---	3.21	9.00	10.16	0.59	2.36	3.01	2.69	10.80	13.90	95	3.82	A	1179	A++	7.47	9.00	424	
1.5+2.5+2.5+7.1	0.99	1.65	1.65	4.70	---	3.41	9.00	10.18	0.56	2.36	3.01	2.70	10.80	13.90	95	3.82	A	1178	A++	7.51	9.00	423	
1.5+2.5+3.5+3.5	1.23	2.05	2.86	2.86	---	2.99	9.00	9.39	0.56	2.41	2.61	2.57	11.10	12.00	95	3.73	A	1206	A++	7.40	9.00	428	
1.5+2.5+3.5+4.2	1.15	1.92	2.69	3.23	---	3.10	9.00	9.51	0.59	2.41	2.68	2.69	11.10	12.30	95	3.73	A	1205	A++	7.40	9.00	428	
1.5+2.5+3.5+5.0	1.08	1.80	2.52	3.60	---	3.21	9.00	9.75	0.59	2.36	2.75	2.69	10.80	12.70	95	3.82	A	1179	A++	7.50	9.00	423	
1.5+2.5+3.5+6.0	1.00	1.67	2.33	4.00	---	3.41	9.00	10.19	0.56</														

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
5MXM90N2V1B9	2.0+2.0+2.0+5.0	1.64	1.64	1.64	4.09	---	2.99	9.00	9.59	0.56	2.37	2.68	2.57	10.90	12.40	95	3.80	A	1183	A++	7.45	9.00	424
	2.0+2.0+2.0+6.0	1.50	1.50	1.50	4.50	---	3.14	9.00	10.04	0.60	2.36	2.95	2.74	10.90	13.60	95	3.81	A	1181	A++	7.46	9.00	424
	2.0+2.0+2.0+7.1	1.37	1.37	1.37	4.88	---	3.41	9.00	10.26	0.56	2.36	3.08	2.70	10.90	14.20	95	3.81	A	1180	A++	7.47	9.00	424
	2.0+2.0+2.5+2.5	1.73	1.73	2.17	2.17	---	2.70	7.80	8.75	0.53	1.88	2.30	2.44	8.70	10.60	95	4.15	A	940	A++	7.55	7.80	366
	2.0+2.0+2.5+3.5	1.70	1.70	2.13	2.98	---	2.85	8.50	9.24	0.53	2.18	2.55	2.44	10.00	11.70	95	3.91	A	1088	A++	7.46	8.50	401
	2.0+2.0+2.5+4.2	1.68	1.68	2.10	3.53	---	2.95	9.00	9.36	0.56	2.42	2.61	2.57	11.10	12.00	95	3.72	A	1210	A++	7.38	9.00	428
	2.0+2.0+2.5+5.0	1.57	1.57	1.96	3.91	---	3.07	9.00	9.71	0.59	2.36	2.75	2.69	10.90	12.60	95	3.81	A	1182	A++	7.46	9.00	424
	2.0+2.0+2.5+6.0	1.44	1.44	1.80	4.32	---	3.21	9.00	10.15	0.60	2.36	3.01	2.74	10.90	13.90	95	3.81	A	1180	A++	7.47	9.00	424
	2.0+2.0+2.5+7.1	1.32	1.32	1.65	4.70	---	3.41	9.00	10.16	0.56	2.36	3.01	2.70	10.80	13.90	95	3.82	A	1179	A++	7.47	9.00	424
	2.0+2.0+3.5+3.5	1.64	1.64	2.86	2.86	---	2.99	9.00	9.38	0.56	2.41	2.61	2.57	11.10	12.00	95	3.73	A	1207	A++	7.39	9.00	428
	2.0+2.0+3.5+4.2	1.54	1.54	2.69	3.23	---	3.10	9.00	9.60	0.59	2.41	2.74	2.69	11.10	12.60	95	3.73	A	1206	A++	7.40	9.00	428
	2.0+2.0+3.5+5.0	1.44	1.44	2.52	3.60	---	3.21	9.00	9.74	0.59	2.36	2.75	2.69	10.80	12.70	95	3.82	A	1180	A++	7.47	9.00	424
	2.0+2.0+3.5+6.0	1.33	1.33	2.33	4.00	---	3.41	9.00	10.18	0.56	2.36	3.02	2.70	10.80	13.90	95	3.82	A	1178	A++	7.51	9.00	423
	2.0+2.0+3.5+7.1	1.23	1.23	2.16	4.38	---	3.59	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95	3.82	A	1177	A++	7.52	9.00	423
	2.0+2.0+4.2+4.2	1.45	1.45	3.05	3.05	---	3.20	9.00	9.61	0.59	2.41	2.74	2.69	11.10	12.60	95	3.73	A	1206	A++	7.40	9.00	428
	2.0+2.0+4.2+5.0	1.36	1.36	2.86	3.41	---	3.41	9.00	9.75	0.56	2.36	2.75	2.70	10.80	12.70	95	3.82	A	1179	A++	7.48	9.00	424
	2.0+2.0+4.2+6.0	1.27	1.27	2.66	3.80	---	3.59	9.00	10.19	0.60	2.35	3.02	2.80	10.80	13.90	95	3.82	A	1177	A++	7.51	9.00	423
	2.0+2.0+4.2+7.1	1.18	1.18	2.47	4.18	---	3.77	9.00	10.69	0.63	2.35	3.36	3.00	10.80	15.50	95	3.83	A	1176	A++	7.52	9.00	423
	2.0+2.0+5.0+5.0	1.29	1.29	3.21	3.21	---	3.43	9.00	9.97	0.56	2.31	2.83	2.70	10.60	13.00	95	3.90	A	1155	A++	7.57	9.00	418
	2.0+2.0+5.0+6.0	1.20	1.20	3.00	3.60	---	3.62	9.00	10.72	0.60	2.31	3.30	2.80	10.60	15.20	95	3.90	A	1153	A++	7.58	9.00	418
	2.0+2.5+2.5+2.5	1.68	2.11	2.11	2.11	---	2.77	8.00	8.99	0.53	1.95	2.42	2.44	9.00	11.20	95	4.10	A	976	A++	7.53	8.00	373
	2.0+2.5+2.5+3.5	1.66	2.07	2.07	2.90	---	2.92	8.70	9.36	0.56	2.28	2.61	2.57	10.50	12.00	95	3.81	A	1140	A++	7.41	8.70	415
	2.0+2.5+2.5+4.2	1.61	2.01	2.01	3.38	---	3.02	9.00	9.58	0.56	2.42	2.74	2.57	11.10	12.60	95	3.72	A	1209	A++	7.38	9.00	428
	2.0+2.5+2.5+5.0	1.50	1.88	1.88	3.75	---	3.14	9.00	9.72	0.59	2.36	2.75	2.69	10.90	12.60	95	3.81	A	1181	A++	7.46	9.00	424
	2.0+2.5+2.5+6.0	1.38	1.73	1.73	4.15	---	3.41	9.00	10.16	0.56	2.36	3.01	2.70	10.80	13.90	95	3.82	A	1179	A++	7.47	9.00	424
	2.0+2.5+2.5+7.1	1.28	1.60	1.60	4.53	---	3.59	9.00	10.18	0.60	2.36	3.01	2.80	10.80	13.90	95	3.82	A	1178	A++	7.51	9.00	423
	2.0+2.5+3.5+3.5	1.57	1.96	2.74	2.74	---	3.07	9.00	9.50	0.59	2.41	2.68	2.69	11.10	12.30	95	3.73	A	1206	A++	7.40	9.00	428
	2.0+2.5+3.5+4.2	1.48	1.84	2.58	3.10	---	3.17	9.00	9.51	0.59	2.41	2.68	2.69	11.10	12.30	95	3.73	A	1205	A++	7.40	9.00	428
	2.0+2.5+3.5+5.0	1.38	1.73	2.42	3.46	---	3.41	9.00	9.75	0.56	2.36	2.75	2.70	10.80	12.70	95	3.82	A	1179	A++	7.50	9.00	423
	2.0+2.5+3.5+6.0	1.29	1.61	2.25	3.86	---	3.59	9.00	10.19	0.60	2.35	3.02	2.80	10.80	13.90	95	3.82	A	1177	A++	7.51	9.00	423
	2.0+2.5+3.5+7.1	1.19	1.49	2.09	4.23	---	3.60	9.00	10.70	0.60	2.35	3.36	2.80	10.80	15.50	95	3.83	A	1176	A++	7.52	9.00	423
	2.0+2.5+4.2+4.2	1.40	1.74	2.93	2.93	---	3.39	9.00	9.62	0.56	2.41	2.74	2.70	11.10	12.60	95	3.74	A	1205	A++	7.40	9.00	429
	2.0+2.5+4.2+5.0	1.31	1.64	2.76	3.28	---	3.41	9.00	9.76	0.56	2.36	2.75	2.70	10.80	12.70	95	3.82	A	1178	A++	7.51	9.00	423
	2.0+2.5+4.2+6.0	1.22	1.53	2.57	3.67	---	3.60	9.00	10.69	0.60	2.35	3.36	2.80	10.80	15.50	95	3.83	A	1176	A++	7.52	9.00	423
	2.0+2.5+5.0+5.0	1.24	1.55	3.10	3.10	---	3.62	9.00	9.98	0.60	2.31	2.83	2.80	10.60	13.00	95	3.90	A	1154	A++	7.58	9.00	418
	2.0+2.5+5.0+6.0	1.16	1.45	2.90	3.48	---	3.80	9.00	10.72	0.63	2.30	3.30	3.00	10.60	15.20	95	3.90	A	1152	A++	7.59	9.00	418
	2.0+3.5+3.5+3.5	1.44	2.52	2.52	2.52	---	3.21	9.00	9.53	0.63	2.41	2.68	2.86	11.10	12.30	95	3.74	A	1203	A++	7.41	9.00	429
	2.0+3.5+3.5+4.2	1.36	2.39	2.39	2.86	---	3.39	9.00	9.54	0.56	2.40	2.68	2.70	11.10	12.30	95	3.74	A	1202	A++	7.42	9.00	429
	2.0+3.5+3.5+5.0	1.29	2.25	2.25	3.21	---	3.60	9.00	9.78	0.60	2.35	2.75	2.80	10.80	12.70	95	3.83	A	1176	A++	7.52	9.00	423
	2.0+3.5+3.5+6.0	1.20	2.10	2.10	3.60	---	3.60	9.00	10.62	0.60	2.35	3.29	2.80	10.80	15.20	95	3.83	A	1174	A++	7.53	9.00	423
	2.0+3.5+4.2+4.2	1.29	2.27	2.72	2.72	---	3.57	9.00	9.55	0.60	2.40	2.68	2.80	11.10	12.30	95	3.74	A	1202	A++	7.42	9.00	429
	2.0+3.5+4.2+5.0	1.22	2.14	2.57	3.06	---	3.60	9.00	10.21	0.60	2.35	3.02	2.80	10.80	13.90	95	3.83	A	1176	A++	7.52	9.00	423
	2.0+3.5+5.0+5.0	1.16	2.03	2.90	2.90	---	3.80	9.00	10.53	0.63	2.30	3.17	3.00	10.60	14.60	95	3.91	A	1152	A++	7.59	9.00	418
	2.0+4.2+4.2+4.2	1.23	2.59	2.59	2.59	---	3.57	9.00	9.56	0.60	2.40	2.68	2.80	11.00	12.40	95	3.75	A	1201	A++	7.42	9.00	429
	2.0+4.2+4.2+5.0	1.17	2.45	2.45	2.92	---	3.78	9.00	10.22	0.63	2.35	3.02	3.00	10.80	13.90	95	3.83	A	1175	A++	7.53	9.00	423
	2.5+2.5+2.5+2.5	2.13	2.13	2.13	2.13	---	2.85	8.50	9.23	0.53	2.18	2.55	2.44	10.00	11.70	95	3.90	A	1089	A++	7.46	8.50	401
	2.5+2.5+2.5+3.5	2.05	2.05	2.05	2.86	---	2.99	9.00	9.37	0.56	2.42	2.61	2.57	11.10	12.00	95	3.72	A	1208	A++	7.39	9.00	428
	2.5+2.5+2.5+4.2	1.92	1.92	1.92	3.23	---	3.10	9.00	9.59	0.59	2.42	2.74	2.69	11.10	12.60	95	3.73	A	1208	A++	7.39	9.00	428
	2.5+2.5+2.5+5.0	1.80	1.80	1.80	3.60	---	3.21	9.00	9.73	0.59	2.36	2.75	2.69	10.90	12.60	95	3.81	A	1180	A++	7.47	9.00	424
	2.5+2.5+2.5+6.0	1.67	1.67	1.67	4.00	---	3.41	9.00	10.17	0.56	2.36	3.01	2.70	10.80	13.90	95	3.82	A	1179	A++	7.51	9.00	423
2.5+2.5+2.5+7.1	1.54	1.54	1.54	4.38	---	3.59	9.00	10.19	0.60	2.36	3.02	2.80	10.80	13.90	95	3.82	A	1178	A++	7.51	9.00	423	
2.5+2.5+3.5+3.5	1.88	1.88	2.63	2.63	---	3.14	9.00	9.51	0.59	2.41	2.68	2.69	11.10	12.30	95	3.73	A	1205	A++	7.40	9.00	428	
2.5+2.5+3.5+4.2	1.77	1.77	2.48	2.98	---	3.39	9.00	9.52	0.56	2.41	2.68	2.70	11.10	12.30	95	3.74	A	1204	A++	7.41	9.00	429	
2.5+2.5+3.5+5.0	1.67	1.67	2.33	3.33	---	3.41	9.00	9.76	0.56	2.36	2.75	2.70	10.80	12.70	95	3.82	A	1178	A++	7.51	9.00	423	
2.5+2.5+3.5+6.0	1.55	1.55	2.17	3.72	---	3.60	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95	3.83	A	1176	A++	7.52	9.00	423	
2.5+2.5+3.5+7.1	1.44	1.44	2.02	4.10	---	3.78	9.00	10.71	0.63	2.35	3.36	3.00	10.80	15.50	95	3.83	A	1175	A++	7.52	9.00	423	
2.5+2.5+4.2+4.2	1.68	1.68	2.82	2.82	---	3.39	9.00																

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
	1.5+1.5+1.5+2.0+2.0	1.41	1.41	1.41	1.88	1.88	2.63	8.00	8.48	0.51	1.85	2.03	2.32	8.50	9.40	95	4.33	A	923	A++	7.78	8.00	363
	1.5+1.5+1.5+2.0+2.5	1.33	1.33	1.33	1.78	2.22	2.70	8.00	8.75	0.51	1.85	2.15	2.32	8.50	9.90	95	4.33	A	923	A++	7.79	8.00	363
	1.5+1.5+1.5+2.0+3.5	1.28	1.28	1.28	1.70	2.98	2.85	8.50	9.26	0.53	2.03	2.39	2.44	9.40	11.00	95	4.18	A	1017	A++	7.73	8.50	385
	1.5+1.5+1.5+2.0+4.2	1.26	1.26	1.26	1.68	3.53	2.95	9.00	9.63	0.53	2.26	2.58	2.44	10.40	11.90	95	3.98	A	1132	A++	7.64	9.00	413
	1.5+1.5+1.5+2.0+5.0	1.17	1.17	1.17	1.57	3.91	3.07	9.00	9.93	0.56	2.25	2.71	2.57	10.40	12.50	95	4.00	A	1126	A++	7.69	9.00	413
	1.5+1.5+1.5+2.0+6.0	1.08	1.08	1.08	1.44	4.32	3.21	9.00	10.17	0.57	2.25	2.84	2.61	10.30	13.10	95	4.00	A	1125	A++	7.72	9.00	412
	1.5+1.5+1.5+2.0+7.1	0.99	0.99	0.99	1.32	4.70	3.48	9.00	10.50	0.56	2.25	3.04	2.60	10.30	14.00	95	4.00	A	1125	A++	7.73	9.00	412
	1.5+1.5+1.5+2.5+2.5	1.26	1.26	1.26	2.11	2.11	2.77	8.00	9.01	0.53	1.84	2.27	2.44	8.50	10.40	95	4.34	A	922	A++	7.79	8.00	363
	1.5+1.5+1.5+2.5+3.5	1.24	1.24	1.24	2.07	2.90	2.92	8.70	9.51	0.53	2.13	2.51	2.44	9.80	11.60	95	4.08	A	1067	A++	7.73	8.70	397
	1.5+1.5+1.5+2.5+4.2	1.21	1.21	1.21	2.01	3.38	3.02	9.00	9.75	0.56	2.26	2.64	2.57	10.40	12.20	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+1.5+1.5+2.5+5.0	1.13	1.13	1.13	1.88	3.75	3.14	9.00	10.05	0.56	2.25	2.78	2.57	10.40	12.80	95	4.00	A	1125	A++	7.72	9.00	412
	1.5+1.5+1.5+2.5+6.0	1.04	1.04	1.04	1.73	4.15	3.29	9.00	10.39	0.60	2.25	2.98	2.74	10.30	13.70	95	4.00	A	1125	A++	7.73	9.00	412
	1.5+1.5+1.5+2.5+7.1	0.96	0.96	0.96	1.60	4.53	3.48	9.00	10.61	0.56	2.25	3.11	2.60	10.30	14.30	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+1.5+3.5+3.5	1.17	1.17	1.17	2.74	2.74	3.07	9.00	9.88	0.56	2.26	2.71	2.57	10.40	12.50	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+1.5+1.5+3.5+4.2	1.11	1.11	1.11	2.58	3.10	3.17	9.00	10.11	0.60	2.26	2.84	2.74	10.40	13.00	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+1.5+1.5+3.5+5.0	1.04	1.04	1.04	2.42	3.46	3.29	9.00	10.40	0.60	2.25	2.98	2.74	10.30	13.70	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+1.5+3.5+6.0	0.96	0.96	0.96	2.25	3.86	3.48	9.00	10.62	0.56	2.25	3.11	2.60	10.30	14.30	95	4.00	A	1124	A++	7.74	9.00	412
	1.5+1.5+1.5+3.5+7.1	0.89	0.89	0.89	2.09	4.23	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95	4.01	A	1123	A++	7.74	9.00	412
	1.5+1.5+1.5+4.2+4.2	1.05	1.05	1.05	2.93	2.93	3.27	9.00	10.22	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1129	A++	7.66	9.00	413
	1.5+1.5+1.5+4.2+5.0	0.99	0.99	0.99	2.76	3.28	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+1.5+4.2+6.0	0.92	0.92	0.92	2.57	3.67	3.67	9.00	10.62	0.59	2.25	3.12	2.80	10.30	14.30	95	4.01	A	1123	A++	7.74	9.00	412
	1.5+1.5+1.5+5.0+5.0	0.93	0.93	0.93	3.10	3.10	3.69	9.00	10.55	0.59	2.21	3.05	2.80	10.20	14.00	95	4.07	A	1107	A++	7.78	9.00	406
	1.5+1.5+1.5+5.0+6.0	0.87	0.87	0.87	2.90	3.48	3.69	9.00	10.77	0.59	2.21	3.19	2.80	10.20	14.60	95	4.07	A	1106	A++	7.79	9.00	406
	1.5+1.5+2.0+2.0+2.0	1.30	1.30	1.73	1.73	1.73	2.70	7.80	8.74	0.51	1.76	2.15	2.32	8.10	9.90	95	4.44	A	878	A++	7.84	7.80	348
	1.5+1.5+2.0+2.0+2.5	1.26	1.26	1.68	1.68	2.11	2.77	8.00	9.00	0.53	1.85	2.27	2.44	8.50	10.40	95	4.33	A	923	A++	7.79	8.00	363
	1.5+1.5+2.0+2.0+3.5	1.24	1.24	1.66	1.66	2.90	2.92	8.70	9.51	0.53	2.13	2.51	2.44	9.80	11.60	95	4.08	A	1067	A++	7.72	8.70	397
	1.5+1.5+2.0+2.0+4.2	1.21	1.21	1.61	1.61	3.38	3.02	9.00	9.74	0.56	2.26	2.64	2.57	10.40	12.20	95	3.98	A	1132	A++	7.64	9.00	413
	1.5+1.5+2.0+2.0+5.0	1.13	1.13	1.50	1.50	3.75	3.14	9.00	10.04	0.56	2.25	2.78	2.57	10.40	12.80	95	4.00	A	1125	A++	7.69	9.00	413
	1.5+1.5+2.0+2.0+6.0	1.04	1.04	1.38	1.38	4.15	3.29	9.00	10.39	0.60	2.25	2.98	2.74	10.30	13.70	95	4.00	A	1125	A++	7.72	9.00	412
	1.5+1.5+2.0+2.0+7.1	0.96	0.96	1.28	1.28	4.53	3.48	9.00	10.61	0.56	2.25	3.11	2.60	10.30	14.30	95	4.00	A	1125	A++	7.73	9.00	412
	1.5+1.5+2.0+2.5+2.5	1.28	1.28	1.70	2.13	2.13	2.85	8.50	9.25	0.53	2.06	2.39	2.44	9.50	11.00	95	4.12	A	1031	A++	7.71	8.50	391
	1.5+1.5+2.0+2.5+3.5	1.23	1.23	1.64	2.05	2.86	2.99	9.00	9.75	0.56	2.26	2.64	2.57	10.40	12.20	95	3.98	A	1132	A++	7.65	9.00	413
	1.5+1.5+2.0+2.5+4.2	1.15	1.15	1.54	1.92	3.23	3.10	9.00	9.98	0.56	2.26	2.77	2.57	10.40	12.70	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+1.5+2.0+2.5+5.0	1.08	1.08	1.44	1.80	3.60	3.21	9.00	10.16	0.60	2.25	2.84	2.74	10.40	13.10	95	4.00	A	1125	A++	7.72	9.00	412
	1.5+1.5+2.0+2.5+6.0	1.00	1.00	1.33	1.67	4.00	3.48	9.00	10.50	0.56	2.25	3.04	2.60	10.30	14.00	95	4.00	A	1125	A++	7.73	9.00	412
	1.5+1.5+2.0+2.5+7.1	0.92	0.92	1.23	1.54	4.38	3.67	9.00	10.61	0.59	2.25	3.11	2.80	10.30	14.30	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+2.0+3.5+3.5	1.13	1.13	1.50	2.63	2.63	3.14	9.00	10.10	0.56	2.26	2.84	2.57	10.40	13.00	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+1.5+2.0+3.5+4.2	1.06	1.06	1.42	2.48	2.98	3.24	9.00	10.22	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+1.5+2.0+3.5+5.0	1.00	1.00	1.33	2.33	3.33	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95	4.00	A	1124	A++	7.73	9.00	412
5MXM90N2V1B9	1.5+1.5+2.0+3.5+6.0	0.93	0.93	1.24	2.17	3.72	3.67	9.00	10.62	0.59	2.25	3.11	2.80	10.30	14.30	95	4.00	A	1124	A++	7.74	9.00	412
	1.5+1.5+2.0+3.5+7.1	0.87	0.87	1.15	2.02	4.10	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95	4.01	A	1123	A++	7.74	9.00	412
	1.5+1.5+2.0+4.2+4.2	1.01	1.01	1.34	2.82	2.82	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.98	A	1129	A++	7.66	9.00	413
	1.5+1.5+2.0+4.2+5.0	0.95	0.95	1.27	2.66	3.17	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+2.0+4.2+6.0	0.89	0.89	1.18	2.49	3.55	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95	4.01	A	1123	A++	7.74	9.00	412
	1.5+1.5+2.0+5.0+5.0	0.90	0.90	1.20	3.00	3.00	3.69	9.00	10.66	0.59	2.21	3.12	2.80	10.20	14.30	95	4.07	A	1107	A++	7.78	9.00	406
	1.5+1.5+2.5+2.5+2.5	1.24	1.24	2.07	2.07	2.07	2.92	8.70	9.50	0.53	2.14	2.51	2.44	9.80	11.60	95	4.07	A	1068	A++	7.72	8.70	397
	1.5+1.5+2.5+2.5+3.5	1.17	1.17	1.96	1.96	2.74	3.07	9.00	9.87	0.56	2.26	2.71	2.57	10.40	12.50	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+1.5+2.5+2.5+4.2	1.11	1.11	1.84	1.84	3.10	3.17	9.00	10.09	0.60	2.26	2.84	2.74	10.40	13.00	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+1.5+2.5+2.5+5.0	1.04	1.04	1.73	1.73	3.46	3.29	9.00	10.39	0.60	2.25	2.98	2.74	10.30	13.70	95	4.00	A	1125	A++	7.72	9.00	412
	1.5+1.5+2.5+2.5+6.0	0.96	0.96	1.61	1.61	3.86	3.48	9.00	10.61	0.56	2.25	3.11	2.60	10.30	14.30	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+2.5+2.5+7.1	0.89	0.89	1.49	1.49	4.23	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+1.5+2.5+3.5+3.5	1.08	1.08	1.80	2.52	2.52	3.21	9.00	10.22	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+1.5+2.5+3.5+4.2	1.02	1.02	1.70	2.39	2.86	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.99	A	1129	A++	7.66	9.00	413
	1.5+1.5+2.5+3.5+5.0	0.96	0.96	1.61	2.25	3.21	3.48	9.															

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
5MXM90N2V1B9	1.5+2.0+2.0+4.2+4.2	0.97	1.29	1.29	2.72	2.72	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.98	A	1129	A++	7.66	9.00	413
	1.5+2.0+2.0+4.2+5.0	0.92	1.22	1.22	2.57	3.06	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+2.0+2.0+5.0+5.0	0.87	1.16	1.16	2.90	2.90	3.69	9.00	10.77	0.59	2.21	3.19	2.80	10.20	14.60	95	4.07	A	1107	A++	7.78	9.00	406
	1.5+2.0+2.5+2.5+2.5	1.23	1.64	2.05	2.05	2.05	2.99	9.00	9.73	0.56	2.27	2.64	2.57	10.40	12.10	95	3.97	A	1133	A++	7.64	9.00	413
	1.5+2.0+2.5+2.5+3.5	1.13	1.50	1.88	1.88	2.63	3.14	9.00	10.09	0.56	2.26	2.84	2.57	10.40	13.00	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+2.0+2.5+2.5+4.2	1.06	1.42	1.77	1.77	2.98	3.24	9.00	10.20	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+2.0+2.5+2.5+5.0	1.00	1.33	1.67	1.67	3.33	3.48	9.00	10.39	0.56	2.25	2.98	2.60	10.30	13.70	95	4.00	A	1125	A++	7.72	9.00	412
	1.5+2.0+2.5+2.5+6.0	0.93	1.24	1.55	1.55	3.72	3.67	9.00	10.61	0.59	2.25	3.11	2.80	10.30	14.30	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+2.0+2.5+2.5+7.1	0.87	1.15	1.44	1.44	4.10	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+2.0+2.5+3.5+3.5	1.04	1.38	1.73	2.42	2.42	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+2.0+2.5+3.5+4.2	0.99	1.31	1.64	2.30	2.76	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.99	A	1129	A++	7.66	9.00	413
	1.5+2.0+2.5+3.5+5.0	0.93	1.24	1.55	2.17	3.10	3.67	9.00	10.40	0.59	2.25	2.98	2.80	10.30	13.70	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+2.0+2.5+3.5+6.0	0.87	1.16	1.45	2.03	3.48	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95	4.01	A	1123	A++	7.74	9.00	412
	1.5+2.0+2.5+4.2+4.2	0.94	1.25	1.56	2.63	2.63	3.65	9.00	10.23	0.60	2.26	2.90	2.80	10.40	13.40	95	3.99	A	1129	A++	7.67	9.00	413
	1.5+2.0+2.5+4.2+5.0	0.89	1.18	1.48	2.49	2.96	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.74	9.00	412
	1.5+2.0+3.5+3.5+3.5	0.96	1.29	2.25	2.25	2.25	3.47	9.00	10.24	0.56	2.26	2.91	2.70	10.40	13.40	95	3.99	A	1128	A++	7.67	9.00	413
	1.5+2.0+3.5+3.5+4.2	0.92	1.22	2.14	2.14	2.57	3.65	9.00	10.67	0.60	2.26	3.18	2.80	10.40	14.60	95	3.99	A	1128	A++	7.67	9.00	413
	1.5+2.0+3.5+3.5+5.0	0.87	1.16	2.03	2.03	2.90	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95	4.01	A	1123	A++	7.74	9.00	412
	1.5+2.0+3.5+4.2+4.2	0.88	1.17	2.05	2.45	2.45	3.65	9.00	10.77	0.60	2.26	3.25	2.80	10.40	14.90	95	3.99	A	1128	A++	7.68	9.00	413
	1.5+2.5+2.5+2.5+2.5	1.17	1.96	1.96	1.96	1.96	3.07	9.00	9.85	0.56	2.26	2.70	2.57	10.40	12.50	95	3.98	A	1132	A++	7.64	9.00	413
	1.5+2.5+2.5+2.5+3.5	1.08	1.80	1.80	1.80	2.52	3.21	9.00	10.21	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1131	A++	7.65	9.00	413
	1.5+2.5+2.5+2.5+4.2	1.02	1.70	1.70	1.70	2.86	3.46	9.00	10.21	0.56	2.26	2.90	2.70	10.40	13.40	95	3.98	A	1130	A++	7.66	9.00	413
	1.5+2.5+2.5+2.5+5.0	0.96	1.61	1.61	1.61	3.21	3.48	9.00	10.39	0.56	2.25	2.98	2.60	10.30	13.70	95	4.00	A	1125	A++	7.73	9.00	412
	1.5+2.5+2.5+2.5+6.0	0.90	1.50	1.50	1.50	3.60	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.73	9.00	412
	1.5+2.5+2.5+3.5+3.5	1.00	1.67	1.67	2.33	2.33	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.99	A	1129	A++	7.66	9.00	413
	1.5+2.5+2.5+3.5+4.2	0.95	1.58	1.58	2.22	2.66	3.47	9.00	10.23	0.56	2.26	2.90	2.70	10.40	13.40	95	3.99	A	1129	A++	7.67	9.00	413
	1.5+2.5+2.5+3.5+5.0	0.90	1.50	1.50	2.10	3.00	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.74	9.00	412
	1.5+2.5+2.5+4.2+4.2	0.91	1.51	1.51	2.54	2.54	3.65	9.00	10.66	0.60	2.26	3.18	2.80	10.40	14.60	95	3.99	A	1128	A++	7.67	9.00	413
	1.5+2.5+3.5+3.5+3.5	0.93	1.55	2.17	2.17	2.17	3.65	9.00	10.24	0.60	2.26	2.91	2.80	10.40	13.40	95	3.99	A	1128	A++	7.67	9.00	413
	1.5+2.5+3.5+3.5+4.2	0.89	1.48	2.07	2.07	2.49	3.65	9.00	10.77	0.60	2.25	3.25	2.80	10.40	14.90	95	3.99	A	1127	A++	7.68	9.00	413
	1.5+3.5+3.5+3.5+3.5	0.87	2.03	2.03	2.03	2.03	3.66	9.00	10.79	0.60	2.25	3.25	2.80	10.40	15.00	95	3.99	A	1126	A++	7.68	9.00	413
	2.0+2.0+2.0+2.0+2.0	1.70	1.70	1.70	1.70	1.70	2.85	8.50	9.24	0.53	2.06	2.39	2.44	9.50	11.00	95	4.12	A	1032	A++	7.70	8.50	391
	2.0+2.0+2.0+2.0+2.5	1.66	1.66	1.66	1.66	2.07	2.92	8.70	9.49	0.53	2.14	2.51	2.44	9.80	11.60	95	4.07	A	1069	A++	7.68	8.70	398
	2.0+2.0+2.0+2.0+3.5	1.57	1.57	1.57	1.57	2.74	3.07	9.00	9.85	0.56	2.26	2.70	2.57	10.40	12.50	95	3.98	A	1132	A++	7.64	9.00	413
	2.0+2.0+2.0+2.0+4.2	1.48	1.48	1.48	1.48	3.10	3.17	9.00	10.08	0.60	2.26	2.84	2.74	10.40	13.00	95	3.98	A	1132	A++	7.64	9.00	413
	2.0+2.0+2.0+2.0+5.0	1.38	1.38	1.38	1.38	3.46	3.29	9.00	10.38	0.60	2.25	2.98	2.74	10.40	13.70	95	4.00	A	1126	A++	7.69	9.00	413
	2.0+2.0+2.0+2.0+6.0	1.29	1.29	1.29	1.29	3.86	3.48	9.00	10.60	0.56	2.25	3.11	2.60	10.30	14.30	95	4.00	A	1125	A++	7.72	9.00	412
	2.0+2.0+2.0+2.0+7.1	1.19	1.19	1.19	1.19	4.23	3.67	9.00	10.71	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1125	A++	7.73	9.00	412
	2.0+2.0+2.0+2.5+2.5	1.64	1.64	1.64	2.05	2.05	2.99	9.00	9.73	0.56	2.27	2.64	2.57	10.40	12.10	95	3.97	A	1133	A++	7.63	9.00	413
	2.0+2.0+2.0+2.5+3.5	1.50	1.50	1.50	1.88	2.63	3.14	9.00	10.08	0.56	2.26	2.84	2.57	10.40	13.00	95	3.98	A	1132	A++	7.65	9.00	413
	2.0+2.0+2.0+2.5+4.2	1.42	1.42	1.42	1.77	2.98	3.24	9.00	10.20	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1131	A++	7.65	9.00	413
	2.0+2.0+2.0+2.5+5.0	1.33	1.33	1.33	1.67	3.33	3.48	9.00	10.38	0.56	2.25	2.98	2.60	10.40	13.70	95	4.00	A	1125	A++	7.72	9.00	412
	2.0+2.0+2.0+2.5+6.0	1.24	1.24	1.24	1.55	3.72	3.67	9.00	10.61	0.59	2.25	3.11	2.80	10.30	14.30	95	4.00	A	1125	A++	7.73	9.00	412
	2.0+2.0+2.0+2.5+7.1	1.15	1.15	1.15	1.44	4.10	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.73	9.00	412
	2.0+2.0+2.0+3.5+3.5	1.38	1.38	1.38	2.42	2.42	2.99	9.00	9.65	0.56	2.26	2.58	2.57	10.40	11.90	95	3.98	A	1130	A++	7.66	9.00	413
2.0+2.0+2.0+3.5+4.2	1.31	1.31	1.31	2.30	2.76	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	3.98	A	1130	A++	7.66	9.00	413	
2.0+2.0+2.0+3.5+5.0	1.24	1.24	1.24	2.17	3.10	3.67	9.00	10.40	0.59	2.25	2.98	2.80	10.30	13.70	95	4.00	A	1124	A++	7.73	9.00	412	
2.0+2.0+2.0+3.5+6.0	1.16	1.16	1.16	2.03	3.48	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.74	9.00	412	
2.0+2.0+2.0+4.2+4.2	1.25	1.25	1.25	2.63	2.63	3.65	9.00	10.22	0.60	2.26	2.90	2.80	10.40	13.40	95	3.98	A	1129	A++	7.66	9.00	413	
2.0+2.0+2.0+4.2+5.0	1.18	1.18	1.18	2.49	2.96	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	4.00	A	1124	A++	7.73	9.00	412	
2.0+2.0+2.5+2.5+2.5	1.57	1.57	1.96	1.96	1.96	3.07	9.00	9.85	0.56	2.27	2.70	2.57	10.40	12.50	95	3.97	A	1133	A++	7.64	9.00	413	
2.0+2.0+2.5+2.5+3.5	1.44	1.44	1.80	1.80	2.52	3.21	9.00	10.20	0.60	2.26	2.90	2.74	10.40	13.40	95	3.98	A	1131	A++	7.65	9.00	413	
2.0+2.0+2.5+2.5+4.2	1.36	1.36	1.70	1.70	2.86	3.46	9.00	9.87	0.56	2.26	2.71	2.70	10.40	12.50	95	3.98	A	1131	A++	7.65	9.00	413	
2.0+2.0+2.5+2.5+5.0	1.29	1.29	1.61	1.61	3.21	3.48	9.00	10.39	0.56	2.25	2.98	2.60	10.30	13.70	95	4.00	A	1125	A++	7.72	9.00	412	
2.0+2.0+2.5+2.5+6.0	1.20	1.20	1																				

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	label	Seasonal data			
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
5MXM90N2V1B9	1.5	1.90	---	---	---	---	1.28	1.90	4.15	0.28	0.53	1.31	1.29	2.43	5.98	95	3.59	---	---	---	---	---	---
	2.0	2.49	---	---	---	---	1.33	2.49	4.37	0.34	0.67	1.37	1.55	3.05	6.25	95	3.73	---	---	---	---	---	---
	2.5	3.11	---	---	---	---	1.39	3.11	4.84	0.36	0.88	1.47	1.64	4.04	6.71	95	3.53	---	---	---	---	---	---
	3.5	4.36	---	---	---	---	1.51	4.36	5.31	0.38	1.40	1.93	1.73	6.42	8.84	95	3.11	---	---	---	---	---	---
	4.2	5.23	---	---	---	---	1.56	5.23	6.16	0.40	1.63	2.06	1.82	7.45	9.42	95	3.22	---	---	---	---	---	---
	5.0	6.21	---	---	---	---	1.94	6.21	7.75	0.47	1.76	2.39	2.13	8.08	10.92	95	3.52	---	---	---	---	---	---
	6.0	7.46	---	---	---	---	2.23	7.46	9.05	0.58	2.25	2.86	2.66	10.32	13.09	95	3.31	---	---	---	---	---	---
	7.1	8.82	---	---	---	---	2.55	8.82	9.38	0.65	2.81	3.01	2.97	12.88	13.77	95	3.14	---	---	---	---	---	---
	1.5+1.5	1.85	1.85	---	---	---	1.51	3.70	7.47	0.37	0.67	1.83	1.68	3.10	8.40	95	5.50	A	A+	4.17	3.50	1157	0.32
	1.5+2.0	1.84	2.46	---	---	---	1.57	4.30	7.89	0.35	0.82	1.99	1.59	3.80	9.20	95	5.22	A	A+	4.18	3.50	1155	0.32
	1.5+2.5	1.84	3.06	---	---	---	1.72	4.90	8.03	0.37	0.99	2.03	1.68	4.60	9.40	95	4.96	A	A+	4.19	3.50	1153	0.32
	1.5+3.5	1.83	4.27	---	---	---	2.02	6.10	8.69	0.44	1.36	2.33	2.02	6.30	10.70	95	4.49	A	A+	4.24	3.80	1236	0.44
	1.5+4.2	1.84	5.16	---	---	---	2.23	7.00	8.98	0.42	1.64	2.39	1.94	7.50	11.00	95	4.28	A	A+	4.27	3.80	1228	0.43
	1.5+5.0	1.85	6.15	---	---	---	2.48	8.00	10.48	0.44	1.91	2.91	2.02	8.80	13.40	95	4.20	A	A+	4.25	4.50	1459	0.73
	1.5+6.0	1.80	7.20	---	---	---	2.87	9.00	10.74	0.46	2.29	3.03	2.20	10.50	13.90	95	3.94	A	A+	4.26	4.50	1456	0.72
	1.5+7.1	1.74	8.26	---	---	---	3.20	10.00	10.75	0.53	2.73	3.01	2.50	12.50	13.80	95	3.67	A	A+	4.27	4.50	1453	0.70
	2.0+2.0	2.45	2.45	---	---	---	1.72	4.90	8.03	0.37	0.99	2.03	1.68	4.60	9.40	95	4.96	A	A+	4.19	3.50	1153	0.32
	2.0+2.5	2.44	3.06	---	---	---	1.88	5.50	8.30	0.39	1.16	2.14	1.76	5.40	9.80	95	4.74	A	A+	4.19	3.50	1151	0.31
	2.0+3.5	2.44	4.26	---	---	---	2.17	6.70	8.83	0.47	1.56	2.38	2.15	7.20	10.90	95	4.30	A	A+	4.24	3.80	1235	0.43
	2.0+4.2	2.45	5.15	---	---	---	2.39	7.60	9.11	0.58	1.85	2.44	2.67	8.50	11.30	95	4.11	A	A+	4.27	3.80	1226	0.43
	2.0+5.0	2.43	6.07	---	---	---	2.71	8.50	10.74	0.43	2.10	3.03	2.10	9.70	13.90	95	4.05	A	A+	4.26	4.50	1457	0.73
	2.0+6.0	2.33	6.98	---	---	---	3.04	9.30	10.87	0.49	2.40	3.08	2.30	11.00	14.10	95	3.88	A	A+	4.27	4.50	1454	0.71
	2.0+7.1	2.20	7.80	---	---	---	3.36	10.00	11.01	0.56	2.71	3.12	2.60	12.50	14.40	95	3.69	A	A+	4.26	4.50	1458	0.69
	2.5+2.5	3.05	3.05	---	---	---	2.02	6.10	8.57	0.44	1.35	2.25	2.02	6.20	10.30	95	4.53	A	A+	4.20	3.50	1150	0.31
	2.5+3.5	3.04	4.26	---	---	---	2.33	7.30	9.22	0.56	1.77	2.55	2.58	8.10	11.70	95	4.13	A	A+	4.25	3.80	1233	0.43
	2.5+4.2	3.06	5.14	---	---	---	2.54	8.20	9.51	0.61	2.10	2.62	2.80	9.70	12.00	95	3.91	A	A+	4.28	3.80	1225	0.43
	2.5+5.0	3.00	6.00	---	---	---	2.87	9.00	10.74	0.46	2.28	3.02	2.20	10.50	13.90	95	3.95	A	A+	4.27	4.50	1454	0.73
	2.5+6.0	2.82	6.78	---	---	---	3.20	9.60	11.01	0.53	2.54	3.13	2.50	11.70	14.40	95	3.78	A	A+	4.25	4.50	1459	0.71
	2.5+7.1	2.60	7.40	---	---	---	3.52	10.00	11.27	0.59	2.70	3.24	2.80	12.40	14.90	95	3.70	A	A+	4.26	4.50	1456	0.69
	3.5+3.5	4.25	4.25	---	---	---	2.76	8.50	9.60	0.45	2.27	2.74	2.10	10.50	12.60	95	3.74	A	A+	4.14	4.50	1499	0.74
	3.5+4.2	4.09	4.91	---	---	---	2.91	9.00	10.26	0.48	2.45	3.00	2.20	11.30	13.80	95	3.67	A	A+	4.17	4.50	1486	0.73
	3.5+5.0	3.91	5.59	---	---	---	3.20	9.50	11.00	0.53	2.50	3.14	2.50	11.50	14.50	95	3.80	A	A+	4.16	5.20	1724	1.04
	3.5+6.0	3.68	6.32	---	---	---	3.36	10.00	11.25	0.56	2.72	3.26	2.60	12.50	15.00	95	3.68	A	A+	4.17	5.20	1720	1.02
	3.5+7.1	3.30	6.70	---	---	---	3.68	10.00	11.27	0.62	2.70	3.24	2.90	12.40	14.90	95	3.70	A	A+	4.18	5.20	1715	1.00
	4.2+4.2	4.75	4.75	---	---	---	3.06	9.50	10.05	0.50	2.60	2.81	2.40	12.00	12.90	95	3.65	A	A+	4.21	4.50	1474	0.73
	4.2+5.0	4.57	5.43	---	---	---	3.35	10.00	11.04	0.55	2.67	3.08	2.60	12.30	14.10	95	3.74	A	A+	4.20	5.20	1708	1.03
	4.2+6.0	4.12	5.88	---	---	---	3.68	10.00	11.30	0.62	2.63	3.19	2.90	12.10	14.60	95	3.80	A	A+	4.21	5.20	1704	1.01
	4.2+7.1	3.72	6.28	---	---	---	4.00	10.00	11.31	0.68	2.61	3.17	3.20	12.00	14.60	95	3.83	A	A+	4.22	5.20	1699	1.00
	5.0+5.0	5.00	5.00	---	---	---	3.65	10.00	11.13	0.60	2.49	2.91	2.80	11.50	13.40	95	4.01	A	A+	4.14	6.46	2151	1.59
	5.0+6.0	4.55	5.45	---	---	---	3.81	10.00	11.40	0.63	2.48	3.02	2.90	11.40	13.90	95	4.03	A	A+	4.15	6.46	2145	1.57
	5.0+7.1	4.13	5.87	---	---	---	4.13	10.00	11.41	0.69	2.47	3.00	3.30	11.30	13.80	95	4.06	A	A+	4.17	6.46	2139	1.55
	6.0+6.0	5.00	5.00	---	---	---	4.13	10.00	11.14	0.69	2.47	2.89	3.30	11.30	13.30	95	4.05	A	A+	4.16	6.46	2140	1.57
	6.0+7.1	4.58	5.42	---	---	---	4.45	10.00	11.28	0.76	2.45	2.93	3.50	11.30	13.50	95	4.08	A	A+	4.18	6.46	2133	1.55
	7.1+7.1	5.00	5.00	---	---	---	4.76	10.00	11.29	0.82	2.44	2.91	3.80	11.20	13.40	95	4.10	A	A+	4.19	6.46	2124	1.54
	1.5+1.5+1.5	1.83	1.83	1.83	---	---	1.88	5.50	10.04	0.44	1.05	2.52	2.02	4.80	11.60	95	5.26	A	A+	4.37	4.80	1538	0.83
	1.5+1.5+2.0	1.83	1.83	2.44	---	---	2.02	6.10	10.18	0.46	1.20	2.56	2.11	5.60	11.80	95	5.07	A	A+	4.38	4.80	1536	0.83
	1.5+1.5+2.5	1.83	1.83	3.05	---	---	2.17	6.70	10.31	0.48	1.37	2.61	2.19	6.30	12.00	95	4.89	A	A+	4.38	4.80	1533	0.82
	1.5+1.5+3.5	1.85	1.85	4.31	---	---	2.48	8.00	10.45	0.52	1.78	2.67	2.37	8.20	12.30	95	4.48	A	A+	4.28	5.50	1798	1.12
	1.5+1.5+4.2	1.81	1.81	5.08	---	---	2.83	8.70	10.47	0.45	1.99	2.61	2.10	9.20	12.00	95	4.36	A	A+	4.33	5.50	1778	1.12
	1.5+1.5+5.0	1.74	1.74	5.81	---	---	2.97	9.30	10.53	0.47	2.10	2.49	2.20	9.70	11.40	95	4.43	A	A+	4.32	6.46	2094	1.54
	1.5+1.5+6.0	1.58	1.58	6.33	---	---	3.29	9.50	11.21	0.52	2.15	2.75	2.50	9.90	12.60	95	4.41	A	A+	4.33	6.46	2090	1.52
	1.5+1.5+7.1	1.49	1.49	7.03	---	---	3.62	10.00	11.21	0.58	2.33	2.73	2.70	10.70	12.60	95	4.29	A	A+	4.34	6.46	2084	1.50
	1.5+2.0+2.0	1.83	2.44	2.44	---	---	2.17	6.70	10.31	0.48	1.37	2.61	2.19	6.30	12.00	95	4.89	A	A+	4.38	4.80	1534	0.82
	1.5+2.0+2.5	1.83	2.43	3.04	---	---	2.33	7.30	10.45	0.50	1.55	2.66	2.28	7.10	12.20	95	4.72	A	A+	4.39	4.80	1531	0.82
	1.5+2.0+3.5	1.82	2.43	4.25	---	---	2.67	8.50	10.58	0.42	1.94	2.71	2.00	8.90	12.50	95	4.38	A	A+	4.29	5.50	1795	1.12
1.5+2.0+4.2	1.75	2.34	4.91	---	---	2.99	9.00	10.61	0.48	2.09	2.66	2.20	9.60	12.30	95	4.30	A	A+	4.34	5.50	1775	1.11	
1.5+2.0+5.0	1.76	2.35	5.88	---	---	3.13	10.00	10.94	0.49	2.35	2.64	2.30	10.80	12.20	95	4.26	A	A+	4.33	6.46	2091	1.53	
1.5+2.0+6.0	1.58	2.11	6.32	---	---	3.46	10.00	11.21	0.55	2.33	2.74	2.60	10.70	12.60	95	4.28	A	A+	4.34	6.46	2086	1.51	
1.5+2.0+7.1	1.42	1.89	6.70	---	---	3.78	10.00	11.22	0.61	2.32	2.73	2.80	10.70	12.50	95	4.30	A	A+	4.37	6.46	2070	1.49	
1.5+2.5+2.5	1.85	3.08	3.08	---	---	2.48	8.00	10.59	0.52	1.77	2.70	2.37	8.20	12.50	95	4.52	A	A+	4.40	4.80	1529	0.82	
1.5+2.5+3.5	1.80	3.00	4.20	---	---	2.83	9.00	10.72	0.45	2.13	2.76	2.10	9.80	12.70	95	4.23	A	A+	4.30	5.50	1789	1.11	
1.5+2.5+4.2	1.83	3.05	5.12	---	---																		

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
5MXM90N2V1B9	2.0+2.0+2.0	2.50	2.50	2.50	---	---	2.33	7.50	10.58	0.50	1.60	2.71	2.28	7.40	12.50	95	4.67	A	A+	4.39	4.80	1531	0.81
	2.0+2.0+2.5	2.46	2.46	3.08	---	---	2.48	8.00	10.59	0.52	1.77	2.70	2.37	8.20	12.50	95	4.52	A	A+	4.40	4.80	1529	0.80
	2.0+2.0+3.5	2.40	2.40	4.20	---	---	2.83	9.00	10.72	0.45	2.13	2.76	2.10	9.80	12.70	95	4.23	A	A+	4.29	5.60	1826	1.15
	2.0+2.0+4.2	2.29	2.29	4.81	---	---	2.99	9.40	10.75	0.47	2.24	2.71	2.20	10.30	12.50	95	4.21	A	A+	4.33	5.60	1809	1.14
	2.0+2.0+5.0	2.22	2.22	5.56	---	---	3.29	10.00	10.94	0.52	2.34	2.63	2.50	10.70	12.10	95	4.28	A	A+	4.33	6.46	2087	1.52
	2.0+2.0+6.0	2.00	2.00	6.00	---	---	3.62	10.00	11.22	0.58	2.33	2.73	2.70	10.70	12.50	95	4.30	A	A+	4.34	6.46	2082	1.50
	2.0+2.0+7.1	1.80	1.80	6.40	---	---	3.94	10.00	11.22	0.64	2.32	2.72	3.00	10.60	12.50	95	4.32	A	A+	4.38	6.46	2067	1.48
	2.0+2.5+2.5	2.43	3.04	3.04	---	---	2.67	8.50	10.59	0.42	1.93	2.69	2.00	8.90	12.40	95	4.41	A	A+	4.37	5.00	1601	0.89
	2.0+2.5+3.5	2.33	2.91	4.07	---	---	3.00	9.30	10.73	0.48	2.23	2.75	2.20	10.20	12.70	95	4.17	A	A+	4.30	5.60	1822	1.14
	2.0+2.5+4.2	2.30	2.87	4.83	---	---	3.15	10.00	10.89	0.50	2.45	2.75	2.40	11.30	12.70	95	4.08	A	A+	4.34	5.60	1806	1.14
	2.0+2.5+5.0	2.11	2.63	5.26	---	---	3.45	10.00	11.21	0.55	2.33	2.73	2.60	10.70	12.60	95	4.29	A	A+	4.34	6.46	2083	1.51
	2.0+2.5+6.0	1.90	2.38	5.71	---	---	3.78	10.00	11.22	0.61	2.32	2.72	2.80	10.70	12.50	95	4.31	A	A+	4.37	6.46	2068	1.49
	2.0+2.5+7.1	1.72	2.16	6.12	---	---	4.10	10.00	11.22	0.67	2.31	2.71	3.10	10.60	12.50	95	4.33	A	A+	4.38	6.46	2063	1.48
	2.0+3.5+3.5	2.22	3.89	3.89	---	---	3.33	10.00	10.86	0.54	2.50	2.81	2.50	11.50	12.90	95	3.99	A	A+	4.20	6.46	2156	1.52
	2.0+3.5+4.2	2.06	3.61	4.33	---	---	3.48	10.00	11.02	0.56	2.45	2.81	2.70	11.30	13.00	95	4.08	A	A+	4.24	6.46	2133	1.52
	2.0+3.5+5.0	1.90	3.33	4.76	---	---	3.78	10.00	11.35	0.61	2.33	2.79	2.80	10.70	12.80	95	4.29	A	A+	4.34	6.46	2083	1.51
	2.0+3.5+6.0	1.74	3.04	5.22	---	---	3.94	10.00	11.35	0.64	2.32	2.78	3.00	10.70	12.80	95	4.31	A	A+	4.37	6.46	2068	1.49
	2.0+3.5+7.1	1.59	2.78	5.63	---	---	4.26	10.00	11.36	0.70	2.31	2.76	3.30	10.60	12.70	95	4.33	A	A+	4.38	6.46	2063	1.47
	2.0+4.2+4.2	1.92	4.04	4.04	---	---	3.63	10.00	11.04	0.59	2.40	2.76	2.80	11.10	12.70	95	4.16	A	A+	4.27	6.46	2117	1.52
	2.0+4.2+5.0	1.79	3.75	4.46	---	---	3.93	10.00	11.37	0.63	2.29	2.74	3.00	10.50	12.60	95	4.37	A	A+	4.40	6.46	2055	1.51
	2.0+4.2+6.0	1.64	3.44	4.92	---	---	4.26	10.00	11.37	0.69	2.28	2.73	3.30	10.50	12.50	95	4.39	A	A+	4.41	6.46	2051	1.49
	2.0+4.2+7.1	1.50	3.16	5.34	---	---	4.58	10.00	11.51	0.75	2.27	2.73	3.50	10.40	12.80	95	4.41	A	A+	4.42	6.46	2046	1.47
	2.0+5.0+5.0	1.67	4.17	4.17	---	---	4.08	10.00	11.13	0.65	2.18	2.53	3.00	10.00	11.60	95	4.59	A	A+	4.50	6.46	2010	1.50
	2.0+5.0+6.0	1.54	3.85	4.62	---	---	4.40	10.00	11.41	0.70	2.17	2.62	3.30	10.00	12.00	95	4.61	A	A+	4.51	6.46	2007	1.48
	2.0+5.0+7.1	1.42	3.55	5.04	---	---	4.72	10.00	11.41	0.76	2.16	2.61	3.60	9.90	12.00	95	4.63	A	A+	4.51	6.46	2003	1.46
	2.0+6.0+6.0	1.43	4.29	4.29	---	---	4.72	10.00	11.54	0.76	2.16	2.66	3.60	9.90	12.30	95	4.63	A	A+	4.51	6.46	2004	1.48
	2.0+6.0+7.1	1.32	3.97	4.70	---	---	5.04	10.00	11.68	0.82	2.15	2.70	3.80	9.90	12.50	95	4.64	A	A+	4.52	6.46	2000	1.46
	2.5+2.5+2.5	3.33	3.33	3.33	---	---	2.83	10.00	10.73	0.45	2.49	2.74	2.10	11.50	12.60	95	4.01	A	A+	4.38	5.00	1599	0.88
	2.5+2.5+3.5	2.94	2.94	4.12	---	---	3.16	10.00	11.00	0.51	2.49	2.86	2.40	11.50	13.10	95	4.01	A	A+	4.31	5.60	1819	1.13
	2.5+2.5+4.2	2.72	2.72	4.57	---	---	3.31	10.00	11.16	0.53	2.44	2.86	2.50	11.20	13.10	95	4.09	A	A+	4.35	5.60	1802	1.13
	2.5+2.5+5.0	2.50	2.50	5.00	---	---	3.62	10.00	11.35	0.58	2.32	2.78	2.70	10.70	12.80	95	4.31	A	A+	4.37	6.46	2069	1.50
	2.5+2.5+6.0	2.27	2.27	5.45	---	---	3.78	10.00	11.36	0.61	2.31	2.77	2.80	10.60	12.70	95	4.33	A	A+	4.38	6.46	2065	1.48
	2.5+2.5+7.1	2.07	2.07	5.87	---	---	4.10	10.00	11.50	0.66	2.30	2.81	3.10	10.60	12.90	95	4.35	A	A+	4.39	6.46	2060	1.46
	2.5+3.5+3.5	2.63	3.68	3.68	---	---	3.49	10.00	11.26	0.57	2.49	2.97	2.70	11.50	13.70	95	4.01	A	A+	4.20	6.46	2151	1.51
	2.5+3.5+4.2	2.45	3.43	4.12	---	---	3.64	10.00	11.29	0.59	2.44	2.92	2.80	11.20	13.40	95	4.09	A	A+	4.25	6.46	2126	1.51
	2.5+3.5+5.0	2.27	3.18	4.55	---	---	3.78	10.00	11.35	0.61	2.32	2.78	2.80	10.70	12.80	95	4.31	A	A+	4.37	6.46	2069	1.49
	2.5+3.5+6.0	2.08	2.92	5.00	---	---	4.10	10.00	11.36	0.67	2.31	2.77	3.10	10.60	12.70	95	4.33	A	A+	4.38	6.46	2065	1.48
	2.5+3.5+7.1	1.91	2.67	5.42	---	---	4.42	10.00	11.50	0.73	2.30	2.81	3.40	10.60	12.90	95	4.35	A	A+	4.39	6.46	2060	1.46
	2.5+4.2+4.2	2.29	3.85	3.85	---	---	3.79	10.00	11.31	0.62	2.40	2.86	2.90	11.00	13.20	95	4.18	A	A+	4.28	6.46	2113	1.50
	2.5+4.2+5.0	2.14	3.59	4.27	---	---	4.10	10.00	11.37	0.66	2.28	2.73	3.10	10.50	12.60	95	4.38	A	A+	4.41	6.46	2052	1.49
	2.5+4.2+6.0	1.97	3.31	4.72	---	---	4.42	10.00	11.38	0.72	2.27	2.72	3.40	10.40	12.50	95	4.40	A	A+	4.42	6.46	2047	1.47
	2.5+4.2+7.1	1.81	3.04	5.14	---	---	4.73	10.00	11.52	0.78	2.26	2.76	3.70	10.40	12.70	95	4.42	A	A+	4.43	6.46	2043	1.45
	2.5+5.0+5.0	2.00	4.00	4.00	---	---	4.24	10.00	11.13	0.67	2.17	2.52	3.20	10.00	11.60	95	4.61	A	A+	4.50	6.46	2008	1.49
	2.5+5.0+6.0	1.85	3.70	4.44	---	---	4.56	10.00	11.41	0.73	2.16	2.61	3.40	10.00	12.00	95	4.62	A	A+	4.51	6.46	2004	1.47
	2.5+5.0+7.1	1.71	3.42	4.86	---	---	4.88	10.00	11.41	0.79	2.16	2.60	3.70	9.90	12.00	95	4.64	A	A+	4.52	6.46	2001	1.45
	2.5+6.0+6.0	1.72	4.14	4.14	---	---	4.88	10.00	11.55	0.79	2.16	2.65	3.70	9.90	12.20	95	4.64	A	A+	4.52	6.46	2001	1.46
	2.5+6.0+7.1	1.60	3.85	4.55	---	---	5.19	10.00	11.68	0.85	2.15	2.70	4.00	9.90	12.40	95	4.65	A	A+	4.53	6.46	1998	1.45
	3.5+3.5+3.5	3.33	3.33	3.33	---	---	3.65	10.00	11.26	0.60	2.49	2.97	2.80	11.50	13.70	95	4.01	A	A+	4.20	6.46	2151	1.48
	3.5+3.5+4.2	3.13	3.13	3.75	---	---	3.96	10.00	11.29	0.66	2.44	2.92	3.10	11.20	13.40	95	4.09	A	A+	4.25	6.46	2126	1.48
	3.5+3.5+5.0	2.92	2.92	4.17	---	---	4.10	10.00	11.35	0.67	2.32	2.78	3.10	10.70	12.80	95	4.31	A	A+	4.37	6.46	2069	1.47
	3.5+3.5+6.0	2.69	2.69	4.62	---	---	4.42	10.00	11.49	0.73	2.31	2.82	3.40	10.60	13.00	95	4.33	A	A+	4.38	6.46	2065	1.45
	3.5+3.5+7.1	2.48	2.48	5.04	---	---	4.74	10.00	11.50	0.79	2.30	2.81	3.70	10.60	12.90	95	4.35	A	A+	4.39	6.46	2060	1.43
	3.5+4.2+4.2	2.94	3.53	3.53	---	---	4.12	10.00	11.31	0.68	2.40	2.86	3.20	11.00	13.20	95	4.18	A	A+	4.28	6.46	2113	1.48
	3.5+4.2+5.0	2.76	3.31	3.94	---	---	4.42	10.00	11.24	0.72	2.28	2.68	3.40	10.50	12.30	95	4.38	A	A+	4.41	6.46	2052	1.46
	3.5+4.2+6.0	2.55	3.07	4.38	---	---	4.58	10.00	11.38	0.75	2.27	2.72	3.50	10.40	12.50	95	4.40	A	A+	4.42	6.46	2047	1.45
3.5+4.2+7.1	2.36	2.84	4.80	---	---	4.89	10.00	11.38	0.81	2.26	2.71	3.80	10.40	12.50	95	4.42	A	A+	4.43	6.46	2043	1.43	
3.5+5.0+5.0	2.59	3.70	3.70	---	---	4.56	10.00	11.13	0.73	2.17	2.52	3.40	10.00	11.60	95	4.61	A	A+	4.50	6.46	2008	1.46	
3.5+5.0+6.0	2.41	3.45	4.14	---	---	4.88	10.00	11.41	0.80	2.16	2.61	3.70	10.00	12.00	95	4.62	A	A+	4.51	6.46	2004	1.44	
3.5+5.0+7.1	2.24	3.21	4.																				

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
5MXM90N2V19	1.5+1.5+2.0+5.0	1.50	1.50	2.00	5.00	---	3.57	10.00	11.42	0.55	2.10	2.53	2.60	9.70	11.70	95	4.76	A	A+	4.58	6.46	1976	1.46
	1.5+1.5+2.0+6.0	1.36	1.36	1.82	5.45	---	3.89	10.00	11.55	0.60	2.09	2.57	2.80	9.60	11.90	95	4.78	A	A+	4.58	6.46	1974	1.46
	1.5+1.5+2.0+7.1	1.24	1.24	1.65	5.87	---	4.22	10.00	11.69	0.66	2.09	2.61	3.10	9.60	12.00	95	4.79	A	A+	4.59	6.46	1971	1.46
	1.5+1.5+2.5+2.5	1.88	1.88	3.13	3.13	---	2.93	10.00	10.71	0.45	2.20	2.40	2.20	10.10	11.00	95	4.55	A	A+	4.47	6.46	2022	1.48
	1.5+1.5+2.5+3.5	1.67	1.67	2.78	3.89	---	3.26	10.00	11.26	0.51	2.20	2.60	2.40	10.10	11.90	95	4.55	A	A+	4.47	6.46	2022	1.48
	1.5+1.5+2.5+4.2	1.55	1.55	2.58	4.33	---	3.42	10.00	11.27	0.53	2.16	2.56	2.50	10.00	11.80	95	4.62	A	A+	4.51	6.46	2005	1.47
	1.5+1.5+2.5+5.0	1.43	1.43	2.38	4.76	---	3.73	10.00	11.42	0.58	2.10	2.53	2.70	9.60	11.60	95	4.77	A	A+	4.58	6.46	1974	1.46
	1.5+1.5+2.5+6.0	1.30	1.30	2.17	5.22	---	4.06	10.00	11.55	0.63	2.09	2.57	3.00	9.60	11.80	95	4.79	A	A+	4.59	6.46	1972	1.46
	1.5+1.5+2.5+7.1	1.19	1.19	1.98	5.63	---	4.38	10.00	11.69	0.69	2.08	2.61	3.20	9.60	12.00	95	4.80	A	A+	4.59	6.46	1969	1.45
	1.5+1.5+3.5+3.5	1.50	1.50	3.50	3.50	---	3.59	10.00	11.26	0.56	2.20	2.60	2.70	10.10	11.90	95	4.55	A	A+	4.47	6.46	2022	1.47
	1.5+1.5+3.5+4.2	1.40	1.40	3.27	3.93	---	3.75	10.00	11.27	0.59	2.16	2.56	2.80	10.00	11.80	95	4.62	A	A+	4.51	6.46	2005	1.47
	1.5+1.5+3.5+5.0	1.30	1.30	3.04	4.35	---	4.06	10.00	11.42	0.63	2.10	2.53	3.00	9.60	11.60	95	4.77	A	A+	4.58	6.46	1974	1.46
	1.5+1.5+3.5+6.0	1.20	1.20	2.80	4.80	---	4.22	10.00	11.55	0.66	2.09	2.57	3.10	9.60	11.80	95	4.79	A	A+	4.59	6.46	1972	1.45
	1.5+1.5+3.5+7.1	1.10	1.10	2.57	5.22	---	4.54	10.00	11.69	0.72	2.08	2.61	3.30	9.60	12.00	95	4.80	A	A+	4.59	6.46	1969	1.45
	1.5+1.5+4.2+4.2	1.32	1.32	3.68	3.68	---	3.90	10.00	11.27	0.61	2.14	2.53	2.90	9.80	11.60	95	4.68	A	A+	4.54	6.46	1992	1.46
	1.5+1.5+4.2+5.0	1.23	1.23	3.44	4.10	---	4.21	10.00	11.41	0.66	2.07	2.50	3.10	9.50	11.50	95	4.82	A	A++	4.60	6.46	1965	1.45
	1.5+1.5+4.2+6.0	1.14	1.14	3.18	4.55	---	4.54	10.00	11.69	0.71	2.07	2.59	3.30	9.50	11.90	95	4.83	A	A++	4.61	6.46	1963	1.45
	1.5+1.5+4.2+7.1	1.05	1.05	2.94	4.97	---	4.85	10.00	11.68	0.77	2.06	2.58	3.60	9.50	11.90	95	4.84	A	A++	4.61	6.46	1961	1.45
	1.5+1.5+5.0+5.0	1.15	1.15	3.85	3.85	---	4.36	10.00	11.53	0.68	2.05	2.49	3.20	9.40	11.40	95	4.88	A	A++	4.64	6.46	1950	1.45
	1.5+1.5+5.0+6.0	1.07	1.07	3.57	4.29	---	4.68	10.00	11.80	0.73	2.04	2.58	3.40	9.40	11.90	95	4.89	A	A++	4.64	6.46	1949	1.45
	1.5+1.5+5.0+7.1	0.99	0.99	3.31	4.70	---	5.00	10.00	11.79	0.79	2.04	2.57	3.70	9.40	11.90	95	4.90	A	A++	4.64	6.46	1948	1.44
	1.5+1.5+6.0+6.0	1.00	1.00	4.00	4.00	---	5.00	10.00	11.93	0.79	2.04	2.62	3.70	9.40	12.10	95	4.90	A	A++	4.64	6.46	1948	1.44
	1.5+2.0+2.0+2.0	1.90	2.53	2.53	2.53	---	2.94	9.50	10.71	0.45	2.04	2.40	2.20	9.40	11.10	95	4.65	A	A+	4.47	6.46	2025	1.48
	1.5+2.0+2.0+2.5	1.88	2.50	2.50	3.13	---	2.93	10.00	10.85	0.45	2.20	2.45	2.20	10.10	11.30	95	4.55	A	A+	4.47	6.46	2022	1.48
	1.5+2.0+2.0+3.5	1.67	2.22	2.22	3.89	---	3.26	10.00	11.26	0.51	2.20	2.60	2.40	10.10	11.90	95	4.55	A	A+	4.47	6.46	2022	1.47
	1.5+2.0+2.0+4.2	1.55	2.06	2.06	4.33	---	3.42	10.00	11.27	0.53	2.16	2.56	2.50	10.00	11.80	95	4.62	A	A+	4.51	6.46	2005	1.47
	1.5+2.0+2.0+5.0	1.43	1.90	1.90	4.76	---	3.73	10.00	11.42	0.58	2.10	2.53	2.70	9.60	11.60	95	4.77	A	A+	4.58	6.46	1974	1.46
	1.5+2.0+2.0+6.0	1.30	1.74	1.74	5.22	---	4.06	10.00	11.55	0.63	2.09	2.57	3.00	9.60	11.80	95	4.78	A	A+	4.59	6.46	1972	1.45
	1.5+2.0+2.0+7.1	1.19	1.59	1.59	5.63	---	4.38	10.00	11.69	0.69	2.08	2.61	3.20	9.60	12.00	95	4.80	A	A+	4.59	6.46	1969	1.45
	1.5+2.0+2.5+2.5	1.76	2.35	2.94	2.94	---	3.10	10.00	10.85	0.48	2.19	2.44	2.20	10.10	11.20	95	4.57	A	A+	4.49	6.46	2016	1.48
	1.5+2.0+2.5+3.5	1.58	2.11	2.63	3.68	---	3.43	10.00	11.26	0.53	2.19	2.59	2.50	10.10	11.90	95	4.57	A	A+	4.49	6.46	2016	1.47
	1.5+2.0+2.5+4.2	1.47	1.96	2.45	4.12	---	3.58	10.00	11.27	0.56	2.16	2.56	2.60	9.90	11.80	95	4.63	A	A+	4.52	6.46	2002	1.46
	1.5+2.0+2.5+5.0	1.36	1.82	2.27	4.55	---	3.89	10.00	11.42	0.60	2.09	2.52	2.80	9.60	11.60	95	4.78	A	A+	4.59	6.46	1972	1.45
	1.5+2.0+2.5+6.0	1.25	1.67	2.08	5.00	---	4.22	10.00	11.55	0.66	2.09	2.56	3.10	9.60	11.80	95	4.79	A	A+	4.59	6.46	1970	1.45
	1.5+2.0+2.5+7.1	1.15	1.53	1.91	5.42	---	4.54	10.00	11.69	0.71	2.08	2.60	3.30	9.60	12.00	95	4.81	A	A+	4.60	6.46	1968	1.45
	1.5+2.0+3.5+3.5	1.43	1.90	3.33	3.33	---	3.75	10.00	11.26	0.59	2.19	2.59	2.80	10.10	11.90	95	4.57	A	A+	4.49	6.46	2016	1.46
	1.5+2.0+3.5+4.2	1.34	1.79	3.13	3.75	---	3.91	10.00	11.27	0.61	2.16	2.56	2.90	9.90	11.80	95	4.63	A	A+	4.52	6.46	2002	1.46
	1.5+2.0+3.5+5.0	1.25	1.67	2.92	4.17	---	4.22	10.00	11.42	0.66	2.09	2.52	3.10	9.60	11.60	95	4.78	A	A+	4.59	6.46	1972	1.45
	1.5+2.0+3.5+6.0	1.15	1.54	2.69	4.62	---	4.38	10.00	11.55	0.69	2.09	2.56	3.20	9.60	11.80	95	4.79	A	A+	4.59	6.46	1970	1.45
	1.5+2.0+3.5+7.1	1.06	1.42	2.48	5.04	---	4.70	10.00	11.69	0.74	2.08	2.60	3.50	9.60	12.00	95	4.81	A	A+	4.60	6.46	1968	1.44
	1.5+2.0+4.2+4.2	1.26	1.68	3.53	3.53	---	4.07	10.00	11.28	0.64	2.13	2.52	3.00	9.80	11.60	95	4.69	A	A+	4.54	6.46	1990	1.46
	1.5+2.0+4.2+5.0	1.18	1.57	3.31	3.94	---	4.37	10.00	11.41	0.68	2.07	2.49	3.20	9.50	11.50	95	4.83	A	A++	4.61	6.46	1964	1.45
	1.5+2.0+4.2+6.0	1.09	1.46	3.07	4.38	---	4.69	10.00	11.69	0.74	2.07	2.58	3.50	9.50	11.90	95	4.84	A	A++	4.61	6.46	1962	1.44
	1.5+2.0+4.2+7.1	1.01	1.35	2.84	4.80	---	5.01	10.00	11.68	0.80	2.06	2.58	3.70	9.50	11.90	95	4.85	A	A++	4.62	6.46	1960	1.44
	1.5+2.0+5.0+5.0	1.11	1.48	3.70	3.70	---	4.52	10.00	11.52	0.70	2.04	2.48	3.30	9.40	11.40	95	4.89	A	A++	4.64	6.46	1949	1.44
	1.5+2.0+5.0+6.0	1.03	1.38	3.45	4.14	---	4.84	10.00	11.79	0.76	2.04	2.57	3.50	9.40	11.90	95	4.90	A	A++	4.64	6.46	1948	1.44
	1.5+2.0+5.0+7.1	0.96	1.28	3.21	4.55	---	5.16	10.00	11.79	0.82	2.04	2.57	3.80	9.40	11.80	95	4.90	A	A++	4.64	6.46	1947	1.43
	1.5+2.0+6.0+6.0	0.97	1.29	3.87	3.87	---	5.16	10.00	11.93	0.82	2.04	2.62	3.80	9.40	12.00	95	4.90	A	A++	4.64	6.46	1947	1.43
	1.5+2.5+2.5+2.5	1.67	2.78	2.78	2.78	---	3.26	10.00	11.26	0.51	2.18	2.58	2.40	10.00	11.90	95	4.58	A	A+	4.49	6.46	2013	1.46
	1.5+2.5+2.5+3.5	1.50	2.50	2.50	3.50	---	3.59	10.00	11.26	0.56	2.18	2.58	2.70	10.00	11.90	95	4.58	A	A+	4.49	6.46	2013	1.45
	1.5+2.5+2.5+4.2	1.40	2.34	2.34	3.93	---	3.75	10.00	11.27	0.58	2.15	2.55	2.80	9.90	11.70	95	4.64	A	A+	4.52	6.46	2000	1.45
	1.5+2.5+2.5+5.0	1.30	2.17	2.17	4.35	---	4.05	10.00	11.41	0.63	2.09	2.51	3.00	9.60	11.60	95	4.79	A	A+	4.59	6.46	1971	1.44
	1.5+2.5+2.5+6.0	1.20	2.00	2.00	4.80	---	4.22	10.00	11.55	0.66	2.08	2.56	3.10	9.60	11.80	95	4.80	A	A+	4.59	6.46	1968	1.43
	1.5+2.5+2.5+7.1	1.10	1.84	1.84	5.22	---	4.54	10.00	11.69	0.71	2.08	2.60	3.30	9.60	11.90	95	4.82	A	A++	4.60	6.46	1966	1.43
	1.5+2.5+3.5+3.5	1.36	2.27	3.18	3.18	---	3.92	10.00	11.26	0.62	2.18	2.58	2.90	10.00	11.90	95	4.58	A	A+	4.49	6.46	2013	1.45
	1.5+2.5+3.5+4.2	1.28	2.14	2.99	3.59	---	4.07	10.00	11.27	0.64	2.15	2.55	3.00	9.90	11.70	95	4.64	A	A+	4.52	6.46	2000	1.45
	1.5+2.5+3.5																						

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
5MXM90N2V1B9	2.0+2.0+2.0+4.2	1.96	1.96	1.96	4.12	---	3.58	10.00	11.27	0.56	2.16	2.56	2.60	9.90	11.80	95	4.63	A	A+	4.52	6.46	2003	1.46
	2.0+2.0+2.0+5.0	1.82	1.82	1.82	4.55	---	3.89	10.00	11.42	0.60	2.09	2.52	2.80	9.60	11.60	95	4.78	A	A+	4.59	6.46	1972	1.45
	2.0+2.0+2.0+6.0	1.67	1.67	1.67	5.00	---	4.22	10.00	11.55	0.66	2.09	2.56	3.10	9.60	11.80	95	4.79	A	A+	4.59	6.46	1970	1.45
	2.0+2.0+2.0+7.1	1.53	1.53	1.53	5.42	---	4.54	10.00	11.69	0.71	2.08	2.60	3.30	9.60	12.00	95	4.81	A	A+	4.60	6.46	1968	1.44
	2.0+2.0+2.5+2.5	2.22	2.22	2.78	2.78	---	3.26	10.00	11.26	0.51	2.18	2.59	2.40	10.00	11.90	95	4.58	A	A+	4.49	6.46	2013	1.47
	2.0+2.0+2.5+3.5	2.00	2.00	2.50	3.50	---	3.59	10.00	11.26	0.56	2.18	2.59	2.70	10.00	11.90	95	4.58	A	A+	4.49	6.46	2013	1.46
	2.0+2.0+2.5+4.2	1.87	1.87	2.34	3.93	---	3.75	10.00	11.27	0.58	2.15	2.55	2.80	9.90	11.70	95	4.64	A	A+	4.52	6.46	2000	1.46
	2.0+2.0+2.5+5.0	1.74	1.74	2.17	4.35	---	4.05	10.00	11.41	0.63	2.09	2.51	3.00	9.60	11.60	95	4.79	A	A+	4.59	6.46	1971	1.45
	2.0+2.0+2.5+6.0	1.60	1.60	2.00	4.80	---	4.22	10.00	11.55	0.66	2.08	2.56	3.10	9.60	11.80	95	4.80	A	A+	4.59	6.46	1968	1.44
	2.0+2.0+2.5+7.1	1.47	1.47	1.84	5.22	---	4.54	10.00	11.69	0.71	2.08	2.60	3.30	9.60	11.90	95	4.82	A	A++	4.60	6.46	1966	1.44
	2.0+2.0+3.5+3.5	1.82	1.82	3.18	3.18	---	3.92	10.00	11.26	0.62	2.18	2.59	2.90	10.00	11.90	95	4.58	A	A+	4.49	6.46	2013	1.46
	2.0+2.0+3.5+4.2	1.71	1.71	2.99	3.59	---	4.07	10.00	11.27	0.64	2.15	2.55	3.00	9.90	11.70	95	4.64	A	A+	4.52	6.46	2000	1.45
	2.0+2.0+3.5+5.0	1.60	1.60	2.80	4.00	---	4.22	10.00	11.41	0.66	2.09	2.51	3.10	9.60	11.60	95	4.79	A	A+	4.59	6.46	1971	1.44
	2.0+2.0+3.5+6.0	1.48	1.48	2.59	4.44	---	4.54	10.00	11.55	0.72	2.08	2.56	3.30	9.60	11.80	95	4.80	A	A+	4.59	6.46	1968	1.44
	2.0+2.0+3.5+7.1	1.37	1.37	2.40	4.86	---	4.86	10.00	11.69	0.77	2.08	2.60	3.60	9.60	11.90	95	4.82	A	A++	4.60	6.46	1966	1.43
	2.0+2.0+4.2+4.2	1.61	1.61	3.39	3.39	---	4.23	10.00	11.28	0.67	2.13	2.52	3.10	9.80	11.60	95	4.70	A	A+	4.55	6.46	1988	1.45
	2.0+2.0+4.2+5.0	1.52	1.52	3.18	3.79	---	4.53	10.00	11.41	0.71	2.07	2.49	3.30	9.50	11.40	95	4.84	A	A++	4.61	6.46	1962	1.44
	2.0+2.0+4.2+6.0	1.41	1.41	2.96	4.23	---	4.85	10.00	11.68	0.77	2.06	2.58	3.60	9.50	11.90	95	4.85	A	A++	4.61	6.46	1960	1.43
	2.0+2.0+4.2+7.1	1.31	1.31	2.75	4.64	---	5.17	10.00	11.68	0.83	2.06	2.57	3.80	9.50	11.90	95	4.86	A	A++	4.62	6.46	1958	1.43
	2.0+2.0+5.0+5.0	1.43	1.43	3.57	3.57	---	4.68	10.00	11.52	0.73	2.04	2.48	3.40	9.40	11.40	95	4.90	A	A++	4.64	6.46	1949	1.43
	2.0+2.0+5.0+6.0	1.33	1.33	3.33	4.00	---	5.00	10.00	11.79	0.79	2.04	2.57	3.70	9.40	11.90	95	4.90	A	A++	4.64	6.46	1948	1.43
	2.0+2.5+2.5+2.5	2.11	2.63	2.63	2.63	---	3.42	10.00	11.27	0.53	2.18	2.58	2.50	10.00	11.90	95	4.59	A	A+	4.50	6.46	2011	1.45
	2.0+2.5+2.5+3.5	1.90	2.38	2.38	3.33	---	3.75	10.00	11.27	0.59	2.18	2.58	2.80	10.00	11.90	95	4.59	A	A+	4.50	6.46	2011	1.45
	2.0+2.5+2.5+4.2	1.79	2.23	2.23	3.75	---	3.91	10.00	11.27	0.61	2.15	2.54	2.90	9.90	11.70	95	4.65	A	A+	4.53	6.46	1998	1.44
	2.0+2.5+2.5+5.0	1.67	2.08	2.08	4.17	---	4.22	10.00	11.41	0.66	2.08	2.51	3.10	9.60	11.50	95	4.80	A	A+	4.59	6.46	1969	1.43
	2.0+2.5+2.5+6.0	1.54	1.92	1.92	4.62	---	4.38	10.00	11.55	0.69	2.08	2.55	3.20	9.60	11.80	95	4.81	A	A+	4.60	6.46	1967	1.43
	2.0+2.5+2.5+7.1	1.42	1.77	1.77	5.04	---	4.70	10.00	11.69	0.74	2.07	2.59	3.50	9.50	11.90	95	4.82	A	A++	4.60	6.46	1964	1.42
	2.0+2.5+3.5+3.5	1.74	2.17	3.04	3.04	---	4.08	10.00	11.27	0.65	2.18	2.58	3.00	10.00	11.90	95	4.59	A	A+	4.50	6.46	2011	1.44
	2.0+2.5+3.5+4.2	1.64	2.05	2.87	3.44	---	4.23	10.00	11.27	0.67	2.15	2.54	3.20	9.90	11.70	95	4.65	A	A+	4.53	6.46	1998	1.44
	2.0+2.5+3.5+5.0	1.54	1.92	2.69	3.85	---	4.38	10.00	11.41	0.69	2.08	2.51	3.20	9.60	11.50	95	4.80	A	A+	4.59	6.46	1969	1.43
	2.0+2.5+3.5+6.0	1.43	1.79	2.50	4.29	---	4.70	10.00	11.55	0.74	2.08	2.55	3.50	9.60	11.80	95	4.81	A	A+	4.60	6.46	1967	1.42
	2.0+2.5+3.5+7.1	1.32	1.66	2.32	4.70	---	5.02	10.00	11.69	0.80	2.07	2.59	3.80	9.50	11.90	95	4.82	A	A++	4.60	6.46	1964	1.42
	2.0+2.5+4.2+4.2	1.55	1.94	3.26	3.26	---	4.39	10.00	11.28	0.69	2.12	2.51	3.30	9.80	11.50	95	4.71	A	A+	4.55	6.46	1986	1.43
	2.0+2.5+4.2+5.0	1.46	1.82	3.07	3.65	---	4.69	10.00	11.41	0.74	2.06	2.48	3.50	9.50	11.40	95	4.85	A	A++	4.61	6.46	1961	1.42
	2.0+2.5+4.2+6.0	1.36	1.70	2.86	4.08	---	4.85	10.00	11.68	0.77	2.06	2.57	3.60	9.50	11.90	95	4.86	A	A++	4.62	6.46	1959	1.42
	2.0+2.5+5.0+5.0	1.38	1.72	3.45	3.45	---	4.84	10.00	11.52	0.76	2.04	2.48	3.50	9.40	11.40	95	4.90	A	A++	4.64	6.46	1948	1.42
	2.0+2.5+5.0+6.0	1.29	1.61	3.23	3.87	---	5.16	10.00	11.79	0.82	2.04	2.57	3.80	9.40	11.80	95	4.91	A	A++	4.65	6.46	1947	1.42
	2.0+3.5+3.5+3.5	1.60	2.80	2.80	2.80	---	4.24	10.00	11.27	0.68	2.18	2.58	3.20	10.00	11.90	95	4.59	A	A+	4.50	6.46	2011	1.41
	2.0+3.5+3.5+4.2	1.52	2.65	2.65	3.18	---	4.55	10.00	11.27	0.73	2.15	2.54	3.40	9.90	11.70	95	4.65	A	A+	4.53	6.46	1998	1.40
	2.0+3.5+3.5+5.0	1.43	2.50	2.50	3.57	---	4.70	10.00	11.41	0.74	2.08	2.51	3.50	9.60	11.50	95	4.80	A	A+	4.59	6.46	1969	1.39
	2.0+3.5+3.5+6.0	1.33	2.33	2.33	4.00	---	5.02	10.00	11.69	0.80	2.08	2.60	3.80	9.60	12.00	95	4.81	A	A+	4.60	6.46	1967	1.39
	2.0+3.5+4.2+4.2	1.44	2.52	3.02	3.02	---	4.71	10.00	11.28	0.75	2.12	2.51	3.50	9.80	11.50	95	4.71	A	A+	4.55	6.46	1986	1.40
	2.0+3.5+4.2+5.0	1.36	2.38	2.86	3.40	---	4.85	10.00	11.41	0.77	2.06	2.48	3.60	9.50	11.40	95	4.85	A	A++	4.61	6.46	1961	1.39
	2.0+3.5+5.0+5.0	1.29	2.26	3.23	3.23	---	5.16	10.00	11.52	0.82	2.04	2.48	3.80	9.40	11.40	95	4.90	A	A++	4.64	6.46	1948	1.39
	2.0+4.2+4.2+4.2	1.37	2.88	2.88	2.88	---	4.86	10.00	11.28	0.78	2.10	2.48	3.60	9.70	11.40	95	4.77	A	A+	4.58	6.46	1975	1.40
	2.0+4.2+4.2+5.0	1.30	2.73	2.73	3.25	---	5.17	10.00	11.40	0.83	2.06	2.46	3.80	9.50	11.40	95	4.85	A	A++	4.63	6.46	1954	1.39
	2.5+2.5+2.5+2.5	2.50	2.50	2.50	2.50	---	3.59	10.00	11.27	0.56	2.17	2.57	2.60	10.00	11.90	95	4.60	A	A+	4.50	6.46	2008	1.45
	2.5+2.5+2.5+3.5	2.27	2.27	2.27	3.18	---	3.91	10.00	11.27	0.62	2.17	2.57	2.90	10.00	11.90	95	4.60	A	A+	4.50	6.46	2008	1.44
	2.5+2.5+2.5+4.2	2.14	2.14	2.14	3.59	---	4.07	10.00	11.27	0.64	2.14	2.54	3.00	9.90	11.70	95	4.67	A	A+	4.53	6.46	1995	1.43
	2.5+2.5+2.5+5.0	2.00	2.00	2.00	4.00	---	4.21	10.00	11.41	0.66	2.08	2.50	3.10	9.60	11.50	95	4.81	A	A+	4.60	6.46	1967	1.42
	2.5+2.5+2.5+6.0	1.85	1.85	1.85	4.44	---	4.54	10.00	11.55	0.71	2.07	2.55	3.30	9.50	11.70	95	4.82	A	A++	4.60	6.46	1965	1.42
	2.5+2.5+2.5+7.1	1.71	1.71	1.71	4.86	---	4.86	10.00	11.69	0.77	2.07	2.59	3.60	9.50	11.90	95	4.83	A	A++	4.61	6.46	1963	1.42
	2.5+2.5+3.5+3.5	2.08	2.08	2.92	2.92	---	4.08	10.00	11.27	0.65	2.17	2.57	3.00	10.00	11.90	95	4.60	A	A+	4.50	6.46	2008	1.43
	2.5+2.5+3.5+4.2	1.97	1.97	2.76	3.31	---	4.39	10.00	11.27	0.70	2.14	2.54	3.30	9.90	11.70	95	4.67	A	A+	4.53	6.46	1995	1.43
	2.5+2.5+3.5+5.0	1.85	1.85	2.59	3.70	---	4.54	10.00	11.41	0.71	2.08	2.50	3.30	9.60	11.50	95	4.81	A	A+	4.60	6.46	1967	1.42
2.5+2.5+3.5+6.0	1.72	1.72	2.41	4.14	---	4.86	10.00	11.55	0.77	2.07	2.55	3.60	9.50	11.70	95	4.82	A	A++	4.60	6.46	1965	1.42	
2.5+2.5+3																							

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
	1.5+1.5+1.5+1.5+6.0	1,25	1,25	1,25	1,25	---	4,19	10,00	12,01	0,64	2,02	2,63	3,00	9,30	12,10	95	4,94	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+1.5+7.1	1,15	1,15	1,15	1,15	---	4,51	10,00	12,00	0,70	2,02	2,63	3,30	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+2.0+2.0	1,76	1,76	1,76	2,35	---	3,22	10,00	10,98	0,49	2,06	2,31	2,30	9,50	10,70	95	4,86	A	A++	4,63	6,46	1952	1,24
	1.5+1.5+1.5+2.0+2.5	1,67	1,67	1,67	2,22	---	3,22	10,00	11,67	0,49	2,06	2,55	2,30	9,50	11,70	95	4,87	A	A++	4,64	6,46	1951	1,24
	1.5+1.5+1.5+2.0+3.5	1,50	1,50	1,50	2,00	---	3,55	10,00	11,67	0,54	2,06	2,55	2,60	9,50	11,70	95	4,87	A	A++	4,64	6,46	1951	1,23
	1.5+1.5+1.5+2.0+4.2	1,40	1,40	1,40	1,87	---	3,71	10,00	11,66	0,57	2,04	2,53	2,70	9,40	11,60	95	4,90	A	A++	4,64	6,46	1948	1,22
	1.5+1.5+1.5+2.0+5.0	1,30	1,30	1,30	1,74	---	4,02	10,00	11,74	0,62	2,02	2,54	2,90	9,30	11,70	95	4,94	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+2.0+6.0	1,20	1,20	1,20	1,60	---	4,35	10,00	12,00	0,67	2,02	2,63	3,10	9,30	12,10	95	4,94	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+2.0+7.1	1,10	1,10	1,10	1,47	---	4,67	10,00	11,99	0,73	2,02	2,63	3,40	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+2.5+2.5	1,58	1,58	1,58	2,63	---	3,39	10,00	11,67	0,52	2,05	2,54	2,40	9,40	11,70	95	4,87	A	A++	4,63	6,46	1952	1,23
	1.5+1.5+1.5+2.5+3.5	1,43	1,43	1,43	2,38	---	3,71	10,00	11,67	0,57	2,05	2,54	2,70	9,40	11,70	95	4,87	A	A++	4,63	6,46	1952	1,22
	1.5+1.5+1.5+2.5+4.2	1,34	1,34	1,34	2,23	---	3,87	10,00	11,66	0,59	2,04	2,52	2,80	9,40	11,60	95	4,90	A	A++	4,64	6,46	1948	1,22
	1.5+1.5+1.5+2.5+5.0	1,25	1,25	1,25	2,08	---	4,19	10,00	11,74	0,64	2,02	2,54	3,00	9,30	11,70	95	4,94	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+2.5+6.0	1,15	1,15	1,15	1,92	---	4,51	10,00	12,00	0,70	2,02	2,63	3,30	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+2.5+7.1	1,06	1,06	1,06	1,77	---	4,83	10,00	11,99	0,75	2,02	2,63	3,50	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+1.5+3.5+3.5	1,30	1,30	1,30	3,04	---	4,04	10,00	11,67	0,62	2,05	2,54	2,90	9,40	11,70	95	4,87	A	A++	4,63	6,46	1952	1,22
	1.5+1.5+1.5+3.5+4.2	1,23	1,23	1,23	2,87	---	4,20	10,00	11,66	0,65	2,04	2,52	3,00	9,40	11,60	95	4,90	A	A++	4,64	6,46	1948	1,22
	1.5+1.5+1.5+3.5+5.0	1,15	1,15	1,15	2,69	---	4,51	10,00	11,74	0,70	2,02	2,54	3,30	9,30	11,70	95	4,94	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+1.5+3.5+6.0	1,07	1,07	1,07	2,50	---	4,67	10,00	12,00	0,73	2,02	2,63	3,40	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+1.5+3.5+7.1	0,99	0,99	0,99	2,32	---	4,98	10,00	11,99	0,78	2,02	2,63	3,70	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+1.5+4.2+4.2	1,16	1,16	1,16	3,26	---	4,35	10,00	11,64	0,67	2,03	2,51	3,20	9,30	11,50	95	4,92	A	A++	4,65	6,46	1944	1,21
	1.5+1.5+1.5+4.2+5.0	1,09	1,09	1,09	3,07	---	4,66	10,00	11,84	0,72	2,02	2,57	3,40	9,30	11,90	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+1.5+4.2+6.0	1,02	1,02	1,02	2,86	---	4,98	10,00	11,97	0,78	2,02	2,62	3,70	9,30	12,10	95	4,95	A	A++	4,66	6,46	1943	1,20
	1.5+1.5+1.5+5.0+5.0	1,03	1,03	1,03	3,45	---	4,81	10,00	11,88	0,75	2,03	2,62	3,50	9,30	12,00	95	4,92	A	A++	4,63	6,46	1953	1,20
	1.5+1.5+1.5+5.0+6.0	0,97	0,97	0,97	3,23	---	5,13	10,00	12,13	0,81	2,05	2,71	3,80	9,40	12,50	95	4,88	A	A++	4,63	6,46	1954	1,19
	1.5+1.5+2.0+2.0+2.0	1,67	1,67	2,22	2,22	---	3,22	10,00	11,67	0,49	2,06	2,55	2,30	9,50	11,70	95	4,87	A	A++	4,64	6,46	1951	1,24
	1.5+1.5+2.0+2.0+2.5	1,58	1,58	2,11	2,11	---	3,39	10,00	11,67	0,52	2,05	2,54	2,40	9,40	11,70	95	4,87	A	A++	4,63	6,46	1952	1,24
	1.5+1.5+2.0+2.0+3.5	1,43	1,43	1,90	1,90	---	3,71	10,00	11,67	0,57	2,05	2,54	2,70	9,40	11,70	95	4,87	A	A++	4,63	6,46	1952	1,23
	1.5+1.5+2.0+2.0+4.2	1,34	1,34	1,79	1,79	---	3,87	10,00	11,66	0,59	2,04	2,52	2,80	9,40	11,60	95	4,90	A	A++	4,64	6,46	1948	1,23
	1.5+1.5+2.0+2.0+5.0	1,25	1,25	1,67	1,67	---	4,19	10,00	11,74	0,64	2,02	2,54	3,00	9,30	11,70	95	4,94	A	A++	4,66	6,46	1942	1,22
	1.5+1.5+2.0+2.0+6.0	1,15	1,15	1,54	1,54	---	4,51	10,00	12,00	0,70	2,02	2,63	3,30	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+2.0+7.1	1,06	1,06	1,42	1,42	---	4,83	10,00	11,99	0,75	2,02	2,63	3,50	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+2.5+2.5	1,50	1,50	2,00	2,50	---	3,55	10,00	11,67	0,54	2,05	2,54	2,60	9,40	11,70	95	4,88	A	A++	4,64	6,46	1951	1,24
	1.5+1.5+2.0+2.5+3.5	1,36	1,36	1,82	2,27	---	3,88	10,00	11,67	0,59	2,05	2,54	2,80	9,40	11,70	95	4,88	A	A++	4,64	6,46	1951	1,23
	1.5+1.5+2.0+2.5+4.2	1,28	1,28	1,71	2,14	---	4,03	10,00	11,65	0,62	2,04	2,52	2,90	9,40	11,60	95	4,91	A	A++	4,65	6,46	1947	1,22
	1.5+1.5+2.0+2.5+5.0	1,20	1,20	1,60	2,00	---	4,35	10,00	11,73	0,67	2,02	2,53	3,10	9,30	11,70	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+2.5+6.0	1,11	1,11	1,48	1,85	---	4,51	10,00	11,99	0,70	2,02	2,63	3,30	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+2.5+7.1	1,03	1,03	1,37	1,71	---	4,82	10,00	11,98	0,75	2,02	2,62	3,50	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+3.5+3.5	1,25	1,25	1,67	2,92	---	4,20	10,00	11,67	0,65	2,05	2,54	3,00	9,40	11,70	95	4,88	A	A++	4,64	6,46	1951	1,22
	1.5+1.5+2.0+3.5+4.2	1,18	1,18	1,57	2,76	---	4,36	10,00	11,65	0,67	2,04	2,52	3,20	9,40	11,60	95	4,91	A	A++	4,65	6,46	1947	1,22
5MXM90N2V19	1.5+1.5+2.0+3.5+5.0	1,11	1,11	1,48	2,59	---	4,51	10,00	11,73	0,70	2,02	2,53	3,30	9,30	11,70	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+3.5+6.0	1,03	1,03	1,38	2,41	---	4,83	10,00	11,99	0,75	2,02	2,63	3,50	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.0+3.5+7.1	0,96	0,96	1,28	2,24	---	5,14	10,00	11,98	0,81	2,02	2,62	3,80	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+2.0+4.2+4.2	1,12	1,12	1,49	3,13	---	4,51	10,00	11,63	0,70	2,03	2,51	3,30	9,30	11,50	95	4,93	A	A++	4,65	6,46	1944	1,22
	1.5+1.5+2.0+4.2+5.0	1,06	1,06	1,41	2,96	---	4,82	10,00	11,84	0,75	2,02	2,57	3,50	9,30	11,90	95	4,95	A	A++	4,66	6,46	1943	1,21
	1.5+1.5+2.0+4.2+6.0	0,99	0,99	1,32	2,76	---	5,14	10,00	11,96	0,81	2,02	2,62	3,80	9,30	12,00	95	4,95	A	A++	4,65	6,46	1943	1,20
	1.5+1.5+2.0+5.0+5.0	1,00	1,00	1,33	3,33	---	4,97	10,00	11,87	0,78	2,05	2,62	3,70	9,40	12,00	95	4,88	A	A++	4,63	6,46	1954	1,18
	1.5+1.5+2.5+2.5+2.5	1,43	1,43	2,38	2,38	---	3,71	10,00	11,66	0,57	2,05	2,53	2,70	9,40	11,70	95	4,88	A	A++	4,64	6,46	1950	1,23
	1.5+1.5+2.5+2.5+3.5	1,30	1,30	2,17	2,17	---	4,04	10,00	11,66	0,62	2,05	2,53	2,90	9,40	11,70	95	4,88	A	A++	4,64	6,46	1950	1,22
	1.5+1.5+2.5+2.5+4.2	1,23	1,23	2,05	2,05	---	4,20	10,00	11,65	0,65	2,04	2,52	3,00	9,40	11,60	95	4,91	A	A++	4,65	6,46	1946	1,22
	1.5+1.5+2.5+2.5+5.0	1,15	1,15	1,92	1,92	---	4,51	10,00	11,73	0,70	2,02	2,53	3,30	9,30	11,70	95	4,95	A	A++	4,66	6,46	1942	1,21
	1.5+1.5+2.5+2.5+6.0	1,07	1,07	1,79	1,79	---	4,67	10,00	11,99	0,73	2,02	2,62	3,40	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+2.5+2.5+7.1	0,99	0,99	1,66	1,66	---	4,98	10,00	11,98	0,78	2,02	2,62	3,70	9,30	12,10	95	4,95	A	A++	4,66	6,46	1942	1,20
	1.5+1.5+2.5+3.5+3.5	1,20	1,20	2,00	2,80	---	4,36	10,00	11,66	0,68	2,05	2,53	3,20	9,40	11,70	95	4,88	A	A++	4,64	6,46	1950	1,2

Combination tables

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)					Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	ENERGY LABEL	Seasonal data				
		A room	B room	C room	D room	E room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
5MXM90N2V1B9	1.5+2.0+2.0+4.2+4.2	1.08	1.44	1.44	3.02	---	4.67	10.00	11.63	0.73	2.03	2.50	3.40	9.30	11.50	95	4.93	A	A++	4.65	6.46	1943	1.19
	1.5+2.0+2.0+4.2+5.0	1.02	1.36	1.36	2.86	---	4.98	10.00	11.83	0.78	2.02	2.57	3.70	9.30	11.90	95	4.95	A	A++	4.66	6.46	1943	1.18
	1.5+2.0+2.0+5.0+5.0	0.97	1.29	1.29	3.23	---	5.13	10.00	11.86	0.81	2.05	2.62	3.80	9.40	12.00	95	4.88	A	A++	4.63	6.46	1955	1.16
	1.5+2.0+2.5+2.5+2.5	1.36	1.82	2.27	2.27	---	3.87	10.00	11.66	0.59	2.05	2.53	2.80	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.21
	1.5+2.0+2.5+2.5+3.5	1.25	1.67	2.08	2.08	---	4.20	10.00	11.66	0.65	2.05	2.53	3.00	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.21
	1.5+2.0+2.5+2.5+4.2	1.18	1.57	1.97	1.97	---	4.36	10.00	11.65	0.67	2.04	2.51	3.20	9.40	11.60	95	4.91	A	A++	4.65	6.46	1945	1.20
	1.5+2.0+2.5+2.5+5.0	1.11	1.48	1.85	1.85	---	4.51	10.00	11.72	0.70	2.02	2.53	3.30	9.30	11.70	95	4.95	A	A++	4.66	6.46	1942	1.19
	1.5+2.0+2.5+2.5+6.0	1.03	1.38	1.72	1.72	---	4.82	10.00	11.98	0.75	2.02	2.62	3.50	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.19
	1.5+2.0+2.5+2.5+7.1	0.96	1.28	1.60	1.60	---	5.14	10.00	11.97	0.81	2.02	2.62	3.80	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.18
	1.5+2.0+2.5+3.5+3.5	1.15	1.54	1.92	2.69	---	4.36	10.00	11.66	0.67	2.05	2.53	3.20	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.20
	1.5+2.0+2.5+3.5+4.2	1.09	1.46	1.82	2.55	---	4.68	10.00	11.65	0.73	2.04	2.51	3.40	9.40	11.60	95	4.91	A	A++	4.65	6.46	1945	1.20
	1.5+2.0+2.5+3.5+5.0	1.03	1.38	1.72	2.41	---	4.83	10.00	11.72	0.75	2.02	2.53	3.50	9.30	11.70	95	4.95	A	A++	4.66	6.46	1942	1.19
	1.5+2.0+2.5+3.5+6.0	0.97	1.29	1.61	2.26	---	5.14	10.00	11.98	0.81	2.02	2.62	3.80	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.16
	1.5+2.0+2.5+4.2+4.2	1.04	1.39	1.74	2.92	---	4.83	10.00	11.63	0.76	2.03	2.50	3.50	9.30	11.50	95	4.93	A	A++	4.65	6.46	1943	1.19
	1.5+2.0+2.5+4.2+5.0	0.99	1.32	1.64	2.76	---	5.14	10.00	11.82	0.81	2.02	2.57	3.80	9.30	11.90	95	4.95	A	A++	4.65	6.46	1943	1.18
	1.5+2.0+3.5+3.5+3.5	1.07	1.43	2.50	2.50	---	4.68	10.00	11.66	0.73	2.05	2.53	3.40	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.20
	1.5+2.0+3.5+3.5+4.2	1.02	1.36	2.38	2.38	---	5.00	10.00	11.65	0.79	2.04	2.51	3.70	9.40	11.60	95	4.91	A	A++	4.65	6.46	1945	1.19
	1.5+2.0+3.5+3.5+5.0	0.97	1.29	2.26	2.26	---	5.14	10.00	11.72	0.81	2.02	2.53	3.80	9.30	11.70	95	4.95	A	A++	4.66	6.46	1942	1.18
	1.5+2.0+3.5+4.2+4.2	0.97	1.30	2.27	2.73	---	5.15	10.00	11.63	0.81	2.03	2.50	3.80	9.30	11.50	95	4.93	A	A++	4.65	6.46	1943	1.19
	1.5+2.5+2.5+2.5+2.5	1.30	2.17	2.17	2.17	---	4.04	10.00	11.66	0.62	2.04	2.53	2.90	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.21
	1.5+2.5+2.5+2.5+3.5	1.20	2.00	2.00	2.00	---	4.36	10.00	11.66	0.67	2.04	2.53	3.20	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.20
	1.5+2.5+2.5+2.5+4.2	1.14	1.89	1.89	1.89	---	4.52	10.00	11.64	0.70	2.03	2.51	3.30	9.40	11.60	95	4.92	A	A++	4.65	6.46	1945	1.19
	1.5+2.5+2.5+2.5+5.0	1.07	1.79	1.79	1.79	---	4.66	10.00	11.71	0.72	2.02	2.53	3.40	9.30	11.60	95	4.95	A	A++	4.66	6.46	1942	1.18
	1.5+2.5+2.5+2.5+6.0	1.00	1.67	1.67	1.67	---	4.98	10.00	11.97	0.78	2.02	2.62	3.70	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.18
	1.5+2.5+2.5+3.5+3.5	1.11	1.85	1.85	2.59	---	4.52	10.00	11.66	0.70	2.04	2.53	3.30	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.19
	1.5+2.5+2.5+3.5+4.2	1.06	1.76	1.76	2.46	---	4.84	10.00	11.64	0.76	2.03	2.51	3.50	9.40	11.60	95	4.92	A	A++	4.65	6.46	1945	1.19
	1.5+2.5+2.5+3.5+5.0	1.00	1.67	1.67	2.33	---	4.98	10.00	11.71	0.78	2.02	2.53	3.70	9.30	11.60	95	4.95	A	A++	4.66	6.46	1942	1.18
	1.5+2.5+2.5+4.2+4.2	1.01	1.68	1.68	2.82	---	4.99	10.00	11.62	0.78	2.03	2.50	3.70	9.30	11.50	95	4.93	A	A++	4.66	6.46	1943	1.19
	1.5+2.5+3.5+3.5+3.5	1.03	1.72	2.41	2.41	---	4.84	10.00	11.66	0.76	2.04	2.53	3.60	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.19
	1.5+2.5+3.5+3.5+4.2	0.99	1.64	2.30	2.30	---	5.00	10.00	11.64	0.79	2.03	2.51	3.70	9.40	11.60	95	4.92	A	A++	4.65	6.46	1945	1.19
	1.5+3.5+3.5+3.5+5.0	0.97	2.26	2.26	2.26	---	5.16	10.00	11.66	0.82	2.04	2.53	3.80	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.18
	2.0+2.0+2.0+2.0+2.0	2.00	2.00	2.00	2.00	---	3.55	10.00	11.67	0.54	2.05	2.54	2.60	9.40	11.70	95	4.88	A	A++	4.64	6.46	1951	1.20
	2.0+2.0+2.0+2.0+2.5	1.90	1.90	1.90	1.90	---	3.71	10.00	11.66	0.57	2.05	2.53	2.70	9.40	11.70	95	4.88	A	A++	4.64	6.46	1950	1.19
	2.0+2.0+2.0+2.0+3.5	1.74	1.74	1.74	1.74	---	4.04	10.00	11.66	0.62	2.05	2.53	2.90	9.40	11.70	95	4.88	A	A++	4.64	6.46	1950	1.19
	2.0+2.0+2.0+2.0+4.2	1.64	1.64	1.64	1.64	---	4.20	10.00	11.65	0.65	2.04	2.52	3.00	9.40	11.60	95	4.91	A	A++	4.65	6.46	1946	1.18
	2.0+2.0+2.0+2.0+5.0	1.54	1.54	1.54	1.54	---	4.51	10.00	11.73	0.70	2.02	2.53	3.30	9.30	11.70	95	4.95	A	A++	4.66	6.46	1942	1.17
	2.0+2.0+2.0+2.0+6.0	1.43	1.43	1.43	1.43	---	4.67	10.00	11.99	0.73	2.02	2.62	3.40	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.17
	2.0+2.0+2.0+2.0+7.1	1.32	1.32	1.32	1.32	---	4.98	10.00	11.98	0.78	2.02	2.62	3.70	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.16
	2.0+2.0+2.0+2.5+2.5	1.82	1.82	1.82	2.27	---	3.87	10.00	11.66	0.59	2.05	2.53	2.80	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.19
	2.0+2.0+2.0+2.5+3.5	1.67	1.67	1.67	2.08	---	4.20	10.00	11.66	0.65	2.05	2.53	3.00	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.18
	2.0+2.0+2.0+2.5+4.2	1.57	1.57	1.57	1.97	---	4.36	10.00	11.65	0.67	2.04	2.51	3.20	9.40	11.60	95	4.91	A	A++	4.65	6.46	1945	1.18
	2.0+2.0+2.0+2.5+5.0	1.48	1.48	1.48	1.85	---	4.51	10.00	11.72	0.70	2.02	2.53	3.30	9.30	11.70	95	4.95	A	A++	4.66	6.46	1942	1.17
	2.0+2.0+2.0+2.5+6.0	1.38	1.38	1.38	1.72	---	4.82	10.00	11.98	0.75	2.02	2.62	3.50	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.16
	2.0+2.0+2.0+2.5+7.1	1.28	1.28	1.28	1.60	---	5.14	10.00	11.97	0.81	2.02	2.62	3.80	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.16
	2.0+2.0+2.0+3.5+3.5	1.54	1.54	1.54	2.69	---	3.87	10.00	11.66	0.59	2.05	2.53	2.80	9.40	11.70	95	4.89	A	A++	4.64	6.46	1949	1.18
	2.0+2.0+2.0+3.5+4.2	1.46	1.46	1.46	2.55	---	4.68	10.00	11.65	0.73	2.04	2.51	3.40	9.40	11.60	95	4.91	A	A++	4.65	6.46	1945	1.18
	2.0+2.0+2.0+3.5+5.0	1.38	1.38	1.38	2.41	---	4.83	10.00	11.72	0.75	2.02	2.53	3.50	9.30	11.70	95	4.95	A	A++	4.66	6.46	1942	1.16
	2.0+2.0+2.0+3.5+6.0	1.29	1.29	1.29	2.26	---	5.14	10.00	11.98	0.81	2.02	2.62	3.80	9.30	12.10	95	4.95	A	A++	4.66	6.46	1942	1.16
	2.0+2.0+2.0+4.2+4.2	1.39	1.39	1.39	2.92	---	4.83	10.00	11.63	0.76	2.03	2.50	3.50	9.30	11.50	95	4.93	A	A++	4.65	6.46	1943	1.17
	2.0+2.0+2.0+4.2+5.0	1.32	1.32	1.32	2.76	---	5.14	10.00	11.82	0.81	2.02	2.57	3.80	9.30	11.90	95	4.95	A	A++	4.65	6.46	1943	1.16
	2.0+2.0+2.5+2.5+2.5	1.74	1.74	2.17	2.17	---	4.04	10.00	11.66	0.62	2.04	2.53	2.90	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.19
	2.0+2.0+2.5+2.5+3.5	1.60	1.60	2.00	2.00	---	4.36	10.00	11.66	0.67	2.04	2.53	3.20	9.40	11.60	95	4.89	A	A++	4.64	6.46	1948	1.18
	2.0+2.0+2.5+2.5+4.2	1.52	1.52	1.89	1.89	---	4.52	10.00	11.64	0.70	2.03	2.51	3.30	9.40	11.60	95	4.92	A	A++	4.65	6.46	1945	1.18
	2.0+2.0+2.5+2.5+5.0	1.43	1.43	1.79	1.79	---	4.66	10.00	11.71	0.72	2.02	2.53	3.40	9.30	11.60	95	4.95	A	A++	4.66	6.46	1942	1.17
	2.0+2.0+2.5+2.5+6.0	1.33	1.33	1.67	1.67	---	4.98	10.00	11.97	0.78	2.02	2.62	3.70	9.30	12.10	95	4.95	A	A++	4.66	6.46	19	

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
2AMXM40M3V1B	2.0	2.00	---	1.30	2.00	2.40	0.33	0.44	0.57	1.78	2.38	3.09	79	---	---	---	---	---	---	---
	2.5	2.50	---	1.30	2.50	3.00	0.33	0.61	0.80	1.78	3.33	4.40	79	---	---	---	---	---	---	---
	3.5	3.50	---	1.30	3.50	4.00	0.33	1.04	1.35	1.78	5.71	7.38	79	---	---	---	---	---	---	---
	2.0+2.0	2.00	2.00	1.50	4.00	4.20	0.30	0.99	1.04	1.67	5.47	5.75	79	4.03	A	497	A+++	8.51	4.00	165
	2.0+2.5	1.78	2.22	1.50	4.00	4.30	0.30	0.97	1.04	1.67	5.34	5.75	79	4.13	A	485	A+++	8.50	4.00	165
	2.0+3.5	1.45	2.55	1.50	4.00	4.50	0.30	0.97	1.10	1.67	5.36	6.03	79	4.11	A	487	A++	8.17	4.00	172
	2.5+2.5	2.00	2.00	1.50	4.00	4.40	0.30	0.98	1.08	1.67	5.39	5.93	79	4.09	A	489	A++	8.34	4.00	168
2.5+3.5	1.67	2.33	1.50	4.00	4.60	0.30	0.96	1.11	1.67	5.31	6.11	79	4.15	A	482	A++	8.09	4.00	173	

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	Energy label	Seasonal data				
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				Label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
2AMXM40M3V1B	2.0	3.00	---	1.00	3.00	3.70	0.26	0.83	1.26	1.43	4.52	6.78	79	---	---	---	---	---	---	---
	2.5	3.40	---	1.00	3.40	4.10	0.26	1.02	1.50	1.43	5.59	8.09	79	---	---	---	---	---	---	---
	3.5	3.80	---	1.00	3.80	4.40	0.26	1.28	1.73	1.43	7.02	9.40	79	---	---	---	---	---	---	---
	2.0+2.0	2.10	2.10	1.30	4.20	4.60	0.24	1.00	1.10	1.31	5.53	6.06	79	4.18	A	A++	4.60	3.20	973	0.60
	2.0+2.5	1.87	2.33	1.30	4.20	4.70	0.24	1.00	1.12	1.31	5.48	6.14	79	4.22	A	A++	4.60	3.20	974	0.50
	2.0+3.5	1.53	2.67	1.30	4.20	4.80	0.24	0.97	1.12	1.31	5.37	6.14	79	4.31	A	A++	4.60	3.20	974	0.40
	2.5+2.5	2.10	2.10	1.30	4.20	4.70	0.24	0.98	1.10	1.31	5.42	6.07	79	4.27	A	A++	4.60	3.20	973	0.50
2.5+3.5	1.75	2.45	1.30	4.20	4.80	0.24	0.96	1.10	1.31	5.31	6.07	79	4.36	A	A++	4.60	3.20	974	0.40	

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
2AMXM50M3V1B	2.0	2.00	---	1.40	2.00	2.60	0.31	0.47	0.69	1.53	2.25	3.37	89	---	---	---	---	---	---	---
	2.5	2.50	---	1.40	2.50	3.10	0.31	0.67	0.92	1.53	3.27	4.50	89	---	---	---	---	---	---	---
	3.5	3.50	---	1.40	3.50	4.00	0.31	1.09	1.42	1.53	5.32	6.95	89	---	---	---	---	---	---	---
	5.0	5.00	---	1.60	5.00	5.30	0.33	0.96	1.46	1.64	4.67	7.11	89	---	---	---	---	---	---	---
	2.0+2.0	2.00	2.00	1.80	4.00	5.00	0.43	0.96	1.30	2.12	4.71	5.89	89	4.15	A	482	A+++	8.68	4.00	162
	2.0+2.5	2.00	2.50	1.80	4.50	5.10	0.44	1.09	1.33	2.14	5.35	6.07	89	4.11	A	548	A+++	8.65	4.50	183
	2.0+3.5	1.82	3.18	1.80	5.00	5.40	0.46	1.27	1.51	2.24	6.20	6.70	89	3.94	A	635	A+++	8.51	5.00	206
	2.0+5.0	1.43	3.57	1.80	5.00	5.50	0.45	1.25	1.46	2.20	6.10	6.71	89	4.01	A	624	A+++	8.50	5.00	206
	2.5+2.5	2.50	2.50	1.80	5.00	5.30	0.46	1.28	1.44	2.25	6.25	6.63	89	3.91	A	640	A+++	8.51	5.00	206
	2.5+3.5	2.08	2.92	1.80	5.00	5.40	0.46	1.26	1.45	2.23	6.17	6.67	89	3.96	A	632	A+++	8.53	5.00	206
	2.5+5.0	1.67	3.33	1.80	5.00	5.50	0.45	1.24	1.40	2.19	6.07	6.68	89	4.03	A	621	A+++	8.51	5.00	206
	3.5+3.5	2.50	2.50	1.80	5.00	5.40	0.45	1.25	1.43	2.20	6.10	6.59	89	4.01	A	624	A+++	8.55	5.00	205
3.5+5.0	2.06	2.94	1.80	5.00	5.50	0.44	1.23	1.35	2.16	5.99	6.59	89	4.08	A	613	A+++	8.50	5.00	206	

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)		Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	Energy label	Seasonal data				
		A room	B room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				Label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
2AMXM50M3V1B	2.0	3.00	---	1.10	3.00	3.70	0.27	0.82	1.15	1.33	3.99	5.52	89	---	---	---	---	---	---	---
	2.5	3.40	---	1.10	3.40	4.10	0.25	0.99	1.36	1.23	4.81	6.54	89	---	---	---	---	---	---	---
	3.5	4.00	---	1.10	4.00	4.60	0.25	1.24	1.55	1.23	6.03	7.46	89	---	---	---	---	---	---	---
	5.0	5.50	---	1.20	5.50	5.60	0.23	1.23	1.58	1.12	6.01	9.01	89	---	---	---	---	---	---	---
	2.0+2.0	2.60	2.60	1.20	5.20	5.70	0.30	1.30	1.42	1.47	6.37	6.99	89	3.99	A	A++	4.60	4.00	1216	0.60
	2.0+2.5	2.49	3.11	1.20	5.60	5.80	0.30	1.40	1.44	1.47	6.84	7.09	89	4.00	A	A++	4.60	4.10	1246	0.70
	2.0+3.5	2.04	3.56	1.20	5.60	5.90	0.30	1.40	1.45	1.47	6.83	7.20	89	4.01	A	A++	4.60	4.20	1278	0.80
	2.0+5.0	1.60	4.00	1.20	5.60	6.20	0.30	1.38	1.52	1.45	6.76	7.49	89	4.05	A	A++	4.67	4.20	1258	0.80
	2.5+2.5	2.80	2.80	1.20	5.60	5.80	0.30	1.41	1.44	1.48	6.88	7.13	89	3.98	A	A++	4.60	4.20	1278	0.80
	2.5+3.5	2.33	3.27	1.20	5.60	6.00	0.31	1.42	1.50	1.49	6.93	7.43	89	3.95	A	A++	4.61	4.20	1274	0.80
	2.5+5.0	1.87	3.73	1.30	5.60	6.30	0.33	1.42	1.60	1.61	6.93	7.80	89	3.95	A	A++	4.70	4.20	1252	0.80
	3.5+3.5	2.80	2.80	1.30	5.60	6.10	0.33	1.41	1.54	1.60	6.88	7.50	89	3.98	A	A++	4.65	4.20	1264	0.80
	3.5+5.0	2.31	3.29	1.30	5.60	6.40	0.33	1.43	1.65	1.63	7.00	8.00	89	3.91	A	A++	4.74	4.20	1240	0.80

Combination tables

Cooling

Outdoor unit	Indoor unit	Cooling capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	EER	Energy label	AEC (kWh)	Seasonal data			
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.					Label	SEER	Pdesign	AEC
3AMXM52N2V1B9	2.0	2.00	---	---	1.60	2.00	3.00	0.36	0.48	0.78	1.60	2.17	3.51	96	---	---	---	---	---	---	
	2.5	2.50	---	---	1.60	2.50	3.20	0.36	0.64	0.87	1.62	2.89	3.92	96	---	---	---	---	---	---	
	3.5	3.50	---	---	1.60	3.50	4.20	0.37	0.98	1.30	1.63	4.43	5.88	96	---	---	---	---	---	---	
	5.0	---	5.00	---	1.60	5.00	5.40	0.35	1.76	2.03	1.55	7.94	9.18	96	---	---	---	---	---	---	
	2.0+2.0	2.00	2.00	---	1.70	4.00	6.00	0.35	0.87	2.61	1.55	3.95	11.81	96	4.62	A	433	A+++	8.50	4.00	165
	2.0+2.5	2.00	2.50	---	1.70	4.50	6.20	0.35	0.96	2.35	1.55	4.35	10.61	96	4.72	A	477	A+++	8.50	4.50	186
	2.0+3.5	1.89	3.31	---	1.70	5.20	6.30	0.35	1.14	2.50	1.55	5.17	11.31	96	4.60	A	566	A+++	8.50	5.20	215
	2.0+5.0	1.49	3.71	---	1.70	5.20	6.50	0.35	1.11	2.37	1.55	5.03	10.72	96	4.72	A	551	A+++	8.50	5.20	215
	2.5+2.5	2.50	2.50	---	1.70	5.00	6.30	0.35	1.18	2.50	1.55	5.35	11.32	96	4.24	A	590	A+++	8.50	5.00	206
	2.5+3.5	2.17	3.03	---	1.70	5.20	6.30	0.35	1.25	2.40	1.55	5.67	10.83	96	4.18	A	623	A+++	8.50	5.20	215
	2.5+5.0	1.73	3.47	---	1.70	5.20	6.50	0.35	1.21	2.39	1.55	5.49	10.82	96	4.32	A	602	A+++	8.50	5.20	214
	3.5+3.5	2.60	2.60	---	1.70	5.20	6.40	0.35	1.24	2.37	1.55	5.62	10.72	96	4.22	A	617	A+++	8.50	5.20	214
	3.5+5.0	2.14	3.06	---	1.70	5.20	6.60	0.35	1.20	2.39	1.55	5.44	10.82	96	4.34	A	600	A+++	8.50	5.20	214
	2.0+2.0+2.0	1.73	1.73	1.73	1.80	5.20	7.00	0.37	1.22	2.20	1.65	5.53	9.94	96	4.27	A	609	A+++	8.50	5.20	215
	2.0+2.0+2.5	1.60	1.60	2.00	1.80	5.20	7.00	0.37	1.20	2.19	1.65	5.44	9.89	96	4.34	A	600	A+++	8.50	5.20	215
	2.0+2.0+3.5	1.39	1.39	2.43	1.90	5.20	7.20	0.39	1.20	2.15	1.75	5.44	9.69	96	4.36	A	597	A+++	8.50	5.20	214
	2.0+2.0+5.0	1.16	1.16	2.89	2.00	5.20	7.30	0.37	1.17	2.06	1.65	5.30	9.29	96	4.45	A	585	A++	8.09	5.20	225
	2.0+2.5+2.5	1.49	1.86	1.86	1.80	5.20	7.10	0.39	1.19	2.10	1.75	5.39	9.49	96	4.38	A	594	A+++	8.50	5.20	215
	2.0+2.5+3.5	1.30	1.63	2.28	1.90	5.20	7.20	0.39	1.18	2.12	1.75	5.35	9.59	96	4.41	A	590	A+++	8.50	5.20	215
	2.0+3.5+3.5	1.16	2.02	2.02	1.90	5.20	7.30	0.39	1.18	2.12	1.75	5.35	9.59	96	4.42	A	589	A+++	8.50	5.20	215
	2.5+2.5+2.5	1.73	1.73	1.73	1.90	5.20	7.10	0.39	1.19	2.17	1.75	5.39	9.79	96	4.40	A	591	A+++	8.50	5.20	215
	2.5+2.5+3.5	1.53	1.53	2.14	1.90	5.20	7.20	0.39	1.18	2.13	1.75	5.35	9.64	96	4.42	A	589	A+++	8.50	5.20	215

Heating

Outdoor unit	Indoor unit	Heating capacity (kW)			Total capacity (kW)			Power input (kW)			Total current (A)			Power factor (%)	COP	Energy label	Seasonal data				
		A room	B room	C room	Min.	Nom.	Max.	Min.	Nom.	Max.	Min.	Nom.	Max.				Label	SCOP	Pdesign	AEC	Back-up heater capacity at -10°C
3AMXM52N2V1B9	2.0	2.70	---	---	1.10	2.70	3.80	0.30	0.76	1.29	1.34	3.40	5.57	96	---	---	---	---	---	---	
	2.5	3.40	---	---	1.10	3.40	4.00	0.30	1.01	1.38	1.34	4.54	5.78	96	---	---	---	---	---	---	
	3.5	4.20	---	---	1.10	4.20	4.80	0.30	1.42	1.76	1.34	6.39	7.73	96	---	---	---	---	---	---	
	5.0	---	5.80	---	1.10	5.80	6.80	0.30	2.17	2.60	1.34	9.80	11.76	96	---	---	---	---	---	---	
	2.0+2.0	3.40	3.40	---	1.20	6.80	7.00	0.32	1.63	2.28	1.44	7.39	10.61	96	4.18	A	A+	4.23	4.80	1588	0.9
	2.0+2.5	3.02	3.78	---	1.20	6.80	7.00	0.32	1.62	2.27	1.44	7.34	10.51	96	4.22	A	A+	4.26	4.80	1577	0.9
	2.0+3.5	2.47	4.33	---	1.20	6.80	7.10	0.32	1.61	2.28	1.44	7.30	10.41	96	4.24	A	A+	4.29	4.80	1566	0.8
	2.0+5.0	1.94	4.86	---	1.40	6.80	7.20	0.32	1.56	2.30	1.44	7.07	10.32	96	4.36	A	A+	4.46	4.80	1505	0.7
	2.5+2.5	3.40	3.40	---	1.20	6.80	7.00	0.32	1.57	2.25	1.44	7.12	10.62	96	4.35	A	A+	4.34	4.80	1533	0.9
	2.5+3.5	2.83	3.97	---	1.30	6.80	7.20	0.32	1.56	2.37	1.44	7.07	10.73	96	4.36	A	A+	4.37	4.80	1537	0.8
	2.5+5.0	2.27	4.53	---	1.40	6.80	7.40	0.32	1.54	2.35	1.44	6.98	10.52	96	4.44	A	A+	4.49	4.80	1495	0.7
	3.5+3.5	3.40	3.40	---	1.40	6.80	7.30	0.32	1.55	2.40	1.44	7.02	11.02	96	4.40	A	A+	4.36	5.00	1604	0.9
	3.5+5.0	2.80	4.00	---	1.45	6.80	7.50	0.32	1.53	2.32	1.44	6.93	10.72	96	4.46	A	A+	4.48	5.00	1548	0.8
	2.0+2.0+2.0	2.27	2.27	2.27	1.30	6.80	8.00	0.32	1.42	2.15	1.44	6.44	9.99	96	4.81	A	A++	4.60	5.00	1521	0.9
	2.0+2.0+2.5	2.09	2.09	2.62	1.30	6.80	8.00	0.32	1.41	2.13	1.44	6.39	9.89	96	4.85	A	A++	4.61	5.00	1519	0.9
	2.0+2.0+3.5	1.81	1.81	3.17	1.40	6.80	8.10	0.32	1.40	2.14	1.44	6.35	9.99	96	4.88	A	A++	4.62	5.00	1514	0.9
	2.0+2.0+5.0	1.51	1.51	3.78	1.60	6.80	8.30	0.32	1.31	2.10	1.44	5.94	9.59	96	5.20	A	A++	4.76	5.00	1468	0.8
	2.0+2.5+2.5	1.94	2.43	2.43	1.30	6.80	8.00	0.32	1.40	2.11	1.44	6.35	9.79	96	4.89	A	A++	4.62	5.00	1514	0.9
	2.0+2.5+3.5	1.70	2.13	2.98	1.50	6.80	8.10	0.32	1.38	2.13	1.44	6.25	9.89	96	4.93	A	A++	4.63	5.00	1510	0.9
	2.0+3.5+3.5	1.51	2.64	2.64	1.50	6.80	8.20	0.32	1.38	2.17	1.44	6.25	9.69	96	4.95	A	A++	4.64	5.00	1507	0.9
	2.5+2.5+2.5	2.27	2.27	2.27	1.40	6.80	8.00	0.32	1.39	2.09	1.44	6.30	9.69	96	4.92	A	A++	4.61	5.00	1505	0.9
	2.5+2.5+3.5	2.00	2.00	2.80	1.50	6.80	8.10	0.32	1.38	2.11	1.44	6.25	9.74	96	4.95	A	A++	4.64	5.00	1509	0.9